Navi Mumbai Campus

Date	Complain No -	Location	Nature of complain	complain against action	HOD/I Sig.	For Info ↓ Electri- Sig.
25/4/22	1.	6th Floor F.M.W. complain by Phone.	① Ceiling Fan not working ② One Side Power Supply is not working	old ceiling Fans removed 08 Nos For repair and Repaired ceiling Fan Fiting 08 Nos 40 A RCCB was Trip RCCB reset and on: 25/4	Parvinder SIN.	By
—11—	2.	5th Floor M.M.W. complain by Phone	Ceiling Fans are not working	old ceiling Fan removed For repair - 03 Nos Repaired ceiling Fan Fiting and connection 02 Nos work done 25/4	Shamkant	By
—11—	3.	3rd Floor MICU	Tube lights are not working 16 Nos	2'x2' LED Lights New Replaced = 08 Nos old Tube lights Removed - 08 Nos work done. 25/4	for Priyanka (NPCC)	By
—11—	4.	3rd Floor O.T. complain by W/G	D.B. 19 cover not Fixed	D.B. No - 19 cover properly fixed work done 25/4	By W/G	By
—11—	5.	2nd Floor Toilet Room complain by W/G	Tube light not working	old 15 W LED removed and new 22 W LED Panel Lights Fixed - 01 Nos work done. 25/4	Mr. Shankar	By

• Vivid Colours: Richer, brighter images & graphics
✓ Excellent runnability
Creating lasting impressions

Date	Complain No.	Location	Nature of complain	Action Taken against complaint	HOD / I Sig	Electri- Sig.
26/4/22	6.	Ground Floor Sonograpy	wall Fan is not working 01 Nos	wall fan new Fiting and connection of Nos work done	KBadi 29/4/2022	By
—11—	7.	2nd Floor F.M.W. complain by Letter	New wall Fan Required = 01 Nos	wall Mounted new Fan Fiting and connection of Nos work done	Priyanka 26/4/22	By
—11—	8.	3rd Floor MICU complain by Letter	Tube lights not working in changing Room 01 and Patient Bed Side Tube Lights not working 07 Nos	· Panel LED Lights old Removed New Panel LED Lights Fiting and connection Patient Bed Side 07 Nos and/ Male changing room 01 Nos work done	for Priyanka (NPCC) 26/4	By
—11—	9.	3rd Floor O.T. Passage & MICU	wall Fan Required 01 Nos	16" wall Fan new Fiting 01 Nos	Sanjay Kadam 26/4	By
—11—	10.	2nd Floor Opthal Dep.	A.C. Power Supply was Trip	we are checked Power Supply and Found Under Size MCB 10A we are Replaced 16A MCB and/ checked A.C. power	Anita 27/4/22	By

Date	complain No-	Location	Nature of complain	Action Taken against complain	HOD/W/I Sig	Electrical Sig.
		6TH Floor	Ceiling Fans	old not working		
27/4/22	11	F.M.W. complain by W/G 27/4/22	are not working - 16 Nos	Ceiling Fans Removed For repair - 16 Nos Repaired Ceiling Fans Fitting and connection 16 Nos work done. 27/4/22	S/N Reshma	By
		3rd Floor				
27/4/22	12.	MICU complain by W/G	Exhaust Fan is not working 01 Nos Bed No - 10	wire connection was - loose we are connected propry wire in Ceiling rose work done	S/N. Vidya	By
		4TH Floor				
27/4/22	13.	Pediatric ward complain by phone	10A MCB Trip	we are checked power Supply one mcb load 3 ~~Switch~~ Switch Board and one 1.5 Ton A.C. 10A MCB Trip Reset and on work done.	27/4/2022	By
-11-	14.	Ground Floor Pharmacy	Switch Board Sifting work.	6A X2 P.P. Removing 01 Nos 6A X2 P.P. fixing 01 Nos work done - 27/4/22	27/04/22	By

Date C.R.D.	complain No.	Location	Nature of complain	Action Taken Against complain	HOD / W/I Sig.	Electri- Sig.
		4th Floor				
27/4/22	15	Peadiatric Dep.	A.C. power Supply is not working 01 Nos	10 A MCB Replace with 16 A MCB S.P. Nos- 01 work done - 27/4/22		
		4th Floor				
28/4/22	16.	Pediatrik Dep- complain by W/G 27/4	18 watt 4' LED Lights is not working - 01 Nos	20 watt LED Fiting and connection - 01 Nos work done - 28/4		
		Ground Floor				
28/4/22	17	metron office complain by phone. 28/4	Tube Lighty not working 01 Nos	we have checked power Supply wire was desconneced From ceiling rose we conneced phase wire in ceiling Rose work done. 28/4/22	MRBendre	
—11—	18.	3rd Floor O.T. Complain by W/G.	24" wall fany Requiered 01 Nos	24" new wall Fan Fiting in patient Relatibe waiting areas Front OF O.T. work done 28/4	SG Sanjay Kadam	

complain Rec. Date	complain No.	Location	Nature of complain	Action Taken against complain	HOD / W/I Sig.	Electri Sig.
29/4/22	19.	Ground Floor Reception Order by H.D. Sir	New wiring Required For PA System	New wiring work is completed P.A. System is proper working and Operatin From Reception counter work done 29/4/22	Mr. Anil Khandkare.	By
— 11 —	20.	4th Floor Medicine Dep complain by Phone.	One ceiling Fan is not working One Tube light is not working 2 capacitor fitting & connection	Old ceiling Fan Removed For Repair or rewinding One Repaired ceiling Fan Fiting and connection One Tube light 36 W x 2' x 2' Fiting and connection work done 29/4/22	Umate	By
— 11 —	21.	1st Floor Opthal O.P.D. complain by Phone.	Ceiling Fans not proper working 03 Nos	Ceiling fan capacitor new Fitting and connection - 03 Nos work done. 29/4/22	Ptelawane 29-4-22	By
— 11 —	22	3rd Floor Special Room	Room - 6, 8, 14 Bath room plate Fixing work pending	6'x6" Aqralic Sheet Fixing 03 Nos in Room No - 6, 8, 14 work done 29/4/22	Umate. 486.	By

complain Received Date	complain No ↓	Location	Nature of complain	Action Taken against complain	comlain At. Date complete	Electri- Sig.	HOD/W/I Sig.
		3rd Floor					
29/4/22	23.	PICU complain by phone	ceiling Fan is not working 01 Nos	old not working ceiling Fans removed For Repair – 01 Nos C- Repaired ceiling Fan Fitting and connection 01 Nos	29/4/22		29/4
29/4/22	24.	Ground Floor Minor O.T.	Tube lights are not working 03 Nos	old Tube light Removed 03 Nos	29/4/22		S/N Kerwity
30/4/22	25.	Ground Floor Fire control Room	P.A. System Check with UPS Supply work. 1) OPD Building 2) Hospital Building.	P.A. System checked Normaly working in OPD Building checked Found OK work done 30/04/22	30/4/22		
30/4/22	26.	3rd Floor Ortho O.T. No-02 Comp. by. Phone	Ceiling Tube lights are not working	18 w 4 Pin PLL LED Lights Fitting and connection work done.	30/4/22		
30/4/22	27.	5th Floor MMW Complain by W/G	Ceiling Fan is not working.	old ceiling Fan Removed For Repair and Repaired ceiling Fan Fitting and connection 4 Nos work done	30/4/22		Bankole

complain Rec. Date	complain No↓	Location	Nature of complain	Action Taken against complain	complain Date complete	Electri- Sig	HOD/W/I Sig.
		3rd Floor					
30/4/22	28.	P.I.C.U. complain by Letter	Table Fans are required 02 NOS For PICU in Side 02 NOS For PICU Front Side Passge	Table Fans Fixing 02 Nos and wall Fans Fixing 02 NOS work done	30/4/22		Cable S/N Commandos 30/4/22
		6th Floor					
30/4/22	29.	Respiratory Medicine Ward comp by Phone.	Geyser is not working 01 NOS	3 KW. 3 Leter capacity Racal Geyser Body was Broken and in Side Nut bolt was rusted it is not repairble Removing work done	30/4/22		21/05/22
		2nd Floor					
30/4/22	30.	E N T. W. complain by Phone	Power Supply is OFF in one Side ward.	40 A, 100MA, R.C.C.B. was Trip due to ceiling Fan wire Toch in ceiling fan body we connected wire in connector and RECB ON power Supply is ok work done	30/4/22		
		Ground Floor					
30/4/22	31.	Minor O.T.	New ceiling Lights are required 03 NOS.	15 watt New Panel LED Fiting and connection 03 Nos work done	30/4/22		S/N Kavita
30/4/22	32	Female Medicale Ward 4th floor	Power point not working	40 Amp mcb trip > mcb restart power point is OK	30/4/22		BBaij

• Vivid Colours: Richer, brighter images
✓ Excellent runnability
Creating lasting impressions

complain Rec-Date	complain No-	Location	Nature of complain	Action Taken against complain	complain Atd-Date comlete	Elect- Sig	HOD/W/I Sig.
2/5/22	33.	2nd Floor cardiology OPD comp. by phone.	Power Supply was OFF	checked main Switch was OFF we did on MCCB 4 Pol Power Supply is on. work done	2/5/22		
—11—	34.	2nd Floor Pea. OPD compl by phone	Power Supply was OFF	4 Pol RCCB was off due to over Load S.P. MCB which is Supplying in A.C. 1.5 Ton we replaced 16A SP MCB of 10A work done power Supply is ON	2/5/22		
—11—	35.	3rd Floor CVTS ward comp by W/G	Switch Board hanging	Switch Board properly fixed	2/5/22		
—11—	36.	2nd Floor ENT Ward comp by phone.	Ceiling Fan is not working	ceiling fan removed for repairing. Repaired ceiling fan fitting & connection —— 1 Nos	2/5/22		

complain Ree-Date	complain Nos	Location	Nature of complain	Action Taken Against complain	complain ~~Act. Date~~ complete date	Ele. Sig	HOD/WI sig.
		6th Floor					
2/5/22	37	Repiratory Medicine ward c/by W/G.	Ceiling Fans are not working. Tube lights are not working.	No - complain			
2/5/22	38)	6th floor PFMW ward c/by W/G	Ceiling fans are not working Tube lights are not working	Old ceiling fan removed for repaired and 2 repaired cieling fan fitting and connection - 2 nos 22 W new LED fitting and connection - 2 Nos Work done	2/5/22	By	Rytul
		3rd Floor					
4/5/22	39.	MICU	2'X2' 36 watt T.L. is not working of 1 Nos in MICU and 15 W LED Lights are not working of 1 Nos	2'X2' 36W T.L. wire was Loos connection we are reconnected wire 36 W T.L. is working in MICU	4/5/22	By	Markays (CAPCC)
				Bath Room Requered 15 W □ Panel LED - 06 Nos please make Letter	4/5/22	By	For required mark Markays CAPCC
		2nd Floor					
4/5/22	40.	OPD cardiology	6A Swith was Broken	6A Switch Replaced work done	4/5/22	By	Bul

Creating lasting impressions

4/5/22	41.	3rd Floor CSSD	6A Switch of 6A Socket of was Burnt	6A Switch replaced of 6A Socket replaced of work done	4/5/22	By	Elg Sanjay Dutt
4/5/22	42.	~~2nd~~ 1st Floor ENT OPD	Ceiling Fans are not working 03 Nos	2.5 MFD Fan capacitor replaced 03 Nos work done.	4/5/22	By	OPTelangana
4/5/22	43	2nd Floor pediatric OPD	power Supply was off	10A. S.P. MCB Trip Reset and ON work done.	4/5/22	By	Sahu 5/22
4/5/22	44	2nd Floor Female ortho ward	ceiling fan not working	ceiling fan removed for Repairing & Repaired ceiling fan fitting and conn — 1Nos	4/5/22	By	Sujata 4/5/22
4/5/22	45	Ground Floor punching machine area	Tubelight not working	6A MCB. trip & MCB Restart Tubelight is ON	4/5/22	By	4-5-22 Bisht
4/5/22	46	FMW 6th Floor	power supply was off	4 pole RCCB was off due to over load S.P MCB RCCB trip 63 AMP, RCCB Restart	4/5/22	By	S.P Bisht

complain Rec- date	complain NOS	Location	Nature of complain	Action Taken against complain	Complain complete date	Ele. Sig.	HOD/W/I sig
4/5/22	47	ENT opD 1st floor	ceiling fan Running Slowly	2.5 MFD capacitor fitting & connection — 1 NOS	4/5/22	By	
5/5/22	48 Medical callage 2nd Floor	Medical callage 2nd floor	4 pole MCB not working	old 3 pole 63 A MCB Replace with 4pole 63 A MCB	5/5/22		
5/5/22	49	plaster room ground floor	switch board hanging	switch board fitting & connection material — screw — 2 NOS grip — 2 Nos	5/5/22	By	
5/5/22	50	male ortho ward	power point not working	6A mcb trip & MCB Restart, power point is on.		By	
5/5/22	51	EMC ICU c/by W/G	Power point not working	Switch board fitting 6A switch = 3 Nos 6A Socket - 1 Nos	5/5/22		
6/5/22 Friq	52	Ground Flo. EMS ICU c/by phone	Power Supply is OFF of X-Ray ~~Ventr~~ - mlc	16 A S.P. MCB was Trip we Reset and ON mcb power Supply is on work done	6/5/22	By	
6/5/22 Fri	53.	Substation Emergency duty	Khanda Colony Transformer was Faliver 6/5/22 7:00 Am	we are restore power Supply From Kamothe Substation which is 50%	Electrician Bajrang will do the duty in		

Creating lasting impressions

Excellent runnability

complain Rec-Date	complain No's	Location	Nature of complain	Action Taken against complain	Complain complete Date	Elect-Sig.	HOD/U/I Sig.
6/5/22	54	1st Floor MOW C/b/phone	Seminor Hall Ceiling Fans are not proper moving 04 Nos	2.5 MFD capacitor Replaced with new 04 Nos work done	6/5/22	By	
6/5/22	55	Ground Floor Radiology C/b/phone	Room No-60 Ceiling Fan not proper moving 01 Nos	2.5 MFD capacitor Replaced with new 01 Nos work done	6/5/22	By	06/05/2022
6/5/22	56	4th FLOOR Medicine Dep. C/b/phone	2'x2' 86 W T.L. Sifting work 01 Nos	2'x2' 86 W T.L. Replaced 01 Nos work done	6/5/22	By	
6/5/22	57	4th FLOOR pediatric ward C/b/phone	Tube light is not working 01 Nos	22 watt 4' T.L. Set Replaced 01 Nos work done	6/5/22	By	

Complain Recv-Date	Complain Nos	Location	Nature of Complain	Action Taken against Complain	Complain Complete Date	Elect - Sig	HOD/ W/I Sig
6/5/22	58	4th floor Pediatric Ward C/b/Phone	Celling fan not working	Celling fan had Removed for Repair = 01 Nos & Repaired Celling fan fitting and Connection = 02 Nos Celling fan is OK Work done	6/5/22	By	
7/5/22	59	Ground Floor Room 30	Ceiling Fan is not proper working 01 Nos	2.5 M.F.D. Fan capacitor Fitting and connection 01 Nos work done.	7/5/22	By	
7/5/22 Sat		emergency duty in Substation	DT. 6th May 2022 at 9 Am Friday Khanda colony main Incomer 11 KV power Transformer Faluase due to First Source 300 Sq mm cable 11 KV power Supply off.	we are restored power Supply From Kamothe Substation 7/5/22 by Second Source Sat 185 mm cable and Laad manege as per Kamothe J. E. instruction HT 56 Amps at 10.47 am Incoming	7/5/22	By VG.	

complain Rec. Date	complain Nos	Location	Nature of complain	Action Taken against complain	Complain complete Date	Ele. Sig.	HOD/W/I Sig.
7/5/22	60	Ground Floor C/b/phone	Room No. 31 Ceiling fan is not working.	2.5 MFD Fan capacitor Replaced – 01 Nos work done	7/5/22		
7/5/22	61	Ground Floor P30	Fans are not working – 04 Nos	2.5 MFD Fan capacitor Fiting and connection 03 Nos and one Ceiling Fan Shifting work done	7/5/22		Uttara Deshmukh F001, Deole 07.5.22
7/5/22	62	5th Floor mm w c/b/phone	Ceiling Fans are not working 12 NOS	2.5 MFD Fan capacitor new Fiting and connection Total 12 NOS work done	7/5/22		
09/05/22	63	Pediatric Ward 4th floor	UPS Supply not working	2.5 mm wire removed & 2.5 mm MCB fitting and Connection on 10Amp MCB UPS Supply is working Work done	09/05/22		
09/05/22	64	3rd floor Special Ward	Celling fan slow working	2.5 MFD New Capacitor Replace=01 Nos Celling fan fast	09/5/22		

Excellent runnability

Creating lasting impressions

Complain Recived date	Complain Nos	Location	Nature of Complain	Action Taken against Complain	Complain Complete Date	Elect Sign	HOD/W/I Sig
09/05/22	65	Tramatology and Surgery Ward I floor	Celling fan removed	Celling fan removed = 03 Nos for Repair	09/05/22	By	Roshani
09/05/22	66	Male Ortho Ward II floor	Celling fan not working	Celling fan had removed for Repair = 01 Nos & Celling fan Shifting = 01 Nos for Male ortho Ward Celling fan is OK Work done	09/05/22	By	Dhanashri
09/05/22	67	Male ortho Ward II floor	Celling fan slow working	~~Celli~~ 2.5 MFD new Capacitor Replace = 01 Nos Celling fan is OK Work done	09/05/22	By	Dhanashri
10/5/22	68.	OPD 2nd Floor	Main Electrical Room Cleaning work complain by C.A.O.	old materials Shifted on 3rd Floor in new Electrical Store Room which is provide by Hospital Director Sir	10/5/22	By	
10/5/22	69.	Ground Floor H.D. Sir Room	UPS power Supply was OFF	we checked and Found S.P. MCB was Trip in 100 KVA UPS D.B. so we are MCB reset and on and checked power (UPS) Supply is ok	10/5/22	By	

complain Rec-date	complain Nos	Location	Nature of complain	Action Taken against complain	complain complete date	Elec-Sig.	HOD/W/I Sig.
11/5/22	70.	OPD 2nd Floor Ped-OPD	Power Suplai is OFF	we are checked S.P. MCB was Trip due to Tube lights Shourt we removed wire of T.L. and MCB reset and ON. work done.	11/5/22	By	
11/5/22	71.	Site office	Ceiling Fan Shifting From Store Room To Drops man Cabin	Ceiling Fan Shifting work done.	11/5/22	By	
11/05/22	72	Male Medical Ward 5th flr	Tubelight not working	22 W 4 feet LED set fitting and Connection = 01 Nos Tubelight is OK. Work done.	11/05/22	By	Lost W.I.
12/05/22	73	Male Medical Ward 5th flr	Celling fan not working	Phase Wire hanging Celling fan wire fitting and Connection Celling fan is OK (1) Work done	12/05/22	By	Lost W.I.

complaint rec. date	complaint Br. No	Location	Nature of complaint	Action taken against complaint	complaint attend date	E.E. sign	W I sign
12/05/22	74	EEg room 2nd Floor	AC not working	MCB Box fitting — 1 Nos 20 A MCB fitting & conn. — 1 Nos 25/8 screw — 4 Nos grip — 4 Nos	12/5/22		12/5/22
12/5/22	75	ophthalmology ward	ceiling fan running Slowly	2.5 mfd capacitor fitting & connection — 2 Nos	12/5/22		
12/5/22	76	Blood bank	AC not working	wire exchange 10 A MCB to 20 A MCB	12/5/22		
13./5/22	76	2nd FLOOR Opthal Ward	Switch Board wire removing or deconnection work OI Nos	Switch Board wire removed work done	13/5/22		
13/5/22	77	2nd FLOOR Ortho ward	A.C. power Supply is OFF	16 A S.P. MCB was Trip we are reset and ON 16 A S.P. MCB po checked power Supply found OK work done.	13/5/22		

Creating lasting impressions

Complain Rec. date	complain Nos	Location	Nature of complain	Action Taken against complain	Complain complete date	E.le. Sig.	HOD/W/I Sig.
13/5/22	78	3rd Floor ~~S+E~~ J MI CU	New Peadestal Fan requered 04 Nos and One Pedestal Fan Requered old	16" New Pedestal Fan Fitting and connection 04 Nos and old one Pedestal Fan Sifting From Opthal ward to M I C U work done.	13/5/22	By	S/N Akshaley 15/5 13/5/22 7PM
14/5/22	-				14/5/22. ④ New fan (16") returned to Electrical department informed to Incharge sister - S/N Akshaley 15/5		
14/05/22	79	Medicine OPD I floor (ECG Room)	Celling fan not working	Celling fan had removed for Repair = 01 & Repaired Celling fan fitting and Connection = 01 Nos Celling fan is OK Work done	14/05/22	By	
14/05/22	80	Medicine OPD 1st floor Passage	Celling fan slow working	2.5 MFD New Capacitor Replace = 5 Celling fan is OK Work done	14/05/22	By	

• Vivid Colours: Richer, brighter images & graphics
✓ Excellent runnability
Creating lasting impressions

complaint Rec. date	complaint No	Location	Nature of complaint	Action taken against complaint	complaint complete date	E|E Sign	W I/H.O.D sign
14|5|22	81	ENT opd passage	ceiling fan not working	ceiling fan removed for repairing — 1 NOS & Repaired ceiling fan fitting & conn — 1 NOS	14|5|22	By	
14|5|22	82	Billing counter	ceiling fan not working	ceiling fan wire connection properly. ceiling fan is ON	14|5|22	By	Bharath 14|5|22
14|5|22	83	casualty passage	ceiling fan running slowly	2.5 mfd capacitor fitting & connection — 2 NOs	14|5|22	By	Gsimal, 14|05|2022
14|5|22	84	CVTS ICU	Switch board hanging	switch board properly fitting	14|5|22	By	Neha 14|5|22 2:34pm
14|5|22	85	ICU 3rd FLOOR	New Pedestal Fans are Requred 04 Nos	New Pedestal Fan Fitting and connection 04 Nos work done	14|5|22	By	Neha 14|5|22 3:11pm
14|5|22	86	Micro biology lab	Autoclave machine not working				

Complain Recieved date	Complaint No	Location	Nature of Complain	Action Taken against Complain	Complain Complete date	Ele sign	I/I/HOD Sig
16/05/22	87	Old MS Office	Tubelight not working	22W 4 feet LED set fitting and Connection Tubelight is OK Work done	16/05/22	Indra 16/5/22	
16/05/22	88	Medicine OPD Class Room I flow	Celling fan hanging	Celling fan fitting and Connection Celling fan is OK Work done	16/05/22		Pruthy
16/05/22	89	OT no 4	Socket not working	6A socket Replace with 16A socket fitting & Connection	16/05/22		
17/05/22	90	HVAC Department	Celling fan ~~slow~~ not working	Celling had Removed for Repair =01 Nos Repaired Celling fan fitting and Connection=01 Celling fan is OK Work done	17/05/22		
	91		Celling fan slow working	2.5MFD New Capacitor Replace =01 Nos Celling fan is ok Work done	17/05/22		

• Vivid Colours: Richer, brighter images & graphics
✓ Excellent runnability
Creating lasting impressions

Complain Recieved date	Complaint No.	Location	Nature of Complain	Action taken against Complain	Complain Complete date	Sign	W/I/HOD
17/05/22	92	ENT Ward II floor	gyser hanging	gyser fitting and Connection gyser is working Work done	17/05/22	By Prod	
17/05/22	93	OT B th Floor	16 Amp Socket not working	16 Amp Socket Removed =01 Nos & 16 Amp Socket New fitting and Connection =01 Nos Work done	17/05/22	By	
18/05/22	94	ENT Ward II floor	Celling fan not working	10 Amp mcb trip & mcb restart Celling fan is ok Work done	18/05/22	By	Prod 18/5/22
18/05/22	95	opthalmology Ward II floor	Celling fan not working	Celling fan had Removed for Repair =01 & repaired Celling fan fitting and Connection =02 Nos Celling fan is ok. Work done	18/05/22	By	
			Celling fan slow working	2.5 MFD New Capacitor Replace =01 Nos Celling fan is ok. Work done	18/05/22	By	

Complain received date	Complain No.	Location	Nature of Complain	Action taken against complain	Complain complete date	Ele sign	W/I/S/I
18/05/22	96	Female Medicale Ward 6th floor	Celling fan not working	10 Amp mcb Trip & mcb restart Celling fan is ok. Work done	18/05/22	By	R Bail
18/05/22	97	Neurology OPD Passage I floor	Celling fan proper not fitting	Nut Bolt New Replace = 01 Nos Washer = 02 Nos Celling fan proper fitting Celling fan is ok Work done	18/05/22	By	Bail
18/05/22	98	6th Floor FMW	Powerpoint not working.	10A MCB trip and we restart MCB. Powerpoint is ok.	18/05/22	By	@Bail
			Exhaust Fan not working.	Phase wire disconnect and Phase wire connected. Exhaust fan is working			
18/05/22	99	mmw II 5th floor	power point not working	40 A RCCB Tripped & RCCB restart. power point is ok			
			Celling Fan are slow	2.5 MFD new capacitor is ~~repal~~. replaced = 03. Celling fan is ok	18/05/22	By	Jossy W12

Complain recieved date	Complain No.	Location	Nature of complain	Action taken against complain	Complain Complite date	W/I & S/I	Elec. sign.
19/05/2022	100	EMS ICU Bathroom	light is not working	15W new ~~big~~ square light fitting and connection. Light is ok.	19/05/22		
18/05/22	101	Blood bank	1) Fan is not working 2) Celling fan is running Slow.	1) Repaired celling fan replaced with old one and fitting and connetion Celling fan is working 2) 2.5 MFD capacitor is replaced. Fan is ok.	18/05/22		
20/05/22	102	MMW I 5th floor	ceiling fan not working switch not working power point not working	ceiling fan removed for repairing & Repaired ceiling fan fitting n connection — 1 Nos 16 A switch fitting & connection — 1 Nos give & supply for 6M switch board	20/05/22		
20/05/22	103	MMW II	ceiling fan not working	ceiling fan removed for repairing & Repaired ceiling fan fitting n connection — 1 Nos 2.5 MFD capacitor fitting & connection	20/5/22		

23/5/22	(104)	casualty	2'x2' LED 36W are Blinking 02 Nos	36 Watt 2'x2' LED Panel Lights new Replaced 02 Nos work done	23/5/22	By	2 LED light Changed 23/5/22
23/05/22	(105)	Anesthesia Department HOD Room	Power point not working	6 Amp mcb trip & mcb restart. Power point is ok	23/05/22	By	Done 23/05/22
23/05/22	(106)	female medical Ward 6th flr	Power point not working	40 Amp RCCB Trip & RCCB restart power point not working work done	23/05/22	By	Replaced
23/05/22	(107)	Male medical Ward 5th flr	Power point not working	10 Amp mcb trip & mcb restart power point is ok work done	23/05/22	By	Lobby wk I
23/05/22	(108)	OT-2 III flr	Power point not working [O.T. light-2 not working]	6 Amp mcb Trip & mcb restart power point is OK work done one O.T. light Complete	23/05/22	By	Done O.T. 23/5/22

Vivid Colours: Richer, brighter images
Excellent runnability
Creating lasting impressions

comp Rec Date.	complain No.	Location	Nature of complain	Action Taken against complain	complain complete date	Ele Sig.	HOD/W/I Sig.
23/5/22	109	HVAC	5 H.P. Motor wire Removing and 5. HP motor wire connection work.	we are checked Motor continuty with multimeter and Fault detected one winding was Open and one winding continuty connected need to be 5 HP motor repair and Relay replee	23/5/22		
24/5/22	110	Medicine department	socket not working	6A Socket Replace fitting & connection — 1 Nos.	24/5/22		Completed
24/5/22	111	Dots center Room no - 130 1st Floor	Power point is not working.	New 8 modul Switch bord is fitting and connect 6A switch — 2 Nos 6A Socket — 3 Nos Power powint is working.	24/5/22		
24/5/22	112	pharmacy Basement	power point not working	8 module surface box — 2 Nos 6 module surface box — 1 Nos 6A switch — ~~3~~ 4 Nos, 16A switch — 2 Nos 6A Socket — 5 Nos, 16A socket — 3 Nos 8 module plate — 2 Nos 6 module plate — 1 Nos 2.5 mm^2 copper 3 core cable — 10 mtr	24/5/22		
25/5/22	113	Dylasis 3rd floor	Tubelight not working	2X2 36W tubelight fitting & connection — 2 Nos			

Complain Recieved	Complain Nos	Location					W/I
25/05/22	114	Dylasis III floor	Tubelight not working	2x2 36 W Tubelight fitting and Connection =02 Nos & 1 light shifting Tubelight is OK Work done	26/05/22	By	25/5/22
25/05/22	115	Minor OT Ground floor	Tubelight not working	2x2 36 W Tubelight fitting and Connection =02 Nos Tubelight is OK. Work done	25/05/22	By	
25/05/22	116	Department of opthalmology	Power point not working	12 module Switch Board fitting and Connection 6Amp Socket =04 Nos 6Amp Switch =04 Nos Casing patti = 2mtr Phase Wire = 2mtr Neutral wire = 2mtr Earthing wire = 2mtr grip =10 Nos Screw =10 Nos	25/05/22	By	
25/05/22	117	Main Security Gate	Celling fan not working	celling fan new requirment & Celling fan fitting and	25/05/22	By	

Complain

Recieved date	Complain Nos	location	Nature of Complain	Action taken against Complain	Date	Ele Sig	WIT
26/05/22	118	Geriatric OPD I floor	Celling fan not working	Phase Wire hanging phase wise fitting and Connection =	26/05/22		
			Celling fan slow working	2.5 MFD New Capacitor Replace = 01 Nos Celling fan is Ok. Work done.	26/05/22		
26/05/22	119	Neurology OPD I st floor	ceiling fan not working	Repaired ceiling fan fitting & connection — 1 Nos ceiling fan removed for repairing — 1 Nos	26/5/22		
26/05/22	120	Central lab Ground floor	Power point not working	10 Amp RCCB Trip & RCCB restart. Power point is Ok Work done	26/05/22		
26/05/22	121	Male medical Ward 5th flr	Gyser not working	6 Amp MCB removed & 16 Amp MCB fitting and Connection = 01 Nos Gyser is working Work done	26/05/22		

Complain received date	Complain Nos	Location	Nature of Complain	Action taken against Complain	Complain Complete Received date	Ele Sign
27/05/22	122	Casulty Ground floor	Celling fan not working	Celling fan shifting=01 Nos & Repaired Celling fan fitting and Connection =01 Nos Celling fan is Ok Work done	27/05/22	By Vinile
27/05/22	123	Female Medical Ward 6th floor	Celling fan not working	Celling fan had Removed =02 Nos & Repaired Celling fan fitting and Connection=03 celling fan is Ok Work done	27/05/22	By Rathi
28/5/22	124	casualty				vinile
28/05/22	125	MJPJY	Fan is not working.	Repaired celling fan fitting and connection - 1 Nos. Now Fan is working.	28/05/22	By Upadej
28/05/22	126	Male Surgical ward I flr	Celling fan slow working	2.5MFD Capacitor New Replace Celling fan is Ok	28/05/22	By
28/05/22	127	Special ward Dick II flow	Tubelight not working	4 feet LED set fitting and Connection = 01 Nos Tubelight is Ok	28/05/22	By

Complain Received date	Complain Nos	location	Nature Of Complain	Action taken against Complain	Complain Complete date	Ele Sig	W/I
30/05/22 VK	128	Room no - 207 2nd Floor	3 pin top not working	New 16A 3pin top fitting and connection. - 1 Nos	30/5/22		
30/5/22	129	Opthe dept. 2nd Floor	MCB trip.	6A two MCB trip & MCB restart. Power point is working.	30/5/22		
30/05/22	130	Ortho OPD Ground floor	Celling fan not working	Celling fan had removed =01 Nos & Repaired Celling fan fitting and Connection =01 Nos Celling fan is OK work done	30/05/22	passage fan. Repaired	
30/05/22	131	Female Ortho Ward II flor	Power point not working	40 Amp MCB trip & MCB restart Power point is OK Work done	30/05/22		
30/05/22 VG	132	Dept of Othalmo II flor	6 Amp MCB removed & 02 & 16 Amp MCB fitting and Connection =02 Machine not working	6 Amp MCB removed=02 & 16 Amp MCB fitting and Connection =02 Nos Work done	30/05/22		31/5/22
30/05/22	133	X-Ray Dept	Power point not working	4 Sqmm 3core 30mtr Cable fitting and Connection in UPS DB. Power point is Ok	30/05/22		

Creating lasting impressions

Complain Received date	Complain Nos	location	Nature of Complain	Action taken against complain	Complain Complete date	Ele Sig	C/I
30/05/22	134	HVAC Dept.	Celling fan slow working.	2.5 mfd New Capacitor Replace = 02 Nos & Celling fan is Ok Work done	30/05/22	✓	✓
31/05/22	135	Ortho OPD Ground flor Room No-09	Tubelight hanging	Tubelight Properly fitting Grip = 01 Nos. Screw - 01 Nos Work done	31/05/22	✓	
31/05/22	136	EMCICU Ground flor	Celling fan not working	Celling fan had removed = 01 Nos & Repaired celling fan fitting and connection = 01 Nos	31/05/22	✓	1 fans changed from
			Celling fan not working	Celling fan Phase Wire removed & phase wire fitting and Connectn celling fan is ok Work done			
31/05/22 checked EEE	137	Male Medical Ward 5th flor	Celling fan not working	Celling fan had removed = 02 Nos & Repaired celling fan fitting and Connection = 03 Nos Celling fan is ok. Work done.	31/05/22	✓	Losty W/L

Vivid Colours: Richer, brighter images
Excellent runnability
Creating lasting impressions

Complain Received date	Complain Nos	Location	Nature of Complain	Action taken against complain	Complain completed date	E/E Sig	W/I
31/05/22	138	FOW 2nd Floor	Ceilling fan is not working	Unrepaired fan removed and repaired fan fitting and connection. Ceilling fan is working	31/5/22	By	
31/05/22	139	Male Ortho Ward II floor	Celling fan not working	Celling fan had Removed =01 Nos & Repaired Celling fan fitting and Connection =01 Nos Celling fan is OK. Work done	31/05/22	By	
31/05/22	140	Ortho OPD Room No - 16	Celling fan slow working	Celling fan is OK. 2.5 MFD New Capacitor Work done — 3 Nos	31/05/22	By	
03/06/22	141	Pediatric OPD II floor	Celling fan not working	Celling fan phase wire hanging. & celling fan wire fitting and Connection Celling fan is OK Work done	03/06/22	By	
03/06/22	142	Cardiology OPD II floor	Celling fan not working	Celling fan had Removed =01 Nos & Repaired Celling fan fitting and Connection =01 Nos Celling fan is OK Work done	03/06/22	By	

Complain received Date	Complain Nos	Location	Nature of Complain	Complain taken against	Complain Complete date	Elec Sig	W/I
04/06/22	143	Pediatric COPD II floor	Celling fan slow working	2.5 MFD New Capacitor Replace = 01 Nos Celling fan is working Work done	04/06/22	By	OCH SIN
06/06/22	144	BMC ICU Ground floor	Tubelight not working	22W LED Set is working 16 Amp switch not working & Phase Wire shift 16 Amp switch. Tubelight is ok Work done	06/06/22	By	
06/06/22	145	Female Ortho Ward II floor	Celling fan not working	Celling fan is ok celling phase wire. Disconnect & Celling fan phase wire fitting and Connection - Celling fan is ok work done	06/06/22	By	
06/06/22	146	X-Ray Dept. (Ush Room)	Wall fan not working	Repaired Wall fan fitting and Connection = 01 Nos Wall fan is ok work done	06/06/22	Surk By	6/6/22
07/06/22	147	Lobby Ground floor	Celling fan slow working	2.5 MFD New Capacitor Replace = 01 Nos Celling fan is ok	07/06/22	By	

Creating lasting impressions

complaint attend Date	Sr No	Location	Nature of complaint	complaint attend & use materials	complaint complete Date	EEE sign	WI sign
7/6/22	148	ENT ward	ceiling fan not working	ceiling fan removed for repairing & Repaired ceiling fan fitting n connection — 1 Nos	7/6/22		
07/06/22	149	Male Medical Ward I 5th floor	Tubelight not working	220 4 feet LED set fitting and connection=03 Tubelight is ok work done	07/06/22		
			Celling fan not working	celling fan wire hanging. celling fan is ok work done	07/06/22		
07/06/22	150	Female medical ward	ceiling fan not working	ceiling fan Removed for repairing, Repaired ceiling fan fitting & conn. — 1 NOS	07/06/22		
8/6/22	151	Skin OPD	Ceiling Fan is not working.				
8/6/22	152	Ped. OPD	Ceiling Fan is not working.				
8/6/22	153	M S W II	Ceiling Fans are not working.	2.5 MFD capacitor fitting & connection — 2 NOS	07/06/22		

9/06/22	154	Opthalmology	2Celling fan supply On 1 Switch	celling fan supply On 1 Switch celling fan is ok	09/06/22	Deepali Barua
08/06/22	155	Surgery OPD	Celling fan not working	Celling fan had removed =01 Nos & Repaired Celling fan fitting and connectn =01 Nos Celling fan is ok	08/06/22	Subhra
10/6/22	156	Dermatology & Reoperatory ward 6th floor	No cap ~~on~~ celling fan	New cap fitting on celling fan - 6 Nos	10/6/22	
10/6/22	157	FMW 6th floor	No cap on celling fan	New cap fitting on celling fan -	10/6/22	
			Celling fan is slow	New 2.5 MFD capacitor fitting and connection	10/6/22	
			Celling fan not working	Celling fan had Removed for Repair =01 Nos & Repaired celling fan fitting and Connection =01 Nos Celling fan is ok	10/06/22	
10/06/22	158	Respiratory ward	Celling fan not working	Celling fan had Removed for Repair=01 Nos & Repaired Celling fan fitting and Connectn =01 Nos	10/06/22	

Complain Received Date	Complain Nos	Location	Nature of Complain	Action taken against Complain	Complain complete date	Eng Sig	W/I
11/06/22	159	Surgery OPD Passage Ground floor	No Cap in Celling fan	Celling fan removed & Celling Cap fitting & Celling fan fitting and Connection = 05 Nos	11/06/22	By	Sanitary
11/06/22	160	Staff Quarter	16 Amp Socket not working	16 Amp Socket removed & 16 Amp Socket fitting and Connection = 01 Nos work done	11/06/22		
11/06/22	161	ENT Ward II floor	Tubelight hanging	Tubelight properly fitting = 01 Nos Tubelight is ok work done	11/06/22	By	
13/06/22	162	Female Medical Ward 6th floor	Power point not working	40 Amp RCCB trip & RCCB restart. power point is ok	13/06/22	By	Rajeev
13/06/22	163	Female Ortho Ward II floor	Celling fan not working	Celling fan had Removed for Repair = 01 & Repaired celling fitting and Connection = 01 Nos Celling fan is ok work done	13/06/22	By	

Complain received date	Complaint Nos	Location	Nature of Complain	Action taken against Complain	Complain Complete date	W I Sig
13/06/22	164	Department of Radiology	Power point not working	Phase wire loose. phase wire fitting	13/06/22	
			Ac not working	20 Amp mcb Trip & mcb restart Ac is Ok Work done		
13/6/22	65	MS officie	AC supply not working	32A MCB trip. Restart and supply on	13/6/22	
14/06/22	166	HR Office Basement	Tubelight not working.	4 feet LED set fitting and connecto =01 Nos. Tubelight is Ok Work done	14/06/22	
14/06/22	167	Physiotherphy II floor	Celling fan not working	Celling fan had removed for Repair =01 Nos Repaired Celling fan fitting and Connector =01 Celling fan is Ok Work done	14/06/22	
15/06/22	168	Male medical ward	power point not working	RCCB trip & RCCB Restart 40 A	15/06/22	

Complain received date	Complain No.	Location	Nature of complain	Action taken against complain	Complain complete date	Ele sig	W/I
15/6/22	169	MSW II 1st Floor	No Fan is not working Fan is slow	Fan is replaced with repaired Fan - 1 Nos New 2.5 MFD capacitor fitting and connection - 3 Nos	15/6/22	By	15/6/22
15/6/22	170	Opth. dept.	Powerpoint is not working.	16A & 16A MCB trip. We start the MCB and supply is on	15/6/22	By	15/6/22
15/6/22	171	X-ray dept.	Wall-fan shifting.	Wall fan is shifting from x-ray dept. to C.T scan room no-26 - 1 Nos	15/6/22	By	15/6/2022
16/6/22	172	OT III floor	Tubelight not working O.T. No. 5 - Scrub. Station	2x2 36 W Tubelight fitting and Connection=01 Tubelight is OK Work done	16/6/22	By	16/6/22.
16/06/22	173	Physiotherapy II floor	Power point not working	40 Amp MCB trip & MCB restart power point is ok	16/06/22		
16/06/22	174	HDO Ground floor	Power point not working	10 Amp mcb trip=02 & 10 Amp mcb restart power	16/06/22	By	

Complain Recieved Date	Complain No.	Location	Nature of Complain	Action taken against Complain	Complain complete date	Ele sig.	W/I sig.
16/6/22	175	Basment store room	Supply not working	20A MCB trip and MCB restart. Supply is On	16/6/22	By	16/6/22
16/06/22	176	Medicine OPD Passage I flow	Tubelight not working	20W 4 feet LED set fitting and Connection = 01 Nos Tubelight is Re Iwork done	16/06/22	By	18/6/22
17/6/22	177	P.T. O.P.D. and Floor complain by W/C	Power Supply is not coming in one Room	Power Supply wire checked and Found Foulty CKT wiring and so Replace with new CKT Line and connected with ETPN D.B Power Supply came in One Room	17/6/22 workdone	By	Dr. Payal
17/6/22	178.	P.T. OPD and Floor	Ceiling Fan is not working 04 Nos	checked Ceiling Fan power Suply is not coming From Switch So we are Replaced Swith connection Fans,ase	17/6/22	By	Dr. Payal

Complain Recieved date	Complain No.	Location	Nature of Complain	Action taken against Complain	Complain complete date	Ele sig.	N/I sig.
17/06/22	179	Male Medical Ward 5th flor	Power point not working	10 Amp MCB Trip ∧ MCB restarg. Power point is ok	17/06/22		
17/06/22	180	Surgery Department 4th floor	Tobelight not working	2X2, 36W Tobelight fitting and Connecth =01 Nos Tobelight is ok Work done	17/06/22		
			Celling fan not working	Celling fan phase wire removed ∧ phase wire fitting and connection=01 Celling fan is ok	17/06/22		
			Celling fan slow working	2.5 MFD New =02 Capacitor Replace. Celling fan is ok Work done	17/06/22		
17/06/22	181	Ortho OPD Ground floor	Tobelight not working	20W 4 feet LED set fitting and connection =03 Nos Tobelight is ok Work done	17/06/22		

Complain recieved date	Complain No	Location	Nature of complain	Action taken against complain	Complain complete date	Ele sig.	W/I sig
17/06/22	182	EMCICU Staircase Complain by W/C 16/6/22	Tubelight not working	20 W 4 feet LED set fitting and connection = 03 Nos Tubelight is OK Work done	17/06/22	By 17/6	Bajrang Sir By Pradhan
17/06/22	183	Geriatric OPD Ground floor	Celling fan not working	Celling fan wire hanging Celling fan Phase wire fitting and Connection. Celling fan is OK	17/06/22	By 17/6	18/6/22
18/6/22	184	Skill Lab 6th Floor complain by Phone.	Power Suply is off due to Tube lights wire Spark.	we are checked and Found One Tube lights wire connect in water due to water Leakage in ceiling So we are did MCB off Room. No - (Issq man cabin)	18/6/22	By	(Illegible) 18/06/22

Complain Recieved date	Complain No.	Location	Nature of complain	Action taken against complain	Complain complete date	Ele sig	WI sig.
18/06/22	185	1st Floor ENT ward	Ceilling fan is not working.	Ceilling had removed for repaired - 01 Nos. And Repaired ceilling Fan fitting and connection - 06	18/06/22		
			Ceilling fan is slow.	New 2.5 MFD capacitor replaced - 08 Nos.			
20/6/22	186	4th FLOOR PSY Ward	Ceiling Fans are not working 04 NOS				
20/6/22	187	6th FLOOR FMW	Ceiling Fans are not working - 02 Nos in D.D.R.				
20/6/22	188	1st FLOOR F.S.W.	Geyzer is not working.	16A S.P.MCB was Trip Reset and on Geyzer is working.	20/6/22		

Complain recieved date	Complain No.	Location	Nature of complain	Action taken against complain	complain complete date	Ele sig.	W/I sig.
20/6/22	189	2nd Floor M.O.W.	Tube lights are not working	4 Feet 22W LED fitting and connection - 1 Nos	20/6/22	By	Sign
20/6/22	190	2nd Floor SKin OPD	Tube lights are not working in Biomedical Equipment	LED ~~Tubelight~~ fitting — 1 Nos old not working LED Light Removed of	20/6/22	By	Prabhu
20/6/22	191	6th Floor Skill Lab	Power Supply is OFF	We are checked power Supply MCB was Trip due to water Leakage So we are Reset MCB and ON power Supply. it's OK. (Admin officer Room) (Conference Hall) (Skill lab incharge room) (store room)	20/6/22	By	Sankara 20/6/2022

Creating lasting impressions

Complain received date	Complain No.	Location	Nature of Complaint	Action taken against Complaint	Complain complete date	Ele sig.	W/I sig.
20/06/22	L92	Cardiology Room – 212 II floor	Ceiling fan Regulator not working	Ceiling fan regulator removed and ceiling fan supply direct Ceiling fan is OK	20/06/22	By	Girish Asst Doctor
20/06/22	L93	Psychiatric Ward 4th floor	Ceiling fan not working	Ceiling fan had removed for Repaired = 03 Nos	20/06/22	By	Purushotham
20/06/22	(194)	MMW 1st Floor	Tube light is not working.	4 Feet 22W LED Fitting and connection - 1 Nos	20/06/22	By	Jagadish
20/08/22	195	OT (OT No 8) 3rd Floor	operation bed not working	3 pin top wire loose. wire connection & 3 pin top fitting.	20/06/22		
20/06/22	196	Casulty Out of gate	Wall Fan removed	Wall Fan had Removed for Repair = 01 Nos	20/06/22	By	Vinith 25/06/22
20/6/22	197	Casualty main Entrance	hand driver removed	handriver removed for Repair = 01 Nos	20/06/22	By	
21/6/22	(198)	Deputy administrative officer	Switch not working	6 A switch is not working. New 6A Switch fitting and connection - 1 Nos.	21/06/22		

Complain complete date	Complain No.	Location	Nature of Complain	Action taken against complain	Complain complete date	Ele sig.	W/I sig.
22/06/22	199	Blood Bank Ground floor	Insect Killer not working	Insect Killer Removed = 02 Nos Insect Killer fitting and Connection = 02 Nos Insect Killer is Working. Work done	22/06/22		Abhay Kumar 22/06/22
22/06/22	200	Dylasis III floor	16 Amp Switch not working	16 Amp Switch Replace = 01 Nos & Switch is Working Work done	22/06/22		Positive all fans are working
22/06/22	201	IT Department	4 Core Armed Core Insulation damage	damage Insulation Cable Remove & fitting and connection	22/06/22		
22/06/22	202	Geriatric OPD I floor	Celling fan not working	Celling fan fitting = 01 Nos & celling fan is ok Work done	22/06/22		Positive all I opn 25/6/22

Excellent runnability

Creating lasting impressions

complain Date	complain Nos	Location	Nature of complain	Action Taken against complain	complain complete Date	Ele. Sig.	W/I HOD/sig.
23/6/22	203	1st Floor F S W C/W/G 23/6	Ceiling Fans are not working 05 Nos Tube lights are not working 05 Nos	Ceiling Fans had Removed For Repair. ___ Nos Old not working Tube lights Removed 05 Nos New E.L.D. 20W 4' Fiting and connection 05 Nos	23/6/2022	By	
23/6/22	204	2nd Floor F.O.W.	Ceiling Fans are not working	ceiling fans shifting from F O W DDR room to new F.O.W ward	23/06/2022		
23/6/22	205	Basement MRD complain by phone.	Ceiling Fans are not proper moving	2.5 MFD Fan Capacitor Fiting - 03 Nos	23/6/22	By	
23/6/22	206	4th Floor PSY ward	Ceiling Fans are not working	ceiling fan fitting and Connection = 03 Nos ceiling fans is work done	23/6/22	By	

Complain Date	Complain No.	Location	Nature of complain	Action Taken against complain Removed	complain complete Date	Ele. Sig.	HOD w/I Sig.
23/6/22	207	3rd Floor O.T.	Power Points (Switch and Socket) are not working. in O.T. No 09 and 13, 02, 01, 05	16 A Switch → 16 A Socket → Fiting 16 A Switch → 16 A Socket → Blank Plate →	23/6/22		
23/06/22	208	Psychiatry Ward 4th floor	Celling fan not working	Celling fan ~~fit~~ repaired fitting and Connection = 03 Nos Celling fan is Ok	23/06/22	By	P.Pkoke
23/06/22	209	Dr. Sameer Kadam Room	Celling fan not working power point not working	16 Amp MCB trip & mcb restart. Celling fan is Ok power point is Ok Work done	23/06/22	By	Ameeta 23/06/22
24/06/22	210	physiotherapy	power point not working	40A RCCB tripped & RCCB restart. power point is on	24/6/22	By	Dr-payal 6:10pm

complain Date	complain Nos	Location	Nature of complain	Action Taken against complain	complain complete Date	Ele. Sig.	W/I Sig.
		2nd Floor					
24/6/22	211	F.O.W. (Called E.N.T.W.D)	Ceiling Fans are not working 04 Nos and Tube lights are not working 02 Nos	check ceiling fans wiring Found Fault and Resolve the Ceiling Fans is working 20 W 4' New LED Lights Fiting with wiring on Temporiy Basis Tube Lights are working	24/6/22	By	Sujata S
24/6/22	212	2nd Floor F O W (Called ENT WD)	Wall Fan Shifting 01 Nos	Wall Fan Removal 01 From MOW Fiting 01 Nos Wall Fan in FOW 01	24/6/22	By	Sujata S
24/05/22	213	Male Surgical Ward II I floor	Celling fan not working	Celling fan had Removed for Repair=01 & Repaired Celling fan no fitting and Connection=01 Nos Celling fan is OK. Work done	24/06/22	By	

Complain date	Complain Nos	Location	Nature of Complain
24/06/22	214	Female Ortho Ward II flor	Celling fan not working
25/6/22	215	F.S.W. 1st Floor	Tube lights are not working 4 Nos in the ward Tube lights not working in Toilet room
25/6/22	216	6TH FLOOR F.M.W.	Ceiling Fans are not working 04 Nos
25/06/22	217	casualty	power point not working
~~25/6/22~~	~~218~~	~~casualty~~	Tubelight not working
25/06/22	218	OT III floor	Switch, Socket not working

Complain attend and use materials	Complain Complete date	Ele Sig	C) I Sig
Celling fan ~~Shifting~~ from FMW. = 04 Nos Celling fan is Ok Work done	24/06/22	3	Sujata S
16A MCB Trip & MCB restart. light are working.	25/6/22		Sn
There is no connection in socket, give connection in socket. power point is ON Now.	25/6/22	3	window visit 25/6/22
New 22 W LED slim panel light fitting & connection	25/6/22		change of 25/6/22
OT-13 - 01 Socket, 01 Switch OT-5, 02 Switch, 1 Socket OT-1, 01 Socket, 03 Switch	25/06/22		

Complain Date	Complain Nos	Location	Nature Of complain	Action taken against Complain	Complain Complete date	E/E Sig	W/I/Sg
27/06/22	219	Side office	Tubelight not working	22W 4 feet LED set fitting and Connection =01 Nos Tubelight is working Work done	27/06/22	By	Bajrang Sir
27/06/22	220	Department of Radiology HOD Room	Celling fan not working	phase wire hanging. & phase wire fitting and connection. Celling fan is OK. Work done	27/02/22	By	
27/06/22	221	Female Medicale Ward 6th floor	Celling fan not working	Celling fan had Removed for Repair=01Nos & Repaired Celling fan fitting and Connection= =05 Nos Celling fan is OK. Work done	27/06/22	By	Ram
29/6/22	222	EMS ICU	Celling Fan is not working = 1 Nos.	Celling Fan had removed for repair - 1 Nos Repaired celling Fan fitting and connection - 1 Nos. Celling Fan is OK Work done	29/6/22	By	Ram

• Vivid Colours: Richer, brighter images
JK PAPER LTD. Creating lasting impressions

complaint date	complaint No	Location	Nature of complaint	Action taken against complate	complaint complete date	Engg sign	W/I sign
29/6/22	223	Sleep lab 6th Floor	Tubelight not working	2X2 36 W LED Tubulight fitting & connection — 1 Nos	29/6/22		
29/6/22	224	EMC ICU	DB fitting loose	DB fitting property	29/6/22		
01/7/22	225	MMW I	power point not working	RCCB tripped & RCCB Restart 40 A power point is ON	1/07/22		
02/7/22	226	General Pharmacy Basement	Power point is not working.	New 16A 3pin top fitting and connection.	2/7/22		
02/7/22	227	central lab	ceiling fan not working	Repaired ceiling fan fitting & connection — 1 Nos old ceiling removed for repairing	2/7/22		

JK PAPER LTD.
Creating lasting impressions

Complain Rec. Date and Time	complain No.	Location	Nature of complain	Action Taken against complain and use materials	Complain complete Date and Time.	HOD/ W.I Sig.	Ele- Sig.
3/9/22 9 Am	01	Centarl Lab Ground Floor	Ceiling Fan is not working 01 Nos	old not working Fan Removed For repair 01 and Repaired Fan Fitting and connection 01 Nos	9:50 3/9/22 wk work done	wk	By
3/9/22 10 Am	02	—11—	wall Fan Fiting work 01 Nos	Wall Fan 400 mm Orient mak ~~ex~~ new Fiting and connection 01 Nos	3/9/22 10.50 wk	wk	By
3/9/22 11 Am	03	casualty	Ceiling Fans are not working 02 Nos	Removed For repair Ceiling Fans - 02 Nos	3/9/22 11:50 Am		By
3/9/22 12 Am	04	PSY ward 4th Floor	Giyser is not working.	20A D.P. MCB not working we replaced 16A SP MCB Giyser is working on Temorary basis Inform for Letter For Purchase 20A D.P. MCB	3/9/22 1:10 Pm		By
3/9/22 1:10 Pm	05	Basement Changing room (Quality Cell)	Ceiling Fan is not working.	Room Locked due to Half day	3/9/22 1:30 Pm		By

Complain Rec- Date and time	Complain NO	Location	Nature of Complain	Action taken against complain and use materials	Complain complete Date and time	HOD / WI sig	Ele sig.
		Female					
3/9/22 2.Pm	06	Surgery ward 1st Floor	Ceiling Fans are not working 02 Nos	Check power Supply Found OK and Ceiling Fan Removed for repair - 01 Nos	3/9/22 3.Pm	Sushanth Kotha	BY
		Ground Floor	Ceiling Fan is	Ceeked power Supply			
3/9/22 3.10Pm	07 3pm	Central Lab	not working in Side Lab	Found OK Ceiling Fan Removed For repair 01 Nos	3/9/22 3:20pm	Vijk.	BY
		Ground Floor	Tube lights are	Old not working Tube			
3/9/22	08	Female	not working	Light removed - 02 Nos	3/9/22		
	3.30pm	Toilet room (C.C.P. Lab)	and Ceiling Fan is not working - 01 Nos	22 watt Panel LED Fiting. and connection 01 Nos and Ceiling Fan wire connection 01 Nos it is working under ~~abgurvation~~ observation	4:PM	Vijk	BY
		3rd Floor	Power Supply	10A S.P. MCB			
3/9/22	09	Patient waiting	was off due	was Trip due to			
	4:00Pm	area (CVTS)	to mobile charger	Mobile charger	3/9/22		
			Shount circuit. due	Faulty and in Side	4:10pm	Nisa	
			to one wall Fan	Shount circuit so		Nisa Sonawane	BY
			is off	we are removed			
				charger and			
				10 A S.P. MCB			
				Reset and on			
				wall fan is			

Complain Rec - Date and time	Complain No	Location	Nature of Complain	Action taken against complain and use materials	Complain complete Date and time	HOD/ W/I sig	Ele sig
5/9/22 9.00 Am	10	3rd FLOOR Pre OFF O.T.	Tube lights are not working in passage area	we checked power Supply panel Found 10A S.P. MCB Trip due to 22 Panel LED chocke (Drive) Shout so we replace new panel LED 22w and 10A S.P. MCB Reset and on the power Supply Tube lights are working.	6/9/22 10.00 Am	✓	✓
6/9/22 10 Am	11	3rd FLOOR O.T. No 4	Power points 16A pedent are not working	we are make new power points (Extention board) with 16A 3 Points 4mm Cable 5 mtr 16A 3 pintop of Nos Given OT No-4 work done.	6/9/22 10:30	✓	✓
6/9/22 11Am	12	3rd Floor OPTHAL O.T.	New Extention Board Required For Lesor machine	we makeed 16A 6 points with 15 feet cable and 16A 3 Pin Top of Nos Given O.T. No-11 OPThal O:T. Given work done.	6/9/22 11.30	✓	✓

Complain Rec - Date and time	Complain No.	Location	Nature of Complain	Action taken against complain and use material	Complain complete Date and time	HOD / W/I sig	Ele sig.
		3rd Floor					
6/9/22 12 pm	13.	O.T. 07	Tube lights are not working 01 Nos	we checked power supply is working 18w 4 Pin PL-L LED New Required Inform to make Letter For purchase Lights	6/9/22 12.30 pm		
		3rd Floor	16 A 3 Pin Top broken 01 Nos	16 A old 3 pin top removed · 01 Nos (which is broken) 16A 3 Pin Top new Fitting and connection which is supplying in monitor.	6/9/22 1:30 pm		
6/9/22 1 pm	14.	O.T. 03					
6/9/22 1.35 pm	15.	Ground Floor micro Lab	Ceiling Fan is not working 01 Nos	old Ceiling fan removed For Repair - 01 Nos Repaired Ceiling Fan Fiting and connection 01 Nos	6/9/22 1:40		
		2nd Floor	Ceiling Fans are not working 02 Nos (4 New Fan Fiting work)	~~Pending night shift on duty electrician do the work.~~ Ceiling fan fiting in D.P-Room	6/9/22 2:30 pm		
6/9/22 2. pm	16.	MOW (OLD FOW)					

Complain Rec-Date and time	Complain No	Location	Nature of Complain	Action taken against complain and use materials	Complain complete Date and time	HOD/WI sig.	Ele sig
6/9/22 3 PM	17.	~~1st~~ 1st Floor E.N.T WD	Ceiling Fan are not working - 02 Nos	Ceiling Fan checked Bed 32 Ceiling Fan Removed For repair 01 Nos Repaired Ceiling Fan Fitting and connection 01 Nos Bed No- 29 Ceiling Fan making Noise due to Fan Kenopy Loose so we fixed proper Fan Kenopy it is proper working Bed No 30 Ceiling Fan is not working we removed not working Ceiling Fan For Repair Repaired Ceiling Fan Fitting and connection work done.	6/9/22 3:51 PM	Brody 6/9/22	③
6/9/22 3.52	18.	Ground Floor EMS ICU	A C not working 01 Nos due to Seprate A C power Supply MCB is not available	we checked power Supply one S.P. MCB is available for control A.C. power Supply and one Seprate MCB D.P. 16A Require For A.C. Maintenace work. also inform WI for Demand A C	6/9/22 4 PM		④

Complain Rec - Date and time	Complain No	Location	Nature of Complain	Action taken against complain and use materials.	Complain complete Date and Time	HOD/ W/I sig	Ele. sig.
6/9/22 4pm	19.	3rd FLOOR MICU	X-Ray Power Supply is not working due to power Supply mcb Trip	we checked power Supply 10A S.P mcb was Trip due to X-Ray m/c connected So we are removed X-Ray m/c From 10A S.P. mcb To Shift from 32A SP mcb X-Ray m/c is working.	6/9/22 4.10 Pm	Dakshi	
6/9/22 4.10	20	Basment Female changing Room	Ceiling Fan is not working 01 NOS	Ceiling Fan Removed For Repairing 01 Nos Repaired Ceiling Fan Fiting and connection of 01 Nos	6/9/22 4:15 Pm		
6/9/22 3. Pm	21	Ground Floor HDU	Ceiling Fan one not working 02 NOS	Ceiling Fan checked and found making noise due to Fan Kenopy was loose so we Refixed Fan Kenopy properly it is working.	6/9/22 4.30 Pm		
6/9/22	22.	Ground Floor casualty	Ciling Fan not working in purge areas	Ceiling fan Removed For repair - 01 Nos Repaired Ceiling Fan	6/9/22 4.21 Pm		

Complain Rec-Date & Time	Complain No	Location.	Nature of Complain	Action taken against complain and use materials	Complain complete Date & Time	HOD / WI sig.	Ele sig.
7-09-22 9:30	23	FOW 2nd Floor.	- 2 Nos celing fan are not working.	2 celing fan removed FOR reparing 2 NOS repaired NewCeiling Fiting and Connection 2 NOS.	10:30 7-09-22	Pending	Dilip Saurabh
7-09-22 9:30	24	=11=	- 1 Nos celing fan running slow.	New 2.5 MFD Capacitor fiting and Connection 1 NOS.	10:30 7-09-22		Dilip saurabh
7-09-22 10:45	25	MOW 2nd floor	New celing fan required. - 4 NOS	Old Fa working celing fan removed 4 NOS. New ceiling fan fiting and connection. 4 NOS	12:15 7-09-22		Dilip Saurabh
7-09-22 12:35	26	=11=	celing fan requaired - 2 NOS	2-Nos old working fan which remove then the are fiting in unit III	12:50 7-09-22		Dilip Saurabh
7-09-22 2:00	27	MOW 2nd floor.	New. ceiling fan requked 2 NOS.	old working ceiling fan remove - 2 NOS. New ceiling fan fiting. and Connection - 2 NOS.	2:50 7-09-22	Verified WID	Dilip Saurabh
7-09-22 2:00	28	MOW 2nd Floor	Celing fan notworking. Dresing Room	Old ~~fan~~ Ceiling fan removed for reposed - 1 NOS And Old working fan which, ~~removed~~ replaced by ne fan is Fitting and connection - 1 NOS	3:30		Dilip Saurabh

7/9/2022
Checked 4:30 pm

Complain Rec-Date & Time	Complain No	Location	Nature of complain	Action taken against complain & use materials.	Complain complete Date & Time	HOD / W/I Sig.	Ele. Sig.
7-9-22 3:45	~~Opthal~~ 29 Checked	Opthalmology ward 2nd floor EEE	Ceiling Fan is not working. - 2 Nos. ✓	Old Fan is removed for repaired - 2 Nos. Repaired Fan is fitting and connection - 2 Nos.	7-9-22 4:20	S/N Kavitha	Dilip Sowrath
8/9/22 8/Am	Ground 30	Ground Floor Central Pathology Lab	Power Supply OFF of Store - Room	10A. S. P. m CB was Trip so I checked Store Room All Lights and Fan Switch it on condition So we did all Switch off and 10A S.P. MCB on and checked One by one Switch on Found OK Supply is working.	8/9/22 10 Am	A.N	By
8/9/22 10 Am	31	— 11 —	Central Pathology Lab Lights not working in passag area	we checked power Supply is not coming due to S.P MCB was Trip So we did MCB On and Checked Tubelights is working.	8/9/22 11:Am	Asi	By
8/9/22	031 11 Am	Water Pump Room	3Φ Motor Pressor is Low	Checked 3Φ connection and Found anti clock wise Rotation So Reduced	8/9/22	By	By

Complain Rec - Date & Time	Complain No.	Location	Nature of Complain	Action taken against complain & use materials.	Complain complete date & Time	HOD/W/I sig.	Ele. sig.
8/9/22 11:30 Am	32	Micro Lab Ground	Power Supply and Tube lights are not working in Gents and Ladies wash room	I checked Switch Board and Found all Switch on condition So I did Switch OFF all Switch Board and Found consild Box is Rusted due to Shourt circut in Switch Board So we removed Rusted consild Box and on The power supply on Tempory Basis	8/9/22 12 Pm		
8/9/22 12.15pm	33	University 3rd Floor	Lane Switch power Supply off due to water Leakage	we are checked in Lan Switch and Found Sam water in side So we removed water From Blower and on power Supply now power Supply is working.	8/9/22 1.30 pm		
8/9/22 1:35 Pm	34	University 3rd Floor	power Supply was off due to water Leakage.	we are checked UTPN D.B. and Found MCB was off condition we found There is nat water Leakage so we on th	8/9/22 1.50		

Complain Rec - Date & Time	Complain No	Location	Nature of Complain	Action taken against complain & use materials	Complain complete Date & Time	HOD / W/I Sig.	E/e Sig.
8/9/22 2 PM	35	1st Floor MSW II	Power Sapply Requered with 4 points Sockets For computer which is use For MJPJY Staff	① I checked There is not power poins avalable For addisinal computer So we arranged 4 points Power Strip From Hospital Store and ~~Installation~~ Fixed in MSW II on Nursing conter Temporary basis Our recommendation please demand For Separate UPS For One computer due to There is ups power Supply is not avalable.	8/9/22 3 PM		
8/9/22 3.15pm	36	3rd Floor SPL-Rooms	Fan Regulator is not working 01 Nos in Rooms No-06	Checked Fan regulator there nob is broken So replaced Fan Regulator nob in Room-No-6 it is working.	8/9/22 3:20 Pm		
8/9/22 3.30pm	37	6th Floor Sleep Lab	Tube light is not working-01 Nos (Dr. Issac mam	36 w 2'x2' New LED panel Lights Fiting and connection (Dr- Issac mam)	8/9/22 4:00 Pm		

Complain Rec- Date & Time	Complain No	Location	Nature of complain	Action taken against Complain & use materials	Complain complete Date & Time	HOD/WI sig.	Ele. sig.
9/9/22 9:00 Am	38	Ceintral patholg Ladies room	One Ceiling Fan is not working.	Cell not working Ceiling Fan Removed For Repair - 01 No Repaired Ceiling Fan Fiting and connection work done.	9/9/22 10.00 Am		
9/9/22 9.00 Am	39	—11—	15 watt Panel Led is not working - 01	15 w Panel LED New Fiting - 01 and Lights Paint wiring Replaced which is Faulty	9/9/22 11:30 Am		
9/9/22 11.30	40	Ground Floor OPD -	Exhaust Fam one Nos Requered	Exhaust Fam new Fitting and connection	9/9/22 12 Pm		
9/9/22 12. Pm	41	6TH Floor Front of LIFt Back Side	Tube light 2'x1' is not working 01 Nos	2'x2' One 36W.x2 Lights Fitting 01 Nos and Cell not working Light Removed	9/9/22 02 pm		

Complain Rec - Date & Time	Complain No	Location	Nature of complain	Action taken against complain & use materials.	Complain complete Date & Time	HOD/ W/I sig	Ele sig.
9/9/22	42 3.Pm	2nd Floor Opthal ward	No power Supply in the Halpward due to MCB Trip	we checked all Lights and Ceiling Fans one by one it is proper working we checked in Ladise wash room There one Gizer is not working and due to there coil / sensor is Shourt (need to be repair) duee to power Supply off So we desconnected From D.Pol MCB and reset RCCB and on the Supply work done. Inform to On duty Sister For make Letter For Gizer repairing.	9/9/22	SIN Kavita 2.30 PM	

Comp Rec Date & Time	Complain No.	Location	Nature of Complain	Action taken against complain & Use materials	Complain complete Date & Time	HOD/ WI sig	Ele Sig.
10/9/22	43 2:10	Medicine OPD 1st Floor	Ceiling fan is not coorking - 1 Nos.	Old ceiling fan is not working and removed for repare. And repaired ceiling fan fitting and connection - 1 Nos Work done	10/9/22 2:30	Prabhi SIM	Dilip Sawabh
10/9/22	44 2:40	Medicine Ward 4th floor	Ceiling fan is not working. - 1 Nos	Old ceiling fan is not working and removed for repair. And repaired fan is fitting and connection - 1 Nos.	10/9/22 3:10	~~Working~~	Dilip Sawabh
10/9/22	45 3:30	Micro Lab	Ceiling fan is not coorking. - 2 Nos.	Old ceiling fan is not working and ~~repaired~~ removed for repair. And repaired celing fan is fitting and connection - 02	10/9/22 4:10	Received Pms a 4:06 PM	Dilip Sawabh
11/9/22	46	New canteen at CSIT College	New energy meter Required For Billing parpose	New energy meter Installed by U.C. engineering work done.	11/9/22 3:30 PM		By

Comp. Rec Date & Time	comp. No.	Location	Nature of complain	Action Taken against complain	complain complte Date & Time	HOD/W/I Sig	Ele Sig.
11/9/22 10.00	47	Hospital Teresa 1st Floor	H Letter is not Working due to Aarralic Broken and LED Fused	H Letter Repaired By Said Vender Work done	11/9/22 3:30pm		
12/9/22 9 Am	48	1st Floor M S W II	Ceiling Fans are not working 02 Nos	Old not working Ceiling Fans are Removed For Repair or Rewinding 02 Nos Repaired Ceiling Fiting and connection 02 Nos	12/9/22 12 PM		
12/9/22 12.54pm	49	Basment A.C. power Supply OFF of T.K. OFFice	AC power Supply off	Checked power Supply Found fult in A.C. due to AC mcb Trip please repair AC fefor on the mcb powe Supply	12/9/22 1:15PM		
12/9/22 1:20	50	Medicine Department 4th floor	Ceiling Fan is not working - 1 Nos.	Old Cieling Fan is not working and removed for repaire or rewinding - 01 Nos. Repaired ceiling fiting and	12/9/22 1:35		

Comp. Rec - Date & Time	Comp. No.	Location	Nature of Complain	Action taken against complain & Use material	Complain complete Date & Time	HOD / W/I Sig.	Ele sig.
12/9/22 1:40	51	EMS - ICU Ground Floor	Power supply off of bathroom	16A S.P. MCB was Trip so I checked bathrooms all lights and fan switch it on condition. So we did all switch off and 16A S.P. MCB on and checked only lights switch on found ok. Supply is working.	12/9/22 1:50	SJN Ajit 13-09-22	Rohit Dage Saurabh.
12/9/22 3:20	52	5th Floor MMW	Many Ceiling Fans are not working - 1 Nos.	Old ceiling fan is not working and remove for repaire or rewinding And repaired ceiling fan is fitting and connection - 1 Nos. Work done.	12/9/22 3:50	Lost W/S	Dilip Saurabh
12/9/22 4:00	53	1st Floor MSW I	Tube lights are not working and Ceiling Fans are not working	22 W 4 feet LED light fitting and connection - 1 Nos Old ceiling fan is not working and remove for repair and repaired ceiling fan is fitting and connection - 1 Nos.	12/9/22 4:30		Dilip Saurabh

Comp. Rec. Date and Time	Comp. No.	Location	Nature of Complain	Action taken against complain and use materials	Complain complete Date & Time	HOD / WI Sig	Ele Sig.
13/9/22 12:00	54	Radiology R.no-58	AC ~~Supply~~ is not working.	Checked power supply and found 32A MCB was trip. Therefor we on the MCB. And supply is On. Work done.	13/9/22 12:20		
13/9/22 2:20	55	MSW II 1st Floor	Tube lights are not working - 2 Nos.	18W 4 Feet LED lights are fitting and connection - 2 Nos. Work done.	13/9/22 2:50	Gopal S/N.	Dilip Sauvabh
13/9/22 4:00	56	ENT ward 1st Floor	Ceiling Fan is not working - 1 Nos.	We checked the connection of ceiling fan and found no connect of nutral ~~of~~ supply. and the wire is ~~break~~ down due to extra load. We remove the old neutral wire and fix new one. Ane connet to the ceiling fan. Neutral Supply is on. Work done.	13/9/22 5:30	S/N Deepali	Dilip Sauvabh

Comp Rec. Date & Time	Comp. No.	Location	Nature of complain	Action taken against complain & use materials	Complain complete Date & Time	HOD/ WLI sig	Ele. sig.
14-09-22 9:00	57	Old laundry	Laundry Heter not working	4 pole MCB trip 4 pole MCB restart and one Coil wire disconect.	14-09-22 9:30		Shreekanth
14-09-22 10:15 10:15	58	Special ward	Electric bel not working	Electricial bed new fitting Ro No: 2, 3, 4, 6, 13, 15, 16	14-9-22 12:15	Jamun	Shreekanth Dilip Dilip
14-09-22 1:40	59	Med/ MOW 2nd floor	Old fan remove and Submite	25 fan Condamination Geom mail altho. ward Second shift sister hand over.	14-9-22 4:30	Puja	Shreekanth Dilip Dilip
14-09-22	60	MOW 2nd floor.	Celing fan not working DDR Room	fan Not available.			
14-09-22 4:00	61	Sacotic ward	Tube light not working.	New LED Tube light fiting and connection.	15-9-22 7:30	Rathod	Dilip

Complain

Rec-Date and Time	comp No.	Location	Nature of complain	Action Taken against complain	complain complete Date & Time	HOD/ W/I Sig	Ele.
15/9/22 9:20	62	3rd Floor University	Power Supply is not working in All computers	we checked power Supply and Found UPS OUT PUT power Supply is not working due to power Supply was OFF. So we call mr. Sukla (UPS Engineer) and UPS did reset and ON (40 KVA EATON) Power Supply is working. ✱Note:- UPS Engineer mr. Sukla ji advised For A.C. Installation in UPS Room For Smoth Functioned 40 KVA UPS OUT PUT power Supply we are Inform to mrs - Jyoti Aravel mam For 1.5 Ton Inverter A.C. Installation in 40 KVA UPS Room 4th Floor	15/9/22 9:55Am	15/09/2022	
					15/9/22 10.02Am	15/09/2022	
15/9/22 9:40Pm	63	Ground Floor Medical college	Power Supply is not working	we are checked power Supply in D.B. Found in coming wire was desconnected so we are connected main wire and on the power Supply	15/9/22 10:58Am	15/9/2022	15/9/2002

Comp Rec Date&Time	comp - No.	Location	Nature of complain	Action Taken against complain	Complain complete Date&Time	HOD W/I	Sig.
15/9/22 11.00 AM	64	Ground Floor casualty	Ceiling Fan is not working in Bed No. 08	Repaired ceiling Fan Fiting 01 Nos old Fan Removed For repair - 01 Nos work done.	15/9/22 11:45 AM	15/9/22	
15/9/22 11.50	65	Ground Floor minor O.T	O.T. Lights are not working	we are checked power Supply and Found wire Burnt so we are replaced Burnt wire with new Taplane wire with Slue and Found power Supply 24 V in O.T. Lights Terminals it is working with one Light and one Light need to be replaced kindly coch to BME For check the work and replace one Light	15/9/22 3:30pm	Veena S/N	
15/9/22 4:00	66	Psychiatric ward 4th floor	Ceiling fan is not working - 1 Nos.	Old ceiling fan is not working and removed for repair and repair ceiling fan is fitting and connection - 1 Nos Work done	15/9/22 4:30	Rushali	Dilip Suvodh

Comp. Rec. Date & Time	Comp. No	Location	Natrise of Complain	Action taken against complain and use materials.	Complain complete Date & Time	HOD/W/I sig	Ele sig.
15/9/22 4:30	67	Psychiatry ward 4th floor	Ceiling fan is running slow 1 Nos.	New 2.5 MFD capacitor is fitting and connection - 1 Nos. Work done.	15/9/22 4:40	Pathak	Dilip Sawarbh
15-9-22 6:00	68	Psychiatry ward 4th floor	Ceiling fan is running slow - 2 Nos	~~Ceiling fan~~ New 2.5 MFD Capacitor is fitting and Connection - 2 Nos. work done ✓	15-9-22 6:30	Pathak	Dilip
15-9-22	69	Psychiatry ward 4th floor	Old Tube light Not working. 2-Nos	New LED Tube light fitting and Connection work done. ✓ - 2 Nos.	15-9-22 7:50	Pathak	Dilip
16/9/22 10:00	70	FSWI 1st floor	~~Gyser~~ is not working.	We checked the gyser and it working properly. Supply is ok. No remaining complain for electrician	16-9-22 10:20		
16/9/22 10:30	71	MOW 1st floor.	No power supply in the ward due to RCCB trip.	We checked the power supply and found 40A RCCB is trip. We restart the RCCB and supply is ON. Work done. No remaining complain for electrician.	16-9-22 10:40		Supr

Comp. Rec Date & Time	Comp. No.	Location	Nature of comp.	Action taken against complain and use materials	Complain complete date & Time	HOD / W/I sig.	Ele. sig.
16/9/22 11:30	72	MMW I 5th floor	Tube light is hanging - 1 Nos.	~~tube~~ 22W 4 feet LED light is hanging and we fix it with ~~chain~~ angles. Work done.	16/9/22 11:45		
16/9/22 4:00	73	FMW 6th floor	Fan is not working - 1 Nos.	Old ceiling fan is not working and remove for repair and Repaired ceiling fan is fitting and connection - 1 Nos. Work done	16/9/22 4:30	Ore Repaired. SN Geeta 752	Dilip Sawant
16/9/22 5:30	74	HVAC 5th floor.	fan is not working - 1 Nos.	Old ceiling fan is not working and remove for repair and Repaired ceiling fan is fitting and connection - 1 Nos Work done.	16/9/22 5:55	Approved.	Dilip.
16/9/22	75	HVAC 5th floor	fan is not working - 2 Nos chiller machine need. = Pending -	—			
16/9/22 7:15	76	FMW 6th floor	2 fan 2 tube light Not working.	FMW 6 A MCB was Trip so I checked. There was a MCB trip I checked it its connection was ~~work done~~ loose I tightened it	16/9/22 7:30	SN Geeta 757	Dilip

Com Date.	Comp No.	Location.	Nature of Comp.	Action Take against complaint and use material.	Complain Date & Time.	HOD/WIC sign	Ele. sing.
16/9/22 1:00	77	Basement Lemmary Ground floor.	Tubel light Not working 1-NOS.	New LED Tube light fitting and Connection	16-9-22 1:15		Dilip Rohit.
		5TH FLOOR	New power points are Required for P.C.				
17/9/22 8.00 Am	78	MJPJAY (MMW)		we are removed old Swith Board and make new power points 04 Nos (old) and Inform Mr. Yogesh Sakhare Sir.	17/9/22 10.50		
		4th FLOOR	power Supply OFF				
17/9/22 9.46 Am	79	Surgery Dep		we checked power Supply and Found on position My observation computer room water leakage from The ceiling due to power OFF my Recomondation please stop the water Leakage From consurn dep. For Avide power Faluar. also inform to Mr. Gagnon Sir.	17/9/22 11:00 Am	17/9/22	
		6TH FLOOR	New power points are required For computer	we are make power points 4 Nos of FMW Rack Side Nursing Station	17/9/22 12:30 Pm		
17/9/22 11.00 Am	80	MJPJAY (FMW)					

Comp-Rec Date&Time	comp No	Location	Nature of complain	Action Taken against complain	Complain Complete Date&Time	HOD/WI Sig.	Ele. Sig.
17/9/22 1:00pm	81	Ground Floor Hous Kiping & Office	Ceiling Fan is not working.	Rewinding Repairing ceiling fan Fitting and old ceiling Fan Remove -1Nos	17-30 pm 6:00pm	Way	Shreekanth Halke
17/9/22 1:00pm	82	6TH Floor FMW	Ceiling Fan is not Working Back side Nursing station (New MJPJAY Staff)	Rewinding Repairing ceiling Fan Fitting 1Nos and old ceiling Fan Remove - 1Nos	8:00pm	SN Geedy 7th	Shreekanth
17/9/22 2:00pm	83	special ward 3rd floor	Electrical Bell and ceiling fan not working	Electrical Bell Fitting Room. 13,14,15,16,17,18 Rewinding Repairing ceiling Fan Fitting Room. No: 12 - 1Nos and old ceiling Fan Remove - 1Nos	17-09-22 2:30pm	Bhagat ICU	Shreekanth
17/9/22 4:00	84	M.O.W 2nd Floor	ceiling Fan is not working	Rewinding Repairing ceiling Fan Fitting - 1Nos and 1-Nos old Fan Remove - 1Nos	17-09-22 4:20	Nikita SSO	Shreekanth
17/9/22	85	Staff quater 4th flore 404 Room. fan Not working	Ceiling fan Not working.	Rewinding Repairing Ceiling fan fitting - 1 Nos. and 1 Nos old fan Remove	17-09-22 4:05 pm	Rathikaj Pawar	Rohit Dunge
17/9/22	86	Blood Bank -1Nos Tube light Not	-1Nos Tube light Not working	Old Tube light remove and New Tube light	17-09-22 11:45	Rohit Dilip	17/9/22 11:45

Comp-Rec-Date&Time	Comp-No.	Location	Nature of complain	Action Taken against complain	Complain complete Date&Time	HOD/ W/I Sig.	Ele Sig.
		3rd Floor	Switch Board is				
18/9/22 8.Am	87.	SPL Room	hanging in Room No - 15	Switch Board fixed with 19x6 Screws work done	18/9/22 8:50Am	Swati S/I	
18/9/22 8:00	88.	5 floor MMW	ceiling fan is running slow	New 2.5 MFD capacitor 18 fitting and Connection - 1Nos Work done.	18/9/22 8:15	Sonal S/I	Dilip
		3rd Floor	Complain by				
19/9/22 9:00 Am	89.	Cath Lab	letter	Visited at site and make requirment as per complain letters and maked purchase order with Store purpose	19/9/22 12:08 Pm		
		Ground Floor					
19/9/22	90.	O.T. (minor)		50W/24 volt Light Remove wich is not working for Sample For purchase	19/9/22 12:30 Pm		
		1st Floor	Tube Lights are				
19/9/22 9:00 Am	91	MSW II	not working of 4 Nos				
		3rd Floor	Ceiling Fan is				
19/9/22 1:00pm	92	SPC Room	not working of 1 No				

Comp Rec Date and Time	Comp No -	Location	Nature of complain	action Taken against Complain	Comp. complete Date/Time	HOD/ WI Sig	Eie Sig -
19/9/22 1:00 PM	93	3rd Floor Room No 8 SPL Room	Calling Bell Indicator not working - 01 No				
-11- 1:00 PM	94	3rd Floor SPL Room	One side Light Repairing work pending -				
-11- 1:00 PM	95	4TH FLOOR Med-Dep	LED Bulb is not working in wash room	New LED Bulb Replace 01 05 watt 01 Nos	19/9/22 2:40 PM		Mahesh
19-09-22 2:00 PM	96	pump House Fire panel	H.R.C. switch not working	H.R.C. new switch Fitting 200A - 1Nos and old H.R.C switch Remove - 1Nos	19/09/22 2:30 PM		Shreekant Halke
20-09-22 2:00 Am	97	Pediatric ward. 4th Floor	Power Supply contine Tripping in D.B. 06	we checked power Supply in D.B. No 6 it is off due to 40 A RCCB, 100 mA was Trip we Attemp to the start contine & Times it not Hold so we replaced 63 A Pol MCB and P do the power Supply on it is working.	20/9/22 4:00 Am	Shreekant 556. 20/9/22.	Dilip Damase

Comp-Rec and Date Time	Comp. No	Location	Nature of complain	Action Tacken against complain	Complain Complete Date and Time	HOD WI Sig.
20/09/22 8:30 Am	98	1st Floor MSW II	Tube lights are not working 04	we checked Tube Lights it is not working due to power Supply was OFF so I have checked in Distribution box there found 10A S.P. MCB was Trip due to one Ceiling Fan winding faulty So we Removed Ceiling Fans wire and 10A S.P. MCB Reset and ON Tube lights are working 04 Nos	20/9/22 9:30 Am	Ashwini
20/9/22 9:35 Am	99	Ground Floor minor O.T.	O.T. Lights (Sado Lights) is not working	we are checked power Supply and Found OK also checked 24 Volt 50 Watt Halozen Bulb and Found one Halozen Bulb fused So we Replaced with new 24 Volt 250watt Halozen Bulb O.T. Shado Less Lights are working.	20/9/22 12:44 Pm	Ashwini

Comp-Rec-Date and Time	Comp-No ↓	Location	Nature of complain	Action Taken against complain	Complain complete Date & time	HOD/ W/I Sig	Ele. Sig.
20/9/2022 12:45	100	Ground Floor Seminor Hall	New power points are Required	6'A X2 Nos power points Fitting with all accesorees in Seminor Hall which is use For projecter 100%. Work completed	20/09/22 1:30 Pm	Nagnath 22/9/22	By
20/9/2022 1:30 Pm	101	Ground Floor minor O.T.	Ceiling Fan Shifting work From other place to Nursing conter -02 Nos	we Removed 02 Nos Ceiling Fans as per required and Ceiling Fan Shifting From other place to Nursing counter 02 Nos work done.	20/9/22 2:00 Pm	Ashwini	By
20/9/2022	102	Ground Floor	120 KVA UPS AMC/CAMC Expire Date 29/9/22	Invite Genuine vender and tacked 120 KVA praposel for CAMC For Next 5 (Five) years on prosses work	20/9/22		By
21-09-2022 10:30	103	M.S.W.I	Tube Light Not working in sporking	Exhaust Fan supply Joint Water Leakage and sporking Joint is Remove	20-9-22 10:31	~~Akt~~	shreekant

Comp. Rec. Date & Time	Comp. No.	comp NO ↓ Location	Nature of Complain	Action taken against Complain and use Materials	Complain Complete Date & Time	HOD /w/I sig	Ele. sig'
20-9-22 10:55	104	M.S.W.I	Tube light Not working and 1 Tube light Hanging ~~and~~	20w L.E.D Tube light fitti - 1Nos and prop~~s~~ Fitti ~~L~~.e.~~D~~ Bulb - 1Nos	20-9-22 ~~11:30~~ 11:00	~~PK~~	Shreekanth
20-9-22 12:00	105	old Laundry	Tube light and fan Not working	20w. L.E.D Tube light - 1Nos 2.5.m capacitor - 1Nos			
20-9-22	106	X-Ray	Ac Not working	32A.S.P M.C.B Fitting - 1Nos Ac. is working	20-9-22		Shreekanth
22-9-22 3:00	107	4th Floor Psychiatry coard	Guyser is not wooking.	New 32A two pole MCB fitting and connection - 1 Nos.	22-9-22 3:30	Pradeep	Dilip Sawanth
22-9-22 ~~1:30~~	108	4th Floor Psychiatry ward	Tube light not working - 1Nos.	New old Tube light remove and new Tube light fitting and connection Work is done.	22-9-22	Dilip	Dilip
22-9-22		4th floor Psychiatry Ward	Tube light not supply.	LED tube light check the supply is one but tube light not work Connection loose. I have work done.	22-9-22	Dilip	Rohit.
23-9-22		Casualty gate Ground floor	UPS Supply off.	Two Switch Board supply off. because MCB triped. I have checked to ~~supply~~ X-Ray light machine wire & joint Normal	23/9/22	Ramesh Sir	Rohit Dilip.

Comp - Rec - Date Time	comp No +	Location	Nature of complain	Action Taken against complain.	Complain complete Date & Time.	HOD / W/I Sig.	Ele. Sig.
		Ground Floor					
23/9/22 9:00Am	111.	Central - P. Lab	New power points are Required For Fridge 03 Nos	16 A Power points new Fitting and connection 04 Nos For Fridge in Central Pathology Lab Store room all Fridge ~~is~~ are working.	23/9/22 11:00Am	SDW	BY
23/9/22 11.00Am	112.	Ground Floor C.P.Lab	old power points are not working and 16 A Power Points are Burnt	we have checked and Found 16 A power points are Burnt due to over Load connected So we have make power points Separate for Auto cleve and Sterizer machine it is working correct work done.	23/9/22 1:00pm	SDW	BY
23/9/22 1:30Pm	113.	1st Floor MSW II	old Switch Boards are hanging	we have checked old Swith Boards are not in use due to we have removed hanging power points with old hanging cable and Removed Lan cable which is not in use.	23/9/22 3:00Pm		BY

Comp-Rec Date and Time	Comp. No.	Location	Nature of complain	Action Taken against complain	Complaint complete Date & Time	HOD / W/I Sig.	Ele. Sig.
		4TH Floor					
23/9/22	114 3:00Pm	Medicine Dep	HOD wosh room Tube light is not working	We have replaced 12 watt LED Bub and Angle Holder 01 Nos work done.	23/9/22 3:30Pm		
		Ground Floor					
23/9/22	115 3:30Pm	Casualty	power Supply is not working in Nursing Station and X-Ray View box	Checked power Supply in power points and Found OFF power Supply due to 6A S.P. MCB was OFF in D.B. No-25 we Reset 6A SP MCB and on the MCB 6A S.P. power Supply Checked and found OK one power cable is faulty need to be replaced work done.	23/9/22 4:00Pm	Gadhan	
23/9/22 11:00	116 4.00Pm	O2 Room.	Tube light is not working - 1 Nos.	Old tube light is not working and remove - 1 Nos And new 22 W 4 feet LED light fitting and connection - 1 Nos. Light is working. Work done.	23/9/22 11:26 4:15Pm	23/09/22	

Comp. Rec. Date & Time	Comp. No.	Location	Nature of Complain	Action taken against complian and use materials.	Complain complete Date & Time	HOD / W/I sig.	Ele sig.
23/9/22 2:30	117	Special ward 3rd floor	Lights are not working.	We checked the lights of all rooms in special ward and found 2x2 LED panal lights are not working - 06 Nos. Nursing station - 1 Nos 2x2 light fitting and connection Room no - 13 & 16 - 2 Nos 2x2 light fitting and connection. Special ward passage - 2 Nos. 2x2 light fitting and connection. All lights are now working. Work done.	23/9/22 4:30	S/N Supervisor	Dilip Jawale
23/9/22 6:00	118	Laundry ward	Tube light not working. 1-Nos	old tube light remove and new tube light fitting and connection Work done. 1-Nos.	23/9/22 6:30		Dilip
23/9/22	119	Laundry ward.	Fan running but slow	New 2.5 MFD Capacitor fitting and connection 1-Nos.	23/9/22 6:30		
23/9/22 12:10	120	MMW 5th floor	Fan is not working.	OLD fan remove and New fan fitting and	23/9/22 12:20	Pawar S/N Supervisor	Dilip Rohit

Comp. Rec Date & Time	Comp No.	Location	Action & Nature of Complain	Action taken against complain and use materials	Complain complete date & Time.	HOD / WI sig.	Ele sig.
24/9/22	121	MSW-1	MSW one side light off MCB trip.	We checked power Supply and found on power supply due to cable is ~~faulty~~ loose. ~~Fitted~~ Connection. Work done.			Dilip
		Ground Floor	New A.C. power points D.P. Switch Required - 01 Nos				
24/9/22 8:00 Am	122	EMS ICU		we have checked these power Supply Cable was available but control MCB D.P. there was not avlable So we have new D.P. MCB Installed 01 Nos and one D.P. Incoser box Fiting - 01 Nos work done.	24/9/22 10.00Am	Ankit 1978	Dilip
24/9/22 9:00Am	123	Ground Floor HDU.	water cooler is not working.	we have checked power Supply was off So we checked in ETPN D.B There 10A S.P. MCB was Trip we Reset the 10A MCB and on we Found Foutlt in water cooler and inform to mr vaman	24/9/22 10.30Am	Ankit	Dilip

Comp. Rec. Date & Time	Comp. No.	Location	Nature of Complain	Action taken against complain and use materials	Complain complete Date & Time	HOD / W.E sig.	Ele. sig.
24/9/22 10.00pm	124	Ground Floor H.D.U.	Switch Board was Broken	we checked Switch Board of water cooler and water filter Both are Broken So we have Replaced 16A Switch - 02 Nos 16A Socked - 02 Nos 6m Plate - 01 Nos 6m S. Boa - 01 Nos Switch Board Replace work done.	24/9/22 12:00pm		
24/9/22 11.00 Pm	125	2nd Floor F.O.W.	Power Supply was OFF	we have checked power Supply and Found circuit wise was Desconnected in old Switch Board So we connect 2.5mm wire in 6A socket and do the power Supply on and Found OK work done.	24/9/22 1:00Pm		
24/9/22 12:Pm	126	1st Floor MSW I	New Geyser Instellation work.	we have Installed new 3 Liter 4.5 KW water Geyser - 01 Nos in central Bath Room.	24/9/22 2:00Pm		

Comp-Rec Date & Time	Comp No	Location	Nature of complain	Action Taken against complain	Complain complete Date & Time	HOD / W/I Sig.	Ele. Sig.
24/9/22	127	3rd Floor O.T. No 13	X-Ray Verne box is not working.	No – Time O.T. was Busy			
24/9/22	128	Ground Floor. Resuscitation.	~~One of the tubes~~ One of the tubes in the insect killer is blocked, fix it tomorrow. Emergency.				
24/9/22 9:00	129	MMW 6 S floor.	fan is not working. - INOS.	Old fan remove and New fan fitting and connection - INOS. Work is done.	24/9/22 9:30	S/N Mehtre Rutuj Rutuj	Dilip Rohit
24/9/22 1:00	130	MSW-2 1st floor.	The MCB was Tripped. The light of the entire ward was gone.	The MCB was tripped we checked a lot and found the faute and turned the MCB on Work is done.	24/9/22 1:15	Rutuj	Rohit Dilip.
5/9/22	131	CVTS 3 floor	Store Room AHU relay Tripping. Not Holding	CVTS was tripping the relay of AHU in ICU, I Checked a lot and then found a fault. one of its wires was	24/9/22		Dilip Rohit

Comp Rec Date & Time	Comp No	Location	Nature of complain	Action Taken against complain	Complain complete Date&time	HOD / WI Sig	Ele Sig
26/9/22 8:05 Am	132	3rd Floor O.T.	X-Ray view box is not working of IOT No - 13	we have checked power supply was ok and opened X-Ray view box and found power Adaptor faulty and Repair / Replace it X-Ray view box is working of O.T. No - 13	26/9/22 12:50 Pm	26/9/22	By
26/9/22 11:30 Am	133	Ground Floor water cooler and water filter HDU	power Supply was not working	we checked power Supply and found 10 A S.P. MCB was Trip due to water Cooler Faulty need to be repair by Li vender also inform mr. Vaman pulumber — we did Reset 10 A S.P. MCB and the power Supply do the on water filter is working	26/9/22 01:10 Pm		By
26/9/22	134	Pediatric ward 4 Floor.	MCB TRIP 10 Amp	4 Floor pediatric had a MCB trip I Checked fully and Switched it back	26/9/22 12:00	S/N Ranjit	Dilip Rohit

Comp. Rec. Date & Time	Comp. No.	Location	Nature of Complain	Action taken against Comp. & use materials	Complain complete Date & Time	HOD/ W/I sig	Ele sig.
26/9/22 10:00	135	MMW 5floor	MCB 6 AMP Damage	The 6 AM MCB of 5th floor was damged and the light went off Completely. So we changed it Work done.	28/9/22 10:45	SIN Viran Virat	Dilip Rohit
26/9/22 3:00	136	CVTS Ward 3rd floor.	Light is Not working - 06	Old 2x2 lights are not working - 06 New 2x2 lights are fitting and connection - 06	26/9/22 4:30		Rohit Shreekanth Sawabh
27/9/22 10:00	137	— 11 —	lights are not working - 08.	Old 2x2 lights are not working - 08 and removed. New 2x2 panal lights are fitting and connection - 08.	28/9/22 12:00		E- Dilip Sawabh
27/9/22 2:30	138	Casualty Ground floor	Insect killer tube is not working - 02	We checked that insect killer and found no gas in tubes - 02 Neew tubes and chokes required - 02	27/9/22 3:00	Virat	

Comp. Rec. Date & Time	Comp. No	Location	Nature of Complain	Action taken against comp. & use materials.	Complain complete Date & Time	HOD/WE sig	Ele. sig.
27-9-22 8.30 pm	139	Respiretory & flore	No fan in ~~2 Nos~~ ward 2 Nos.	New 2 Fan fitting & New Connection J- Work is Done,	27-09-22 9:15 pm	~~Patil~~	Rohit Dupe Shreekant
28-9-22 9:00 Am	140	M.M.W.I&II	Fan Not wirking	2.5. mld ceiling Fan copocitor Fitting-15Nos	28-9-22 9:30Am		Shreekanth
28-9-22	141	S.P.W	Light is Not working	4pin TLL light Fitting -6Nos	28-9-22	Mavali SIN	
25-9-22	142	C.V.T.S. ward	Light is Not working	old Light are Not working -06Nos ~~New~~ 2x2 Light are Fitting and cantin -6Nos	dnjlh 136 28/9/22	~~Dnjlh~~	
28-9-22	143	FOW 2nd flore	Supply off in ward	We Checked that Supply in DB, MCB triped. & Supply ON. work Done		Dilip Rohit Dupe Lidar	
28-9-22	144	MMW	Fan not working	We checked Connection, to Switch Cable loose, & Connection ok. Work done.		Vanekary	Rohit Dupe Dilip

Comp. Rec. Date & Time	Comp. No	Location.	Nature of Complain	Action taken against comp. & Use materials.	Complain Complete Date & Time	HOD/ WI Sig	Ele Sig.
29/9/22 9:00 Am	145	Ground Floor EMS-ICU	Tube lights are not working in Toilet Rooms 03 Nos	18 watt New LED Panel Lights Fitting and connection - 03 Nos checked with on power Supply it is proper working	29/9/22 10:00 Am		By
29/9/22 10.00 Am	146	Ground Floor EMS-ICU	Tube lights are not working in Doctor Dutty Room	checked power Supply and found 2'x2' POP Lights is not working So we are new panel LED 22 Watt Fitting - 02 Nos with wiring in Doctor Dutty Room work has completed	29/9/22 11:00 Am		By
29/9/22 10.00 Am	147	2nd Floor P.T.O.P.D.	Power Supply is not working due to ceiling fans and Tube lights are not working	we are checked power Supply in D.B. and found 40A RCCB was Trip dee to very old age wiring need to be replaced also wooden Switch Board for normal Functional RCCB power Supply. we Replace 4 Pol MCB with 40A RCCB. under Abservation	29/9/22 11:30 Am		By

Comp. Rec. Date & Time	Comp. No.	Location	Nature of Complain	Action taken against Complain & Use materials.	Complain Complete Date & Time	HOD / WI sig.	Ele Sig.
		4th Floor Medicens	Tube light Fitting work	2' x 2' Lights fitting of 1 No			
29/9/22 11:00 AM	148	Dep.					
29/9/22	149	2nd Floor F.O.W.	RCCB getting Tripped.	we are checked power supply one by one 40 A RECB 100 mA getting cont.- Tripped so due are Replaced with 63 A 4 Pole MCB on Temporery basis Power Supply is working	29/9/22 12:00pm	Sujata 29/9/22	1
29/9/22 12:15	150	Ground Floor EMS ICU	Out LED NOT working Toilet power Supply of.	We are checked Power Supply in D.B are found 6 nos wire trip due to Out LED loose connection and MCB single pole MCB loose connection. Work is done.	29/9/22 12:30	Ankit 1478	Dilip Rohit

Comp. Rec. Date & Time	Comp. No	Location	Nature of Complain	Action taken against comp. & Use materials	Complain complete Date & Time	HOD / NS sig.	Ele sig.
30/9/22 8:00AM	151.	3rd FLOOR Cath Lab	Tube lights are not working.	We checked power Supply and found OK many Tube lights had Fused So we are replaced new LED Lights 36 W 2'X2' Light LED Panel fitting - NOS 22 watt LED Panel Lights fitting and connection NOS 12 watt LED Bulb fitting and Connection	30/9/22 1:00PM	Patel Pranita	
30/9/22 12:00 PM	152.	1st Floor MSW II	Remove old net in use cable.	We are Removed old net working / hanging wire / cable	30/9/22 02:00 PM		
30/9/22 12:00 Pm	153.	3rd Floor Dialysis	New power points Required for computer For MJPJAY	We makked power points for computer on Temporary basis with casing Caping Patti	30/9/22 02:pm		
2/10/22	0153.	3rd Floor CVTS/ward	Power point need to be repair	16A/6A powe Swith and Socket Fixed in plate - 60 NOS	2/10/22		

Comp. Rec. Date & Time	Comp. No.	Location	Nature of Complain	Action taken against comp. & Use materials.	Complain Complete Date & Time	HOD Init Sg.	Ele. sig
01/10/22 9:10 Am	154	Ground Floor 'A' side main Electrical Panel	Preventive Maintenance	Main Electrical Panel All Feeder Cleaning with Blower also Cleaned Electrical panel Room 'A' side with Ele- Team	1/10/22 1:00 PM		
1/10/22 1:05 PM	155	Ground Floor 'B' Side Main Electrical Panel	Preventive maintenance	'B' Side all Feeder in panel Cleaning ~~and~~ with Blower also Cleaned Ele Panel Room. with Ele- Team.	1/10/22 3:20 PM		
1/10/22 3:20 PM	156	New Canteen Near Main gate	Tube light Required - 01 Nos	22 watt 4' Tubelight new fitting and connection	1/10/22 4:00 PM	2 nos	
2/10/22	157	MMW store	1- Nos fan Not Working	Old Fan Remove and New fan fitting and Connection. - 1 Nos. Work done.	2/10/22 1:32 pm	Sanu SM	
3/10/22 10:00	158	Ground Floor EMS - ICU	22 watt Panel LED Required 04 Nos	New 22 watt panel LED lights are fitting and connection - 04 Nos.	3/10/22 1:00	Probable WE	Prathmesh Nishant
3/10/22	159	3rd Floor Ped- and	wall fans are not working.				

Comp Rec Date & Time	Comp No	Location	Nature of complain	Action Taken against complain	Complain complete Date & Time	HOD W/I Sig.	Ele Sig.
		Ground - Floor					
3/10/22	159	HDU	Ceiling Fan is not working - 01 Nos	Ceiling fan is not working due to loose connection. We fix the Phase wire and connect it properly. Ceiling fan is working. Work done.	4/10/22 10:10		Nishant Suvasth
		5th Floor	There are no Geyser for Hot water yet. The geyzers installed on 5th Floor are still not working.				
3/10/22	160	Medicine Dep					
~~3/10/22~~	~~161~~	~~1st Floor~~ ~~MSWI~~	~~Geyzer power Supply connection Required of Nos~~				
		3rd Floor	Many Switch Boards are Broken need to be Replace.				
3/10/22	162	CVTS - ICU and CCU					
		Ground Floor	A.C. is not working due to ther MCB is not working.	We checked and found 20A MCB single pole was faulty - 2 Nos And 25A single pole MCB fitting and connection - 2 Nos. AC is working.	3/10/22 5:00		Prathmesh Suvasth.
3/10/22 4:20	163	casualty					

Comp. Rec Date and Time	Comp No.	Location	Nature of complain	Action Taken against complain	Complain complete Date & Time	HOD/ W/E Sig	Ele Sig.
3/10/22 10.30	164	3rd Floor OT.	16A MCB trip - 3 Nos. Single pol OT-14	We checked the DB and found MCB 16A is off due to electrical work and restart the MCB of 16A single pole. - 3 Nos. OT - 14 Work done	3/10/22 11:00		
3/10/22 5.10	165	Main Sub station	Transformer cleaning	Main transformer cleaning with blower & remove all dust	3/10/2022 5.45		Prathamesh
4/10/22 11:20	166	EMG- ICU Passage. Ground floor.	2x2 LED panel lights are required - 2 Nos.	New 2'x 2 LED panel lights are fitting and connection - 02 Nos. Work done.	4/10/22 12:10	Abdullah W/E	Saurabh Vishant
4/10/2022 2.49 pm	167	Casualty gate ground floor.	Switch Board Body. Screw Screw Damage	New Screw insert and fiber Cap insert work Done	4/10/22 3.00 pm		Rohit.D. Nishant
4/10/22 8:10	168	5th floor MMW I	10 ceiling fan are slow light are not working - 2 Nos.		4/10/22 8:pm	Sonal	
	~~169~~	5th floor MMW II					

Comp. Rec Date & Time	Comp. No.	Location	Nature of Comp.	Action taken against comp. & Use materials	Comp. Complete Date & Time	HOD / WI Sig	Ele. sig.
6/10/22 10:00	169	OT 3rd floor OT no - 13	Three Pin top required for view boxe - 1 Nos.	New 6A three pin top fitting and connection to the view boxe - 1 Nos view boxe is working. Work done.	6/10/22 10:30	SP valsons	Nishant Sawabh
6/10/22 10:45	170	Psy. Ward 4th floor	Switch board is not working - 1 Nos.	We checked the switch bord and found 1 socket and button is damage. We connect new switch and socket of 6A = 1-1 nos Switch bord is working. Work done.	6/10/22 11:30		Nishant Sawabh
6/10/22 11:45	171	Physiotherapy Ward 2nd floor.	Passage lights are not working.	We checked the lights and found no supply. And MCB not working - 6A. We transfer the wire to the anthor MCB of 6 A for temperory work. lights are working. Work done.	6/10/22 12:30		Nishant Sawabh
06/10/22 2:30	172	male surgical ward 1st Floor	Celling Fan Running slow - 10 Nos.	We identify the celling fan and change the fan capaitor insert New capacitor. and the work is done - 2.5 MFD - 10 Nos.	06/10/22 03:40		Sawabh Prathamesh Nishant
06/10/22	173	male surgical	New Geyser connection	New geyser supply fitting			

Comp. Rec. Date & Time	Comp. No.	Location	Nature of Comp.	Action taken against Comp and use of materials	Comp. Complete Date & Time	HOD / W/I Sig.	Ele Sig.
7/10/22 9:45	174	HVAC Dept.	1) Ceiling fan is running slow - 1 Nos. 2) Ceiling fan is not working - 1 Nos. 3) Lights are not working - 4 nos.	1) New 2.5 MFD capacitor replace with old one and fitting & connection. Work done. 2) We checked the ceiling fan and found winding is not working properly. So we replace that fan with repaired ceiling fan - 1 Nos. Fan is working. Work done. 3) New 22 W 4 feet LED is are fitting and connection - 4 Nos. Work done.	7/10/22 12:10	Approved	Swabh Nishant
7/10/22 3:00	175	Blood Bank.	Three pin top required for ~~eto~~ autoclave machine. - 1 Nos.	New 16A three pin to fitting and connection in autoclave machine - 1 Nos. Machine is working. Work done.	7/10/22 3:30	07-10-22	Swabh
7/10/22 ~~3:00~~ 3:30	176	Dialysis ward	Net lan cable connection required for PC.	Install in net lan cable in Dialysis ward for MJPJY Section PC. Work done.	7/10/22 ~~5:00~~	7/10/22 17:11	Swabh Dilip.

Comp. Rec Date & Time	Comp No	Location	Nature of Complain	Action taken against comp & use materials	Comp. Complete Date & Time	Hop/W/S sig.	Ele sig.
7/10/22 5:00	177	~~Dialysis~~ ward	1) New light required - 1 Nos. 2) Extension board required - of 8 module - 1 Nos.	1) New 22W panel ~~light~~ square light is fitting and connection - 1 Nos Work done. 2) 16A switch - 2 Nos. 16A Socket - 3 Nos. 3 pin top 16A - 1 Nos. 8 module extension board fitting and connection and given to the MTPTY. Work done.	7/10/22 6:00	7/10/22 17:12 pm	Dilip Sawabh
7/10/22 8:30	172	ITDU Ground floor	Power supply off. The light of one room was gone.	The light of one room was gone, I checked it and there was an MCB trip. I switched it on.	7/10/22 8:45		Dilip
		Ground Floor					
8/10/22 9.00Am	173	Minor OT	One wall fan is Required in Labour room	16" New wall Fan Fitting and connection in Labour Room.	8/10/22 10:30Am	8/10/22	Nishant.
		3rd Floor					
8/10/22 9:30Am	174	PICU	One wall Fan Required For patient waiting areas.	18" Heavy Duty wall Fan Fitting and connection in	8/10/22 11:30Am		

Comp-Rec (Date & Time)	Comp. No ↓	Location	Nature of complain	Action Taken against complain	Complain complete Date & Time	HOD / E/I Sig.	E/e Sig.
8/10/22 11:00 Am	175	3rd Floor Dialysis	One wall fan Required in patient waiting areas.	18" Heavy Duty wall fan Fitting and connection .01 Nos in patient waiting areas	8/10/22 1:00 pm		
8/10/22 3.45	176	3rd floor ~~PICU~~ Dialysis	12M board with 4 switch & 4 socket Required in Dialysis (PICU)	12 M board with 4 switch & 4 socket fitting in board & get wiring & connection. & board working	8/10/22 4.30	8/10/22 6.32pm	Prathamesh Rohit D Nishant
8/10/22 3.45	176	3rd floor ~~PICU~~ Dialysis	8M board with 1 switch & 3 socket 16A return & 3 pin multi plug return	8M board Return & 3 pin multi plug return null	8/10/22 4.30	8/10/22 6.32pm	Prathamesh Rohit D. Nishant
8/10/22 10:00	177	3rd Floor Dialysis	Wall fan required - 01 Nos.	New Wall fan fitting and connection - 01 Nos fan is working. Work done.	8/10/22 11:00		Dilip Swabh.
8/10/22 11:30	178	3rd floor PICU	Wall fan required - 01 Nos.	New wall fan fitting and connection - 01 Nos. fan is working Work done.	8/10/22 1:00	PICU 10/10/22	Dilip Swabh.
10/10/22	179	2nd floor ENT	selling fans slow working	New 2.5 mf capacitor replace with old one & fit & connected & fan pipe screw fitte	10/10/22		Prathamesh

Comp. Rec Date. Time	Comp No	Location	Nature of Complain	Action taken against complaint.	Comp. complete Date. time	HOD/ WI sign	Elec. sign.
10/10/22 3:00 AM	180	3rd Floor MICU	x-ray machine 3 pin socket not working due to the socket wiring lose connection.	We identify the problem and 3 pin socket connection properly side the connection and x-ray machine work property - Work done	10/10/22 3:30 AM		Rohit. D Mohant
	181						

Aurangabad Campus

MGM MEDICAL COLLEGE & HOSPITA
ELECTRICAL MAINTANCE REPORT 06/09/2021 to 12/09/2021

Sr.No.	Received Date	Time	Attende Time	Response Time	Cpmplaint No.	Nature Of Complent	Name Of Department	Date Of Complation	Close Time	Remark
1	05.09.2021	11.20 am	11.25 am		1897	Gizer not working	Old Deluxe	07.09.2021	11.35 am	
2	06.09.2021	11.00 am	11.35 am		888	Lift no-02 Not working	Time Office	06.09.2021	02.40 pm	
3	06.09.2021	09.30 am	09.45 am		295	Electrical problame	PSM Dept.	06.09.2021	10.30 am	
4	06.09.2021	02.25 pm	03.05 pm		2711	LED Light not Working	New Deluxe	06.09.2021	03.05 pm	
5	06.09.2021	12.15 pm	12.40 pm		863	AHU Servicing work	MCRI OPD	06.09.2021	04.10 pm	
6	06.09.2021	03.13 pm	04.00 pm		1169	Refregator not working	Super Deluxe	10.09.2021	10.40 am	
7	07.09.2021	11.20 am	11.23 am		2601	LED Light not Working	Old Deluxe	07.09.2021	11.25 am	
8	07.09.2021	09.45 am	10.00 am		868	Switch Board not working	MCRI OPD-10	07.09.2021	10.20 am	
9	07.09.2021	12.02 pm	12.35 pm		3548	LED Light not Working	Cardac OT	07.09.2021	02.15 pm	
10	07.09.2021	10.45 am	11.15 am		1906	Water filter not working	Time Office	07.09.2021	12.35 pm	
11	07.09.2021	02.25 pm	03.35 pm		249	Cilling Fan not working	SS OPD	08.09.2021	02.00 pm	
12	07.09.2021	11.35 am	11.55 am		3159	Switch Board not working	ENT Ward	07.09.2021	04.15 pm	
13	07.09.2021	12.10 pm	12.55 pm		815	Split AC not working	Readiology	13.09.2021	09.55 p	
14	07.09.2021	09.40 am	09.55 am		1905	Water filter not working	Time Office	07.09.2021	02.10 pm	
15	07.09.2021	11.05 am	11.35 pm		1906	Water filter not working	HR,Blood Bank,Readiology,Canteen & MCRI OPD	07.09.2021	03.45 pm	
16	07.09.2021	01.08 pm	02.35 pm		1177	Refregator not working	Super Deluxe	10.09.2021	10.40 am	
17	07.09.2021	10.40 am	11.35 am		815	VRV Casset unit-01 not working	Casulty	07.09.2021	02.40 pm	
18	07.09.2021	12.21 pm	02.20 pm		234	LED Tubelight not working	MJPJAY ward	07.09.2021	03.00 pm	
19	08.09.2021	11.45 am	12.05 pm		1907	Water filter not working	Time Office	08.09.2021	12.45 pm	
20	08.09.2021	02.00 pm	02.25 pm		3025	Switch Board not working	MMW	08.09.2021	02.30 pm	
21	08.09.2021	10.05 am	12.15 pm		3160	Switch Board not working	Covid-19	08.09.2021	04.25 pm	
22	08.09.2021	12.21 pm	03.10 pm		239	Switch Board not working	MJPJAY ward	08.09.2021	09.25 am	
23	08.09.2021	11.30 am	12.15 pm		464	LED Tubelight not working	OT Complex	08.09.2021	12.15 pm	
24	08.09.2021	11.35 am	12.10 pm		2091	FCU Not working	PICU	09.09.2021	11.40 am	
25	09.09.2021	09.20 am	10.15 am		2093	FCU Not working	PICU	09.09.2021	11.40 am	
26	09.09.2021	01.00 pm	02.40 pm		2714	Switch Board not working	New Deluxe	09.09.2021	03.30 pm	
27	09.09.2021	02.00 pm	02.40 pm		2273	LED Tubelight & Cilling fan not working	Nephrology ward	09.09.2021	04.15 pm	
28	09.09.2021	10.39 am	10.55 am		2093	FCU Not working	PICU	09.09.2021	11.35 am	
29	09.09.2021	10.26 am	10.40 am		2195	Lift Not working	OPD	09.09.2021	11.55 am	
30	11.09.2021	11.38 am	12.10 pm		2266	LED Light not Working	Psy ward	11.09.2021	11.40 am	
31	11.09.2021	09.05 am	09.15 am		2415 & 2416	AHU not working	Reserch lab	11.09.2021	03.20 pm	
32	12.09.2021	09.30 am	09.55 am		Oral	FCU Cleaning work	OT Complex	12.09.2021	04.15 pm	

						Pending work				
1	24.07.2021	01.45 pm	02.00 pm	00.15 Hr	1688	Table fan not working	CVTS	06.09.2021	10.40 am	
2	16.08.2021	11.15 am	12.05 pm		4261	VRV Casset unit-01 not working	Dyotan Hall	09.09.2021	02.45 pm	
3	25.08.2021	02.17 pm	02.55 pm		1890	Water cooler not working	Old Deluxe	06.09.2021	11.35 am	
4	26.08.2021	11.15 am	12.55 pm		2243	Switch Board not working	STP/ETP			Work in progress
5	30.08.2021	12.45 pm	02.45 pm		1163	Refregator not working	Super Deluxe	13.09.2021	04.00 pm	
6	31.08.2021	12.39 pm	04.35 pm		463	Split AC not working	MICU	10.09.2021	10.40 am	

Total Complaint	38
Pending Complaint	1
Complete Complaint	37
Complaint Precentrage	97%

M.V.Gaikwad
MGM Aurangabad

Electrical Engineer
MGM Aurangabad

Electrical Supervisor
MGM Aurangabad

MGM MEDICAL COLLEGE & HOSPITA
ELECTRICAL MAINTANCE REPORT 13/09/2021 to 19/09/2021

Sr.No.	Received Date	Time	Attende Time	Response Time	Cpmplaint No.	Nature Of Complent	Name Of Department	Date Of Complation	Close Time	Remark
1	13.09.2021	09.30 am	09.45 am		444	LED Tubelight not working	Ortho OPD	13.09.2021	10.55 am	
2	13.09.2021	02.45 pm	03.35 pm		2873	Tharmameter not working	Pead.ward	18.09.2021	12.00 pm	
3	13.09.2021	11.15 am	11.35 am		1674	Switch Board not working	Blood bank	13.09.2021	11.40 am	
4	14.09.2021	10.20 am	10.55 am		471	LED Light not Working	OT Complex	14.09.2021	11.10 am	
5	14.09.2021	12.40 pm	02.20 pm		774	LED Tubelight not working	Microbiology	17.09.2021	03.05 pm	
6	14.09.2021	12.05 pm	12.40 pm		2269	LED Tubelight not working	Psy.ward.	14.09.2021	03.10 pm	
7	14.09.2021	12.05 pm	12.45 pm		2268	Standing Fan not Working	Psy.ward.			Work in Progress
8	14.09.2021	03.23 pm	04.20 pm		3275	LED Bulb not working	Ex.Deluxe	18.09.2021	10.40 am	
9	14.09.2021	12.10 pm	12.20 pm		874	LED Tubelight not working	MCRI OPD-18	14.09.2021	12.55 pm	
10	15.09.2021	10.30 am	10.45 am		1163	LED Bulb not working	Labour Room	15.09.2021	11.00 am	
11	15.09.2021	08.45 am	08.55 am		1162	Switch Board not working	Labour Room	15.09.2021	08.55 am	
12	15.09.2021	12.47 pm	02.47 pm		2607	Water cooler not working	Old Deluxe	17.09.2021	12.30 pm	
13	15.09.2021	10.45 am	11.35 am		1184	FCU Not working	Super Deluxe	15.09.2021	12.55 pm	
14	15.09.2021	12.00 pm	12.35 pm		3988	Switch Board not working	Hemotology ICU	15.09.2021	12.55 pm	
15	15.09.2021	11.50 am	12.45 am		2137	LED Tubelight not working	Dean Office	15.09.2021	03.20 pm	
16	16.09.2021	10.15 am	10.20 am		392	LED Tubelight not working	OBGY Dept.	16.04.2021	10.20 am	
17	16.09.2021	11.40 am	12.05 pm		1338	Cilling Fan not working	MSW	16.09.2021	12.50 pm	
18	16.09.2021	03.15 pm	04.15 pm		2608	LED Light not Working	Old Deluxe	17.09.2021	11.30 am	
19	16.09.2021	11.25 am	12.35 pm		1667	Cilling Fan not working	Casulty	18.09.2021	04.20 pm	
20	16.09.2021	11.40 am	12.20 pm		1339	LED Tubelight not working	MSW	16.09.2021	12.50 pm	
21	16.09.2021	11.45 am	12.00 pm		475	LED Tubelight not working	OT Complex	16.09.2021	12.35 pm	
22	17.09.2021	10.00 am	11.15 am		2273	Wall fan fitting	Psy.ward.	18.09.2021	02.10 pm	
23	17.09.2021	11.36 am	12.20 pm		777	Switch Board not working	Microbiology	17.09.2021	03.00 pm	
24	17.09.2021	10.21 am	11.35 am		3278	LED Light not Working	Ex.Deluxe	18.09.2021	11.20 am	
25	18.09.2021	09.21 am	09.35 am		2609	Gizer not working	Old Deluxe	18.09.2021	09.45 am	
26	18.09.2021	10.51 am	11.00 am		270	VGA Cable laying	Nephrology ward	18.09.2021	11.30 am	
27	18.09.2021	12.40 pm	03.15 pm		1234	LED Bulb not working	Emergncy Medicine	18.09.2021	04.34 pm	
28	18.09.2021	11.00 am	12.35 pm		3167	LED Tubelight not working	Covid-19	18.09.2021	03.35 p	
29	18.09.2021	02.35 pm	02.55 pm		2277	LED Tubelight not working	Nephrology ward	18.09.2021	03.20 pm	
30	18.09.2021	03.00 pm	03.30 pm		1401	Electrical Wiring work	Covid-19	18.09.2021	03.30 pm	
31	18.09.2021	10.35 am	10.40 am		4265	Earthing & LED Light not Working	IT Department	18.09.2021	04.00 pm	
32	18.09.2021	03.50 pm	04.15 pm		2097	FCU Not working	PICU	18.09.2021	04.55 pm	
	Pending work									
1	26.08.2021	11.15 am	12.55 pm		2243	Switch Board not working	STP/ETP	18.09.2021	04.00 pm	

Total Complaint	33
Pending Complaint	1
Complete Complaint	32
Complaint Precentrage	97%

M.V.Gaikwad
MGM Aurangabad

Electrical Engineer
MGM Aurangabad

Electrical Supervisor
MGM Aurangabad

MGM MEDICAL COLLEGE & HOSPITAL

ELECTRICAL MAINTANCE REPORT 20/09/2021 to 26/09/2021 (26-09-2021)

Sr.No.	Received Date	Time	Attende Time	Response Time	Cpmplaint No.	Nature Of Complent	Name Of Department	Date Of Complation	Close Time	Remark
1	20.09.2021	12.00 pm	12.45 pm		3169	Refregator not working	ENT	21.09.2021	02.30 pm	
2	20.09.2021	03.15 pm	03.30 pm		1342	Cilling Fan not working	MSW	20.09.2021	03.30 pm	
3	20.09.2021	10.23 am	11.15 am		3030	LED Tubelight & Switch Board not working,	M.Med.ward	24.09.2021	03.15 pm	
4	20.09.2021	03.15 pm	03.30 pm		1340	Switch Board not working	MSW	20.09.2021	04.20 pm	
5	21.09.2021	11.07 am	11.45 am		644	Earthing Light not Working	Pathology Department	21.09.2021	12.30 pm	
6	21.09.2021	09.30 am	09.45 am		1666	FCU Not working	Casulty	21.09.2021	09.45 am	
7	21.09.2021	12.20 pm	02.00 pm		297	Cilling Fan not working	PSM Dept.	21.09.2021	02.15 pm	
8	21.09.2021	04.16 pm	05.00 pm		1675	LED 15watt not working	Blood bank	23.09.2021	11.15 am	
9	21.09.2021	10.55 am	11.15 am		2878	Refregator not working	Pead.ward			Work in progress
10	21.09.2021	09.55 am	11.15 am		2199	Motor not working	6th Floor	22.09.2021	04.30 pm	
11	21.09.2021	01.11 pm	02.10 pm		2612	Gizer not working	Old Deluxe	23.09.2021	10.45 am	
12	21.09.2021	10.15 am	10.55 am		1480	VRV Casset unit-01 not working	OBGY ICU	22.09.2021	03.15 pm	
13	21.09.2021	12.04 pm	12.35 pm		2877	Cilling Fan not working	Old Peadiatric ward	21.09.2021	01.40 pm	
14	22.09.2021	10.45 am	11.05 am		2511	LED Tubelight not working	Record Section	22.09.2021	11.50 am	
15	22.09.2021	12.30 pm	02.40 pm		247	LED Bulb not working	MJPJAY ward	22.09.2021	04.00 pm	
16	22.09.2021	10.27 am	12.15 pm		3996	Extention Board not working	Hematology	23.09.2021	02.40 pm	
17	22.09.2021	02.10 pm	04.15 pm		1909	LED Tubelight not working	Time Office	23.09.2021	12.30 pm	
18	22.09.2021	09.34 am	12.50 pm		1186	LED 12watt not workkkking	Super Deluxe	22.09.2021	04.10 pm	
19	23.09.2021	12.00 pm	02.45 pm		59	Call Bell not working	Central Laibrary	23.09.2021	03.40 pm	
20	23.09.2021	09.59 pm	10.15 am		1481	Switch Board not working	OICU	24.09.2021	10.55 am	
21	23.09.2021	06.20 pm	07.30 pm		58	OPD Lift not working	Central Laibrary	21.09.2021	07.30 pm	
22	23.09.2021	09.30 am	09.45 am		605	Lift No-06 Not working	Time Office	24.09.2021	12.30 pm	
23	23.09.2021	11.05 am	12.20 pm		722	Electrical problame	OBGY Ward-II	23.09.2021	03.25 pm	
24	24.09.2021	10.50 am	11.15 am		1731	LED Light not Working	SICU	24.09.2021	12.55 pm	
25	24.09.2021	03.00 pm	03.15 pm		1278	Electrical problame	OBGY Ward-I	24.09.2021	03.24 pm	
26	24.09.2021	10.15 am	03.00 pm		491	LED Tubelight not working	OT Complex	25.09.2021	03.17 pm	
27	24.09.2021	10.50 am	11.15 am		618	Split AC not working	NICU			Work in progress
28	24.09.2021	04.30 pm	04.55 pm		1642	Exhouast Fan not working	CCU+CVTS	25.09.2021	04.10 pm	
29	24.09.2021	12.20 pm	03.20 pm		291	LED Tubelight & Cilling fan not working	Psiology Dept.	24.09.2021	04.10 pm	
30	24.09.2021	11.26 am	04.30 pm		1277	Gizer not working	OBGY Ward-I	24.09.2021	04.45 pm	
31	24.09.2021	11.24 am	11.35 am		2618	Gizer not working	Old Deluxe	25.09.2021	11.29 am	
32	25.09.2021	10.20 am	10.20 am		1192	Tharmameter not working	Super Deluxe	25.09.2021	11.05 am	
33	25.09.2021	03.45 pm	04.00 pm		609	Lift not working	Time Office	25.09.2021	04.15 pm	
34	25.09.2021	10.58 am	12.25 pm		1194	Cilling Fan not working	Super Deluxe	25.09.2021	12.35 pm	
35	25.09.2021	09.30 am	10.30 am		606	Lift No-06 Not working	Time Office	25.09.2021	02.00 pm	

36	25.09.2021	10.41 am	11.11 am		1279	LED Tubelight not working	OBGY W[illegible]-I	25.09.2021	03.40 pm	
37	26.09.2021	01.00 pm	01.15 pm		[illegible]	Switch Board not working	MSW	26.09.2021	01.15 pm	
38	25.09.2021	12.55 pm	02.15 pm		3615					
						Pending work				
1	14.09.2021	12.05 pm	12.45 pm		2268	Standing Fan not Working	Psy.ward.	20.09.2021	02.50 pm	

Total Complaint	39
Pending Complaint	2
Complete Complaint	37
Complaint Precentrage	95%

M.V.Gaikwad
MGM Aurangabad

Electrical Engineer
MGM Aurangabad

Electrical Supervisor
MGM Aurangabad

MGM MEDICAL COLLEGE & HOSPITAL

ELECTRICAL MAINTANCE REPORT 27/09/2021 to ~~10/2021~~ 03.10.2021

Sr.No.	Received Date	Time	Attende Time	Response Time	Cpmplaint No.	Nature Of Complent	Name Of Department	Date Of Complation	Close Time	Remark
1	27.09.2021	09.50 am	09.55 am		2309	Cilling Fan not working	Medical Store	27.09.2021	10.15 am	
2	27.09.2021	10.00 am	10.20 am		2132	LED Tubelight not working	Registition Department	27.09.2021	10.31 am	
3	27.09.2021	11.28 am	11.28 am		885	Switch Board not working	MCRI OPD	27.09.2021	11.30 am	
4	27.09.2021	10.30 am	12.40 pm		1345	Switch Board not working	MSW	27.09.2021	03.00 pm	
5	27.09.2021	10.40 am	11.00 am		1196	Switch Board not working	Super Deluxe	27.09.2021	03.45 pm	
6	27.09.2021	12.25 pm	01.45 pm		1733	Switch Board not working	SICU	27.09.2021	02.10 pm	
7	27.09.2021	12.30 pm	02.45 pm		2278	Switch Board not working	Psy.ward.	27.09.2021	04.35 pm	
8	28.09.2021	09.20 am	10.15 am		1406	Call Bell not working	Central library	28.09.2021	10.55 am	
9	28.09.2021	03.00 pm	03.30 pm		887	Cat-06 Cable laying	MCRI OPD-10	29.09.2021	03.45 pm	
10	28.09.2021	03.30 pm	04.10 pm		724	Exhouast Fan not working	OBGY II			Work in progress
11	28.09.2021	12.20 pm	12.55 pm		306	LED 15watt not working	Super Deluxe	02.10.2021	09.45 am	
12	28.09.2021	10.25 am	10.35 am		3998	Switch Board not working	Hematology	04.10.2021	10.45 am	
13	28.09.2021	11.36 am	12.26 pm		1412	Switch Board not working	Covid OPD	01.10.2021	03.45 pm	
14	29.09.2021	03.13 pm	03.20 pm		615	Lift No-06 Not working	Time Office	29.09.2021	05.10 pm	
15	29.09.2021	10.50 am	11.10 am		2278	Exhouast Fan & Cilling Fan not worki	Nephrology ward	29.09.2021	11.45 am	
16	28.09.2021	11.20 am	12.10 pm		1735	AHU Filter cleaning	SICU	29.09.2021	02.00 pm	
17	29.09.2021	04.29 pm	04.40 pm		3175	Switch Board not working	Hemotolgy Dept.	29.09.2021	04.55 pm	
18	29.09.2021	05.00 pm	05.15 pm		617	Refregator not working	Time Office	29.09.2021	05.30 pm	
19	30.09.2021	11.55 am	12.20 pm		477	Switch Board not working	MICU	30.09.2021	01.00 pm	
20	30.09.2021	02.46 pm	02.55 pm		2882	Refregator not working	Pead.ward	02.10 2021	02.40 pm	
21	30.09.2021	10.05 am	11.15 am		2249	LED Tubelight not working	STP/ETP	02.10.2021	12.15 pm	
22	30.09.2021	12.00 pm	12.40 pm		1686	Electrical problame	Casulty	30.09.2021	01.00 pm	
23	01.10.2021	11.54 am	12.35 pm		1703	LED 15watt not working	Dyotan Hall			Work in progress
24	01.10.2021	09.50 am	10.00 am		620	Lift No-05 not working	Time Office	01.10 2021	11.15 am	
25	01.10.2021	11.35 am	12.20 pm		1377	Switch Board not working	Dialysis	01.10.2021	02.30 pm	
26	01.10.2021	11.00 am	11.25 am		2726	Call Bell not working	New Deluxe			Work in progress
	Pending work									
	24.09.2021	10.50 am	11.15 am		618	Split AC not working	NICU	28.09.2021	02.40 pm	

Total Complaint	27
Pending Complaint	3
Complete Complaint	24
Complaint Precentrage	89%

M.V.Gaikwad
MGM Aurangabad

Electrical Engineer
MGM Aurangabad

Electrical Supervisor
MGM Aurangabad

MGM MEDICAL COLLEGE & HOSPITAL

ELECTRICAL MAINTANCE REPORT 04/10/2021 to 10/~~10~~/2021 10-10-2021

Sr.No.	Received Date	Time	Attende Time	Response Time	Cpmplaint No.	Nature Of Complent	Name Of Department	Date Of Complation	Close Time	Remark
1	04.10.2021	09.30 am	09.55 am		2546	LED Tubelight not working	CSSD	04.10.2021	11.15 am	
2	04.10.2021	10.00 am	11.35 am		1677	Switch Board not working	Blood bank	04.10.2021	03.00 pm	
3	04.10.2021	11.30 am	11.45 am		1488	VRV Casset unit-01 not working	OBGY ICU	04.10.2021	04.30 pm	
4	04.10.2021	12.00 pm	12.35 pm		1736	AC Vent not working	SICU	04.10.2021	02.45 pm	
5	04.10.2021	10.00 am	10.15 am		1676	DipFreez not working	Blood bank			Work in progress
6	04.10.2021	02.20 pm	03.05 pm		3403	LED Tubelight not working	OT Complex	04.10.2021	03.15 pm	
7	04.10.2021	09.35 am	10.55 am		1346	Cilling Fan not working	MSW	04.10.2021	03.50 pm	
8	04.10.2021	10.25 am	11.30 am		4057	LED Tubelight not working	OBGY OPD	04.10.2021	12.55 pm	
9	05.10.2021	11.00 am	11.30 am		622	Switch Board not working	NICU	05.10.2021	11.45 am	
10	05.10.2021	02.18 pm	02.45 pm		1738	LED 15watt not working	SICU	07.10.2021	03.35 pm	
11	05.10.2021	10.00 am	10.20 am		2100	Extention Board not working	PICU	05.10.2021	04.00 pm	
12	05.10.2021	10.50 am	11.00 am		1414	Cilling Fan not working	Covid-19	07.10.2021	12.40 pm	
13	05.10.2021	03.15 pm	03.55 pm		197	LED Tubelight not working	F.Ortho ward	05.10.2021	04.25 pm	
14	05.10.2021	02.18 pm	03.00 pm		3176	Switch Board not working	Hematology	05.10.2021	03.15 pm	
15	05.10.2021	09.20 am	09.45 am		3175	Switch Board not working	Hematology ICU	05.10.2021	11.35 am	
16	06.10.2021	10.10 am	10.50 am		250	Cilling Fan not working	MJPJAY ward	06.10.2021	01.00 pm	
17	06.10.2021	10.40 am	11.55 pm		1415	LED Tubelight not working	Covid-19	07.10.2021	01.00 pm	
18	06.10.2021	09.45 am	10.20 am		2703	Tharmameter not working	Old Deluxe			Work in progress
19	06.10.2021	09.45 am	09.55 am		2702	Cilling Fan not working	Old Deluxe	06.10.2021	01.10 pm	
20	06.10.2021	10.20 am	11.10 am		1736	Air cartain not working	SICU	09.10.2021	03.55 pm	
21	06.10.2021	02.30 pm	03.00 pm		3408	LED Tubelight not working	OT Complex	06.10.2021	03.45 pm	
22	06.10.2021	10.40 am	11.00 am		3406	LED Tubelight not working	OT Complex	06.10.2021	03.45 pm	
23	07.10.2021	10.00 am	10.15 am		898	Electrical Checkup	MCRI OPD	07.10.2021	11.05 am	
24	07.10.2021	12.15 pm	12.55 pm		2631	Gizer not working	Old Deluxe	07.10.2021	12.55 pm	
25	07.10.2021	02.50 pm	03.15 pm		3289	LED 15watt not working	MCRI ICU	07.10.2021	03.45 pm	
26	07.10.2021	01.50 pm	02.15 pm		104	LED Tubelight not working	PICU	09.10.2021	03.15 pm	
27	07.10.2021	02.50 pm	03.00 pm		623	Switch Board not working	Dean Office	07.10.2021	03.00 pm	
28	07.10.2021	10.00 am	12.15 pm		1348	Cilling Fan not working	MSW	07.10.2021	02.15 pm	
29	07.10.2021	05.50 pm	05.55 pm		663	Electrical problame	CATH-LAB	07.10.2021	07.00 pm	
30	07.10.2021	04.30 pm	04.45 pm		298	LED Tubelight not working	PSM Dept.	08.10.2021	10.45 am	
31	08.10.2021	09.20 am	09.55 am		318	Switch Board not working	Super Deluxe	08.10.2021	10.10 am	
32	08.10.2021	10.58 am	11.15 am		664	Split AC not working	CATH-LAB	08.10.2021	12.15 pm	
33	08.10.2021	11.00 am	11.55 am		25	X-Ray Box not working	Endoscophy	08.10.2021	01.37 pm	
34	08.10.2021	04.24 pm	04.35 pm		626	2TR Split AC not working	Time Office	09.10.2021	10.45 pm	
35	08.10.2021	10.28 am	11.00 am		1417	LED 15watt not working	Covid OPD	08.10.2021	03.15 pm	
36	08.10.2021	01.30 pm	02.40 pm		3288	Switch Board not working	Ex.Deluxe	08.10.2021	02.50 pm	
37	08.10.2021	12.30 pm	12.55 pm		670	Cilling Fan not working	NICU	08.10.2021	01.50 pm	
38	09.10.2021	11.10 am	11.55 am		3412	LED 15watt not working	OT Complex	09.10.2021	11.00 am	

39	09.10.2021	02.35 pm	02.55 pm		2731	LED 15watt not working	New Deluxe	09.10.2021	04.05 pm	
40	09.10.2021	04.45 pm	05.00 pm		628	Cilling Fan not working	Skin VD	09.10.2021	05.15 pm	
	Pending work									
1	28.09.2021	03.30 pm	04.10 pm		724	Exhouast Fan not working	OBGY II			Work in progress
2	01.10.2021	11.54 am	12.35 pm		1703	LED 15watt not working	Dyotan Hall			Work in progress
3	01.10.2021	11.00 am	11.25 am		2726	Call Bell not working	New Deluxe			Work in progress
4	03.10.2021	11.20 am	11.35 am		1735	AHU Filter cleaning	SICU	04.10.2021	02.00 pm	

Total Complaint	44
Pending Complaint	5
Complete Complaint	39
Complaint Precentrage	89%

M.V.Gaikwad
MGM Aurangabad

Electrical Engineer
MGM Aurangabad

Electrical Supervisor
MGM Aurangabad

MGM MEDICAL COLLEGE & HOSPITAL

ELECTRICAL MAINTANCE REPORT 11/10/2021 to ~~10/2021~~ 17.10.2021

Sr.No.	Received Date	Time	Attende Time	Response Time	Cpmplaint No.	Nature Of Complent	Name Of Department	Date Of Complation	Close Time	Remark
1	11.10.2021	11.00 am	11.20 am		2104	Switch Board not working	Hematology ICU	11.10.2021	11.45 am	
2	11.10.2021	04.10 pm	04.45 pm		1349	Cilling Fan not working	MSW	11.10.2021	05.00 pm	
3	11.10.2021	12.30 pm	12.45 pm		1745	Cat-06 Cable laying	C' Building	15.10.2021	04.00 pm	
4	11.10.2021	02.54 pm	03.15 pm		2006	LED Tubelight & Cilling fan requirem	Community Med.	11.10.2021	05.00 pm	
5	11.10.2021	11.23 am	12.00 pm		1745	Switch Board not working	SICU	11.10.2021	12.15 pm	
6	11.10.2021	12.30 pm	12.40 pm		331	Switch Board not working	Radiology Dept	12.10.2021	12.05 pm	
7	12.10.2021	12.30 pm	12.30 pm		2106	Switch Board not working	Hematology ICU	12.10.2021	12.55 pm	
8	12.10.2021	11.18 am	12.20 pm		2735	Switch Board not working	New Deluxe	16.10.2021	01.45 pm	
9	12.10.2021	12.55 pm	02.40 pm		3636	LED Light not Working	Cardac OT			Work in progress
10	12.10.2021	11.15 am	12.00 pm		17	Telephone cable laying work.	Gate No-01	12.10.2021	04.20 pm	
11	12.10.2021	09.00 am	09.30 am		Letter	Switch Board not working	Dean Office	12.10.2021	04..00 pm	
12	13.10.2021	12.06 pm	12.26 pm		1668	Extention Board not working	Surgery OPD	13.10.2021	12.40 pm	
13	13.10.2021	12.06 pm	12.26 pm		1667	LED Tubelight not working	Surgery OPD	13.10.2021	12.45 pm	
14	13.10.2021	03.20 pm	03.55 pm		336	LED Light not Working	Radiology Dept	16.10.2021	04.30 pm	
15	13.10.2021	03.47 pm	04.10 pm		3041	Cilling Fan not working	MMW	16.10.2021	05.10 pm	
16	13.10.2021	02.30 pm	02.55 pm		835	Cilling Fan not working	Radiology Dept	13.10.2021	03.15 pm	
17	13.10.2021	10.04 am	10.35 am		2002	Switch Board not working	MCRI OPD	14.10.2021	12.30 pm	
18	14.10.2021	03.31 pm	03.45 pm		2637	Switch Board not working	Old Deluxe	16.10.2021	12.55 pm	
19	15.10.2021	09.55 am	10.45 am		2006	LED 15watt not working	MCRI OPD	15.10.2021	12.15 pm	
20	15.10.2021	12.30 pm	02.10 pm		631	Lift No-06 Not working	Time Office	15.10.2021	04.36 pm	
21	15.10.2021	08.24 am	09.15 am		633	Lift No-06 Not working	Time Office	15.10.2021	04.30 pm	
22	16.10.2021	12.30 pm	12.45 pm		1006	Electrical problame	Medicin Dept.	16.10.2021	12.45 pm	
23	16.10.2021	09.20 am	09.40 am		329	Cilling Fan not working	Scool of Bio.Scince	16.10.2021	12.10 pm	
24	16.10.2021	12.35 pm	12.55 pm		791	Split AC not working	Microbiology	18.10.2021	12.10 pm	
25	16.10.2021	11.06 am	11.45 am		177	X-Ray Box not working	F.Ortho ward	17.10.2021	05.10 pm	
26	16.10.2021	10.35 am	11.05 am		1952	LED Tubelight not working	Pharm.Lecture Hall	18.10.2021	04.05 pm	
27	17.10.2021	07.50 am	09.05 am		635	Lift No-06 Not working	Time Office	17.10.2021	10.45 am	
	Pending work									
1	28.09.2021	03.30 pm	04.10 pm		724	Exhouast Fan not working	OBGY II	13.10.2021	02.40 pm	
2	01.10.2021	11.54 am	12.35 pm		1703	LED 15watt not working	Dyotan Hall			Work in progress
3	01.10.2021	11.00 am	11.25 am		2726	Call Bell not working	New Deluxe			Work in progress
4	04.10.2021	10.00 am	10.15 am		1676	DipFreez not working	Blood bank			Work in progress
5	06.10.2021	09.45 am	10.20 am		2703	Tharmameter not working	Old Deluxe	16.10.2021	04.00 pm	
6	10.10.2021	02.50 pm	02.50 pm		3306	LED Tubelight Requirement	PSM Dept.	12.10.2021	03.05 pm	

Total Complaint	[illegible]
Pending Complaint	4
Complete Complaint	29
Complaint Precentrage	88%

M.V.Gaikwad
MGM Aurangabad

Electrical Engineer
MGM Aurangabad

Electrical Supervisor
MGM Aurangabad

MGM MEDICAL COLLEGE & HOSPITAL

ELECTRICAL MAINTANCE REPORT 18/10/2021 to 24.10.2021

Sr.No.	Received Date	Time	Attende Time	Response Time	Cpmplaint No.	Nature Of Complent	Name Of Department	Date Of Complation	Close Time	Remark
1	18.10.2021	09.50 am	09.50 am		516	Wall fan fitting	Dental OPD	18.10.2021	11.06 am	
2	18.10.2021	09.30 am	09.45 am		851	Extention Board not working	Hematology ICU	19.10.2021	12.45 pm	
3	18.10.2021	09.40 am	09.55 am		253	Electrical problame	MJPJAY ward	18.10.2021	12.10 pm	
4	18.10.2021	11.15 am	12.20 pm		1028	LED Tubelight not working	MICU	18.10.2021	03.15 pm	
5	18.10.2021	04.15 pm	04.45 pm		1684	LED 15watt not working	Blood bank	19.10.2021	02.00 pm	
6	18.10.2021	12.00 pm	12.35 pm		2304	LED Tubelight & Cilling fan Requirer	PSM Dept.	23.10.2021	03.40 pm	
7	18.10.2021	12.17 pm	12.45 pm		904	Wall Fan not Working	Central Lab.	18.10.2021	02.15 pm	
8	18.10.2021	11.19 am	12.10 pm		298	LED Tubelight not working	PSM Dept.	18.10.2021	12.25 pm	
9	18.10.2021	01.10 pm	02.45 pm		886	LED Tubelight not working	Anatomy	18.10.2021	03.35 pm	
10	18.10.2021	12.54 pm	03.35 pm		3432	Switch Board not working	OT Complex	18.10.2021	04.30 pm	
11	18.10.2021	01.00 pm	03.15 pm		3429	LED Tubelight not working	OT Complex	18.10.2021	03.30 pm	
12	18.10.2021	12.55 pm	04.36 pm		3424	LED 15watt not working	OT Complex	18.10.2021	05.00 pm	
13	19.10.2021	12.39 pm	01.35 pm		1236	LED Tubelight not working	MET Cell	19.10.2021	01.40 pm	
14	19.10.2021	10.58 am	11.05 am		2015	Switch Board not working	MJPJAY ward	19.10.2021	04.45 pm	
15	19.10.2021	03.19 pm	03.40 pm		1148	LED 15watt not working	5th floor deluxe	21.10.2021	04.35 pm	
16	19.10.2021	02.00 pm	02.15 pm		895	Projector Point requirement	Anatomy	19.10.2021	03.37 pm	
17	19.10.2021	04.31 pm	04.31 pm		1955	Projector Point requirement	Pharm.Lecture Hall	19.10.2021	05.28 pm	
18	19.10.2021	04.38 pm	04.55 pm		278	Electrical problame	Physiotherapy	19.10.2021	04.55 pm	
19	20.10.2021	10.00 am	10.05 am		3328	Electrical problame	Dermatology	20.10.2021	10.20 am	
20	20.10.2021	11.34 am	02.40 pm		2549	Switch Board not working	CSSD	20.10.2021	03.10 pm	
21	20.10.2021	11.46 am	02.30 pm		3438	LED Tubelight not working	OT Complex	20.10.2021	04.31 pm	
22	20.10.2021	10.09 am	11.00 am		2890	Cilling Fan not working	Pead.ward	21.10.2021	11.35 am	
23	20.10.2021	10.42 am	03.00 pm		2110	LED 15watt not working	Hematology ICU	22.10.2021	03.44 pm	
24	21.10.2021	11.10 am	11.55 am		2016	Wind Blower not working	MJPJAY ward	22.10.2021	01..00 pm	
25	21.10.2021	11.27 am	12.10 pm		2639	LED Tubelight not working	Cardac OT	22.10.2021	04.30 pm	
26	21.10.2021	11.58 am	02.45 pm		638	Lift No-05 not working	Time Office	21.10.2021	02.45 pm	
27	22.10.2021	12.05 pm	12.05 pm		251	LED Tubelight not working	SS OPD	22.10.2021	12.15 pm	
28	22.10.2021	03.05 pm	03.45 pm		2738	Tharmameter not working	New Deluxe	25.10.2021	04.45 pm	
29	22.10.2021	03.35 pm	04.00 pm		19	Dipawal Lamp not working	Hospital Build.	25.10.2021	11.00 pm	
30	22.10.2021	12.05 pm	12.15 pm		1353	Switch Board not working	MSW	22.10.2021	12.45 pm	
31	22.10.2021	12.45 pm	12.55 pm		334	Switch Board not working	Super Deluxe	22.10.2021	01.15 pm	
32	22.10.2021	12.45 pm	02.40 pm		255	Exhouast Fan not working	MJPJAY ward	24.10.2021	10.00 am	
33	23.10.2021	10.45 am	11.00 am		1111	LED Bulb not working	M.Ortho ward	24.10.2021	10.39 am	
34	24.10.2021	02.40 pm	03.10 pm		1601	Switch Board not working	Ex.Deluxe	25.10.2021	04.45 pm	
	Pending work									
1	01.10.2021	11.54 am	12.35 pm		1703	LED 15watt not working	Dyotan Hall	19.10.2021	02.30 pm	
2	01.10.2021	11.00 am	11.25 am		2726	Call Bell not working	New Deluxe			Work in progress

3	04.10.2021	10.00 am	10.15 am		1676	DipFreez not working	Blood bank			Work in progress
4	12.10.2021	12.55 pm	02.40 pm		363	LED Light not Working	Cardac OT		25.10.2021	03.55 pm

Total Complaint	38
Pending Complaint	2
Complete Complaint	36
Complaint Precentrage	95%

M.V.Gaikwad
MGM Aurangabad

Electrical Engineer
MGM Aurangabad

Electrical Supervisor
MGM Aurangabad

MGM MEDICAL COLLEGE & HOSPITAL

ELECTRICAL MAINTANCE REPORT 24/10/2021 to 31/10/2021 ~~31/10/2021~~

Sr.No.	Received Date	Time	Attende Time	Response Time	Cpmplaint No.	Nature Of Complent	Name Of Department	Date Of Complation	Close Time	Remark
1	25.10.2021	09.35 am	10.20 am		1114	LED Tubelight not working	M.Ortho ward	25.10.2021	11.45 am	
2	25.10.2021	09.45 am	10.10 am		643	Tharmameter not working	NICU	25.10.2021	12.35 pm	
3	25.10.2021	02.57 pm	03.55 pm		1268	LED Tubelight not working	Biochemistry Dept.	28.10.2021	02.00 pm	
4	25.10.2021	10.35 am	11.55 pm		3043	Switch Board not working	MMW	25.10.2021	03.15 pm	
5	25.10.2021	02.55 pm	03.25 pm		1506	LED Tubelight not working	Casulty	26.10.2021	11.55 am	
6	25.10.2021	02.55 pm	03.15 pm		1507	LED Tubelight not working	Casulty	26.10.2021	10.55 am	
7	26.10.2021	10.20 am	11.50 am		2013	UPS Battery change	MCRI OPD	26.10.2021	11.50 am	
8	26.10.2021	02.00 pm	02.20 pm		3444	LED Tubelight not working	OT Complex	26.10.2021	03.30 pm	
9	26.10.2021	02.00 pm	02.20 pm		3447	LED Tubelight not working	OT Complex	26.10.2021	03.30 pm	
10	26.10.2021	11.50 am	12.55 pm		2290	LED Tubelight not working	Pead.ward	27.10.2021	11.50 am	
11	26.10.2021	03.18 pm	03.21 pm		3445	Switch Board not working	OT Complex	26.10.2021	03.30 pm	
12	26.10.2021	10.20 am	10.45 am		Letter	LED Tubelight not working	Parking Side	27.10.2021	03.00 pm	
13	26.10.2021	03.35 pm	03.55 pm		19	Aakash Kandil Instalation	Hospital Build.	02.11.2021	11.55 am	
14	26.10.2021	11.30 am	11.55 am		1420	Switch Board not working	Covid OPD	26.11.2021	12.30 pm	
15	27.10.2021	02.30 pm	02.45 pm		1914	Exhouast Fan not working	House kiping Dept.	30.10.2021	11.10 am	
16	28.10.2021	10.30 am	10.50 am		1654	X-Ray Box not working	CCU+CVTS	28.10.2021	11.15 am	
17	28.10.2021	11.05 am	11.55 am		1656	X-Ray Box not working	CCU+CVTS	01.11.2021	11.00 am	
18	28.10.2021	11.05 am	12.10 pm		1657	LED Tubelight not working	CCU+CVTS	01.11.2021	11.11 am	
19	28.10.2021	09.45 am	11.05 am		340	Switch Board not working	Super Deluxe	28.10.2021	12.10 pm	
20	28.10.2021	10.15 am	11.00 am		2512	LED Tubelight not working	Record Section	28.10.2021	11.45 am	
21	28.10.2021	04.04 pm	04.20 pm		2648	LED 18watt Panel	Old Deluxe	28.10.2021	04.35 pm	
22	29.10.2021	03.10 pm	04.20 pm		1577	Cilling Fan not working	Medicin OPD	29.10.2021	04.50 pm	
23	29.10.2021	02.38 pm	03.15 pm		3118	Cilling Fan not working	Hematology ICU	01.11.2021	03.15 pm	
24	30.10.2021	12.45 pm	12.55 pm		2898	LED Tubelight not working	Pead.ward	30.10.2021	03.20 pm	
	Pending work									
1	01.10.2021	11.00 am	11.25 am		2726	Call Bell not working	New Deluxe	27.10.2021	10.55 am	
2	04.10.2021	10.00 am	10.15 am		1676	DipFreez not working	Blood bank			Work in progress

Total Complaint	26
Pending Complaint	1
Complete Complaint	25
Complaint Precentrage	96%

M.V.Gaikwad
MGM Aurangabad

Electrical Engineer
MGM Aurangabad

Electrical Supervisor
MGM Aurangabad

MGM MEDICAL COLLEGE & HOSPITAL

ELECTRICAL MAINTANCE REPORT 01/11/2021 to ~~1/2021~~ 07.11.2021

Sr.No.	Received Date	Time	Attende Time	Response Time	Cpmplaint No.	Nature Of Complent	Name Of Department	Date Of Complation	Close Time	Remark
1	01.11 2021	10.49 am	11.15 am		2021	Switch Board not working	MJPJAY ward	01.11.2021	12.00 pm	
2	01.11.2021	09.30 am	10.00 am		1354	Electrical problame	MSW	06.11.2021	11.25 am	
3	01.11.2021	05.20 pm	05.35 pm		7652	Exhouast Fan not working	MCRI Canteen	04.11.2021	10.00 am	
4	01.11.2021	11.15 am	11.55 am		1916	Gizer not working	Time Office			Work in progress
5	01.11.2021	03.10 pm	04.15 pm		1658	LED 15watt not working	CCU+CVTS	03.11.2021	11.35 am	
6	02.11.2021	11.10 am	11.55 am		1296	LED 15watt not working	OBGY Ward	02.11.2021	03.10 pm	
7	02.11.2021	12.43 pm	02.10 pm		512	Gizer not working	MCRI ICU	06.11.2021	11.45 am	
8	02.11.2021	11.10 am	11.30 am		1399	Switch Board not working	Dialysis	02.11.2021	11.30 am	
9	02.11.2021	11.00 am	11.00 am		1298	LED 15watt not working	OBGY Ward	03.11.2021	11.25 am	
10	03.11.2021	09.35 am	09.55 am		2122	Cilling Fan not working	Hematology ICU	03.11.2021	10.35 am	
11	03.11.2021	12.45 pm	02.35 pm		4301	VRV Casset unit-01 not working	OBGY ward	08.11.2021	10.00 am	
12	03.11.2021	02.36 pm	03.10 pm		3442	Tharmameter not working	OT Complex			Work in progress
13	03.11.2021	04.30 pm	04.55 pm		3182	Gizer not working	Covid-19 ward	05.11.2021	09.45 am	
14	04.11.2021	04.21 pm	04.45 pm		644	Electrical problame	Time Office	05.11.2021	11.00 am	
15	04.11.2021	10.00 am	12.00 am		Letter	Shutdown cable repairing work	OT Complex	04.11.2021	12.30 pm	
16	05.11.2021	09.55 am	09.58 am		113	Switch Board not working	PICU	05.11.2021	10.08 am	
17	05.11.2021	12.46 pm	02.10 pm		2419	VRV Not working	Central Research Dept.	05.11.2021	03.20 pm	
18	05.11.2021	04.08 pm	04.35 pm		2654	LED 15watt not working	Old Deluxe	06.11.2021	02.20 pm	
19	06.11.2021	10.45 am	11.35 am		395	LED Tubelight not working	OBGY	06.11.2021	01.25 pm	
20	06.11.2021	10.35 am	12.00 pm		121	Switch Board not working	FSW	06.11.2021	12.45 pm	
21	06.11.2021	10.20 am	10.35 am		2022	Split AC not working	MJPJAY ward	06.11.2021	04.00 pm	
	Pending work									
1	04.10.2021	10.00 am	10.15 am		1676	DipFreez not working	Blood bank			Work in progress

Total Complaint	22
Pending Complaint	3
Complete Complaint	19
Complaint Precentrage	86%

M.V.Gaikwad
MGM Aurangabad

Electrical Engineer
MGM Aurangabad

Electrical Supervisor
MGM Aurangabad

MGM MEDICAL COLLEGE & HOSPITAL

ELECTRICAL MAINTANCE REPORT 08/11/2021 to 14/11/2021 14.11.2021

Sr.No.	Received Date	Time	Attende Time	Response Time	Cpmplaint No.	Nature Of Complent	Name Of Department	Date Of Complation	Close Time	Remark
1	25.10.2021	09.00 am	09.15 am		641	Water cooler not working	Time Office	25.10.2021	02.55 pm	
2	25.10.2021	10.45 am	11.05 am		1706	Cat-06 Cable laying	Dyotan Hall			Work in progress
3	27.10.2021	11.35 am	12.15 pm		2740	Call Bell System Change	New Deluxe			Requirment work
4	27.10.2021	11.22 am	12.10 pm		2296	LED Bulb not working	MCRI ICU	27.10.2021	12.35 pm	
5	29.10.2021	10.22 am	12.21 pm		4588	Telephone cable laying work.	Biochemistry Dept.			Requirment work
6	08.11.2021	10.20 am	11.05 am		480	Switch Board not working	NICU	08.11.2021	12.45 pm	
7	08.11.2021	11.02 am	12.20 pm		331	AHU Filter cleaning	Super Deluxe	08.11.2021	04.20 pm	
8	08.11.2021	12.30 pm	12.55 pm		482	Extention Board not working	NICU	08.11.2021	01.10 pm	
9	08.11.2021	10.25 am	11.15 am		481	LED Tubelight not working	NICU	08.11.2021	01.20 pm	
10	09.11.2021	02.40 pm	03.20 pm		1661	X-Ray Box not working	CVTS	10.11.2021	09.20 am	
11	09.11.2021	12.20 pm	12.45 pm		796	LED Tublight Required	Microbiology	15.11.2021	12.35 pm	
12	09.11.2021	10.30 am	10.55 am		3457	Switch Board not working	OT Complex	09.11.2021	02.55 pm	
13	09.11.2021	10.30 am	11.00 am		3456	Switch Board not working	OT Complex	09.11.2021	02.40 pm	
14	10.11.2021	09.45 am	10.00 am		82	LED Light not Working	ENT OPD	10.11.2021	10.15 am	
15	10.11.2021	10.30 am	11.45 am		649	Dipawali Lamp Removing work	Time Office			Work in progress
16	10.11.2021	02.15 pm	03.10 pm		2251	LED Focus Requirement	STP/ETP			Requirment work
17	10.11.2021	03.30 pm	03.30 pm		797	Tharmameter not working	Microbiology	10.11.2021	03.30 pm	
18	10.11.2021	12.35 pm	02.55 pm		1919	Exhouast Fan not working	House kiping Dept.			Work in progress
19	11.11.2021	12.59 pm	02.40 pm		3460	Incubator not working	OT Complex	11.11.2021	04.20 pm	
20	11.11.2021	09.55 am	11.55 am		484	LED 18watt Panel	Pulmo.Med.OPD	12.11.2021	12.45 pm	
21	11.11.2021	12.25 pm	12.45 pm		648	Inset Killer not working	NICU	15.11.2021	09.05 am	
22	11.11.2021	07.14 pm	07.55 pm		650	Lift No-06 Not working	Time Office	12.11.2021	09.45 am	
23	11.11.2021	11.14 am	11.45 am		397	LED Tubelight not working	OBGY Dept.	13.11.2021	12.15 pm	
24	11.11.2021	11.55 am	12.20 pm		4201	LED Light not Working	OBGY ICU	13.11.2021	11.40 am	
25	12.11.2021	10.20 am	11.15 am		4071	LED Tubelight not working	OBGY Ward	12.11.2021	12.30 pm	
26	12.11.2021	10.55 am	12.20 pm		1423	LED Tubelight not working	Covid OPD	12.11.2021	01.15 pm	
27	12.11.2021	02.50 pm	03.55 pm		4305	LED 15watt not working	OBGY Ward-I	13.11.2021	11.55 am	
28	12.11.2021	10.55 am	11.35 am		1422	Cilling Fan not working	Covid OPD	16.11.2021	11.15 am	
29	12.11.2021	11.30 am	11.55 am		1118	Exhouast Fan not working	M.Ortho ward			Work in progress
30	12.11.2021	12.53 pm	02.55 pm		3013	Switch Board not working	FMW	16.11.2021	10.05 am	
31	13.11.2021	11.20 am	11.55 am		672	LED 18watt Panel	CATH-LAB	13.11.2021	03.10 pm	
32	13.11.2021	03.45 pm	04.10 pm		2295	LED Tubelight not working	Psy.ward.	15.11.2021	02.50 pm	
33	13.11.2021	02.55 pm	03.15 pm		1270	Vaccum Motor not working	Biomedical Dept.			Work in progress

Pending work

1	04.10.2021	10.00 am	10.15 am		411	DipFreez not working	Blood bank			Work in progress
2	01.11.2021	11.15 am	11.55 am		1916	Gizer not working	Time Office	09.11.2021	02.30 pm	
3	03.11.2021	02.36 pm	03.10 pm		3442	Tharmameter not working	OT Complex			Work in progress

Total Complaint	36
Pending Complaint	7
Complete Complaint	29
Complaint Precentrage	81%

M.V.Gaikwad
MGM Aurangabad

Electrical Engineer
MGM Aurangabad

Electrical Supervisor
MGM Aurangabad

MGM MEDICAL COLLEGE & HOSPITAL

ELECTRICAL MAINTANCE REPORT 15/11/2021 to 21/~~11/2021~~ 22.11.2022

Sr.No.	Received Date	Time	Attende Time	Response Time	Cpmplaint No.	Nature Of Complent	Name Of Department	Date Of Complation	Close Time	Remark
1	15.11.2021	09.45 am	10.15 am		2029	Switch Board not working	MCRI OPD	15.11.2021	12.40 pm	
2	15.11.2021	10.40 am	10.25 am		4202	LED Light not Working	OBGY ICU	15.11.2021	12.05 pm	
3	15.11.2021	10.40 am	10.30 am		4203	Switch Board not working	OBGY ICU	15.11.2021	12.05 pm	
4	15.11.2021	03.50 pm	03.50 pm		3324	LED Tubelight not working	Skin VD	15.11.2021	03.50 pm	
5	15.11.2021	01.00 pm	02.15 pm		2746	Call Bell not working	New Deluxe	15.11.2021	02.30 pm	
6	15.11.2021	04.05 pm	04.35 pm		3463	Switch Board not working	OT Complex	16.11.2021	02.10 pm	
7	15.11.2021	10.05 am	10.35 am		847	LED Light & AC not working	Radiology Dept	17.11.2021	11.55 am	
8	15.11.2021	04.05 pm	04.55 pm		3462	LED Tubelight not working	OT Complex	16.11.2021	01.55 pm	
9	15.11.2021	01.05 pm	02.10 pm		2744	LED Tubelight not working	New Deluxe	15.11.2021	02.30 pm	
10	15.11.2021	09.45 am	09.55 am		2745	LED Tubelight not working	New Deluxe	15.11.2021	02.30 pm	
11	16.11.2021	10.45 am	11.00 am		1424	Switch Board not working	Covid OPD	16.11.2021	11.15 am	
12	16.11.2021	10.17 am	10.30 am		279	LED Light not Working	Physiotherapy	18.10.2021	10.10 am	
13	16.11.2021	11.30 am	11.45 am		1118	Exhouast Fan not working	M.Ortho ward	18.11.2021	03.00 pm	
14	16.11.2021	10.30 am	11.15 am		3001	Refregator not working	Microbiology	19.11.2021	12.55 pm	
15	16.11.2021	11.03 am	12.15 pm		1580	LED Tubelight not working	Med.OPD	18.11.2021	02.20 pm	
16	17.11.2021	10.00 am	10.25 am		651	Tharmameter not working	NICU	17.11.2021	10.55 am	
17	17.11.2021	09.30 am	09.55 am		259	Switch Board not working	MJPJAY ward	17.11.2021	02.50 pm	
18	17.11.2021	10.45 am	11.10 am		Letter	Telephone cable laying work.	Anaesthesia	20.11.2021	02.30 pm	
19	17.11.2021	02.20 pm	02.30 pm		737	Cilling Fan not working	OBGY Ward	17.11.2021	02.30 pm	
20	17.11.2021	02.10 pm	02.45 pm		1622	LED Bulb not working	Ex.Deluxe	17.11.2021	03.10 pm	
21	17.11.2021	03.58 pm	04.10 pm		81	Cilling Fan not working	Endoscophy	17.11.2021	04.10 pm	
22	18.11.2021	10.30 am	10.30 am		3018	Tharmameter not working	FMW	18.11.2021	10.30 am	
23	18.11.2021	10.55 am	10.55 am		3184	Tharmameter not working	COVID 19 OPD	18.11.2021	10.55 am	
24	18.11.2021	04.30 pm	04.30 pm		3185	Tharmameter not working	COVID 19 OPD	18.11.2021	04.35 pm	
25	18.11.2021	12.40 pm	02.15 pm		520	Cilling Fan not working	MCRI ICU	19.11.2021	01.55 pm	
26	18.11.2021	12.39 pm	02.20 pm		519	LED Bulb not working	MCRI ICU	19.11.2021	10.35 am	
27	18.11.2021	03.40 pm	04.15 pm		4403	LED Light not Working	F.Ortho ward	18.11.2021	04.40 pm	
28	19.11.2021	01.15 pm	02.10 pm		525	LED Light not Working	MCRI ICU	19.11.2021	02.30 pm	
29	19.11.2021	12.05 pm	12.55 pm		659	Switch Board not working	Time Office			Work in progress
30	19.11.2021	12.51 pm	02.05 pm		3002	LED Light not Working	Microbiology	19.11.2021	02.40 pm	
31	19.11.2021	12.15 pm	12.45 pm		2816	Switch Board not working	EICU	19.11.2021	03.05 pm	
32	19.11.2021	10.45 am	10.55 am		3187	Refregator not working	COVID 19 OPD	19.11.2021	04.00 pm	
33	20.11.2021	09.45 am	10.15 am		655	Extention Board not working	NICU	20.11.2021	11.15 am	
34	20.11.2021	12.43 pm	02.15 pm		676	LED Bulb not working	CATH-LAB	20.11.2021	04.35 pm	
35	20.11.2021	10.59 am	11.15 am		1756	LED Light not Working	SICU	20.11.2021	02.40 pm	
36	20.11.2021	10.59 am	11.45 am		1757	Air cartain not working	SICU			Work in progress
37	20.11.2021	12.00 pm	12.35 pm		1523	AC Vent not working	Casulty	20.11.2021	04.00 pm	

	Pending work									
1	04.10.2021	10.00 am	10.15 am		167	DipFreez not working	Blood bank			Work in progress
2	03.11.2021	02.36 pm	03.10 pm		3442	Tharmameter not working	OT Complex			Work in progress
3	25.10.2021	10.45 am	11.05 am		1706	Cat-06 Cable laying	Dyotan Hall	20.11.2021	10.50 am	
4	10.11.2021	10.30 am	11.45 am		649	Dipawali Lamp Removing work	Time Office	19.11.2021	05.00 pm	
5	10.11.2021	12.35 pm	02.55 pm		1919	Exhouast Fan not working	House kiping Dept.			Work in progress

Total Complaint	42
Pending Complaint	5
Complete Complaint	37
Complaint Precentrage	88%

M.V.Gaikwad
MGM Aurangabad

Electrical Engineer
MGM Aurangabad

Electrical Supervisor
MGM Aurangabad

MGM MEDICAL COLLEGE & HOSPITAL
ELECTRICAL MAINTANCE REPORT 22/11/2021 to 28/11/2021

Sr.No.	Received Date	Time	Attende Time	Response Time	Cpmplaint No.	Nature Of Complent	Name Of Department	Date Of Complation	Close Time	Remark
1	22.11.2021	09.30 pm	09.45 pm		331	Cat-06 Cable laying	School of Bio-Med.	26.11.2021	04.15 pm	
2	22.11.2021	09.20 am	09.45 am		2134	LED Tubelight & Cilling fan not v	Resistation	25.11.2021	01.45 pm	
3	23.11.2021	10.00 am	10.15 am		3472	LED Tubelight not working	OT Complex	23.11.2021	11.08 am	
4	23.11.2021	10.20 am	11.00 am		2031	VRV Indoor Not working	MCRI OPD	23.11.2021	12.25 pm	
5	23.11.2021	02.15 pm	02.45 pm		2132	Extention Board not working	Hematology ICU	24.11.2021	03.40 pm	
6	23.11.2021	02.17 pm	02.35 pm		2133	Cilling Fan not working	Hematology ICU	26.11.2021	12.35 pm	
7	23.11.2021	12.05 pm	12.30 pm		858	LED Tubelight not working	MJPJAY ward	25.11.2021	10.05 am	
8	23.11.2021	09.20 am	11.10 am		4310	Cilling Fan not working	OBGY 1st	25.11.2021	12.15 pm	
9	24.11.2021	01.25 pm	02.10 pm		2756	Switch Board not working	New Deluxe	24.11.2021	10.35 am	
10	25.11.2021	10.30 am	11.00 am		4311	LED Tubelight not working	OBGY 1st	25.11.2021	11.45 am	
11	25.11.2021	02.15 pm	02.40 pm		2557	LED Tubelight not working	CSSD	26.11.2021	10.05 am	
12	25.11.2021	09.05 am	09.20 am		1122	Exhouast Fan not working	M.Ortho ward	25.11.2021	12.10 pm	
13	25.11.2021	03.05 pm	03.40 pm		521	X-Ray Box not working	Dental OPD	26.11.2021	11.56 am	
14	25.11.2021	10.30 am	11.05 am		4312	Extention Board not working	OBGY 1st	25.11.2021	11.25 am	
15	25.11.2021	10.30 am	10.50 am		1121	Cilling Fan not working	M.Ortho ward	27.11.2021	03.35 pm	
16	25.11.2021	04.35 pm	04.40 pm		660	Lift No-05 not working	Time Office	25.11.2021	04.40 pm	
17	25.11.2021	03.30 pm	03.45 pm		3007	Electrical problame	Microbiology	25.11.2021	03.40 pm	
18	27.11.2021	03.20 pm	03.35 pm		1398	VRV Unit water leckage	Dialysis	27.11.2021	04.30 pm	
19	27.11.2021	01.10 pm	02.35 pm		2515	LED Tubelight not working	MCRI	27.11.2021	02.45 pm	
20	28.11.2021	09.20 am	09.45 am		664	Water cooler not working	Time Office	28.11.2021	10.15 am	
21	28.11.2021	09.31 am	09.45 am		3905	Switch Board not working	Dialysis	28.11.2021	10.50 am	
22	28.11.2021	10.05 am	11.15 am		665	Water cooler not working	Time Office	28.11.2021	03.20 pm	
	Pending work									
1	04.10.2021	10.00 am	10.15 am		1676	DipFreez not working	Blood bank	22.11.2021	09.30 am	
2	03.11.2021	02.36 pm	03.10 pm		3442	Tharmameter not working	OT Complex			Work in progress
3	19.11.2021	12.05 pm	12.55 pm		659	Switch Board not working	Time Office	20.11.2021	10.55 am	
4	20.11.2021	10.59 am	11.45 am		1757	Air cartain not working	SICU			Work in progress
5	10.11.2021	12.35 pm	02.55 pm		1919	Exhouast Fan not working	House kiping Dept.	24.11.2021	04.20 pm	
6	20.11.2021	02.35 pm	02.55 pm		3003	LED 18watt Panel	Microbiology	22.11.2021	02.30 pm	

Total Complaint	28
Pending Complaint	2
Complete Complaint	26
Complaint Precentrage	93%

M.V.Gaikwad
MGM Aurangabad

Electrical Engineer
MGM Aurangabad

Electrical Supervisor
MGM Aurangabad

MGM MEDICAL COLLEGE & HOSPITAL

ELECTRICAL MAINTANCE REPORT 29/11/2021 to ~~2/2021~~ 05.12.2022

Sr.No.	Received Date	Time	Attende Time	Response Time	Cpmplaint No.	Nature Of Complent	Name Of Department	Date Of Complation	Close Time	Remark
1	30.11.2021	09.30 am	09.55 am		3313	RO Puri fire not working	PSM Dept.	30.11.2021	04.15 pm	
2	30.11.2021	12.17 pm	02.15 pm		738	Exhouast Fan not working	OBGY Ward			Plasti fan required
3	01.12.2021	03.30 am	03.35 am		1668	LED 15watt not working	CCU+CVTS	01.12.2021	03.35 pm	
4	01.12.2021	11.17 am	11.55 am		3555	LED Light not Working	Cardac OT	01.12.2021	04.00 pm	
5	01.12.2021	12.00 pm	04.25 pm		2301	LED 15watt not working	Psy.ward.	01.12.2021	04.34 pm	
6	01.12.2021	09.41 am	11.05 am		364	Cilling Fan not working	Super Deluxe	02.12.2021	11.15 am	
7	01.12.2021	09.40 am	10.00 am		365	LED 15watt not working	Super Deluxe	02.12.2021	10.55 am	
8	02.12.2021	09.30 am	10.11 am		370	LED Light not Working	Super Deluxe	02.12.2021	10.55 am	
9	02.12.2021	09.30 am	10.40 am		369	Cilling Fan not working	Super Deluxe	02.12.2021	11.15 am	
10	02.12.2021	11.45 am	12.20 pm		1763	Switch Board not working	SICU	02.12.2021	02.55 pm	
11	02.12.2021	10.30 am	10.55 am		4210	Switch Board not working	OBGY ICU	02.12.2021	03.30 pm	
12	02.12.2021	12.50 pm	02.40 pm		3193	Gizer not working	ENT Ward	02.12.2021	03.45 pm	
13	02.12.2021	10.20 am	11.35 am		90	VRV Not working	Endoscophy	02.12.2021	11.55 am	
14	02.12.2021	03.30 pm	03.55 pm		2665	LED Light not Working	Old Deluxe	04.12.2021	04.00 pm	
15	02.12.2021	05.35 pm	05.40 pm		3642	LED Light not Working	Cardac OT	03.12.2021	12.45 pm	
16	03.12.2021	10.22 am	10.40 am		258	LED Tubelight not working	SS OPD	03.12.2021	10.55 am	
17	03.12.2021	09.30 am	09.55 am		763	LED Tubelight & Cilling fan not work	Central Lab.	03.12.2021	01.05 pm	
18	03.12.2021	10.07 am	11.10 am		2421	VRV Not working	Central Research Dept.	03.12.2021	12.35 pm	
19	03.12.2021	03.25 pm	03.45 pm		2667	Exhouast Fan not working	Old Deluxe	06.12.2021	11.05 am	
20	03.12.2021	09.30 am	09.45 am		693	Lift not working	Chairman Office	03.12.2021	01.55 pm	
21	03.12.2021	03.30 pm	03.55 pm		2668	Fan Regulator not working	Old Deluxe	06.12.2021	11.30 am	
22	03.12.2021	12.00 pm	03.00 pm		3479	LED Tubelight not working	OT Complex	03.12.2021	03.30 pm	
23	03.12.2021	12.05 pm	12.45 pm		2040	LED Tubelight not working	MCRI OPD No-25	06.12.2021	04.35 pm	
24	03.12.2021	09.30 am	09.45 am		2421	VRV Not working	Central Research Dept.	03.12.2021	12.30 pm	
25	03.12.2021	12.02 pm	02.55 pm		3477	LED Tubelight not working	OT Complex	03.12.2021	03.15 pm	
26	03.12.2021	04.35 pm	04.55 pm		4315	Exhouast Fan not working	OBGY ICU	04.12.2021	12.00 pm	
27	03.12.2021	03.30 pm	03.45 pm		2666	Switch Board not working	Old Deluxe	06.12.2021	10.15 am	
28	04.12.2021	09.05 am	09.20 am		1012	Electrical problame	Med.OPD	04.12.2021	09.20 am	
29	04.12.2021	10.20 am	11.15 am		4316	LED Tubelight not working	OBGY ICU	04.12.2021	12.30 pm	
30	04.12.2021	02.10 pm	02.20 pm		538	Gizer not working	MCRI ICU	04.12.2021	02.20 pm	
31	04.12.2021	09.10 am	11.15 am		266	Gizer not working	MJPJAY ward	04.12.2021	12.05 pm	
32	04.12.2021	03.33 pm	03.55 pm		88	Split AC not working	Endoscophy	06.12.2021	12.15 pm	
	Pending work									
1	03.11.2021	02.36 pm	03.10 pm		3442	Tharmameter not working	OT Complex			Work in progress
2	20.11.2021	10.59 am	11.45 am		1757	Air cartain not working	SICU			Work in progress

Total Complaint	
Pending Complaint	3
Complete Complaint	31
Complaint Precentrage	91%

M.V.Gaikwad
MGM Aurangabad

Electrical Engineer
MGM Aurangabad

Electrical Supervisor
MGM Aurangabad

MGM MEDICAL COLLEGE & HOSPITAL

ELECTRICAL MAINTANCE REPORT 06/12/2021 to ~~2/2021~~ 12-12-2021

Sr.No.	Received Date	Time	Attende Time	Response Time	Cpmplaint No.	Nature Of Complent	Name Of Department	Date Of Complation	Close Time	Remark
1	03.12.2021	09.30 am	09.55 am		693	Lift No-11 not working	Time Office	03.12.2021	01.55 pm	
2	06.12.2021	03.05 pm	03.35 pm		903	Exhouast Fan not working	CVTS	06.12.2021	04.15 pm	
3	07.12.2021	01.40 pm	02.10 pm		2292	LED Light not Working	Nephrology ward	07.12.2021	03.15 pm	
4	07.12.2021	04.20 pm	04.30 pm		1533	X-Ray Box not working	Casulty	07.12.2020	04.30 pm	
5	08.12.2021	12.30 pm	12.45 pm		541	Switch Board not working	MCRI ICU	08.12.2021	01.00 pm	
6	08.12.2021	02.45 pm	04.15 pm		907	Extention Board not working	CVTS	09.12.2021	10.30 am	
7	08.12.2021	03.05 pm	04.00 pm		2028	Extention Board not working	MJPJAY ward	09.12.2021	10.35 am	
8	08.12.2021	10.15 am	11.45 am		3023	LED Tubelight not working	FMW	09.12.2021	12.00 pm	
9	09.12.2021	10.05 am	10.20 am		692	LED Tubelight not working	Pathology Department	09.12.2021	10.40 am	
10	09.12.2021	12.00 pm	12.45 pm		3024	LED Tubelight not working	FMW	09.12.2021	03.00 pm	
11	09.12.2021	10.10 am	10.35 am		3643	Cat-06 Cable laying	Cardac OT	09.12.2021	04.15 pm	
12	10.12.2021	11.32 am	11.55 am		3818	Switch Board not working	Dialysis	10.12.2021	12.10 pm	
13	10.12.2021	11.15 am	12.05 pm		1634	LED Light not Working	Ex.Deluxe	10.12.2021	12.45 pm	
14	10.12.2021	11.33 am	12.55 pm		3817	VRV Not working	Dialysis	10.12.2021	04.20 pm	
15	10.12.2021	03.47 pm	03.55 pm		1195	LED Bulb not working	Labour Room	11.12.2021	03.47 pm	
16	10.12.2021	10.40 am	12.00 pm		1193	Switch Board not working	Labour Room	10.12.2021	03.19 pm	
17	11.12.2021	10.15 am	11.00 am		668	LED Tubelight not working	CVTS	11.12.2021	11.00 am	
18	11.12.2021	04.25 pm	04.45 pm		2683	Switch Board not working	Old Deluxe	13.12.2021	12.20 pm	
19	11.12.2021	04.25 pm	04.35 pm		2684	Gizer not working	Old Deluxe	13.12.2021	12.55 pm	
20	11.12.2021	10.15 am	02.45 pm		2562	FCU Not working	CSSD	11.12.2021	04.30 pm	
	Pending work									
1	03.11.2021	02.36 pm	03.10 pm		3442	Tharmameter not working	OT Complex			Work in progress
2	20.11.2021	10.59 am	11.45 am		1757	Air cartain not working	SICU			Work in progress
3	30.11.2021	12.17 pm	02.15 pm		738	Exhouast Fan not working	OBGY Ward			Plasti fan required

Total Complaint	23
Pending Complaint	3
Complete Complaint	20
Complaint Precentrage	87%

M.V.Gaikwad
MGM Aurangabad

Electrical Engineer
MGM Aurangabad

Electrical Supervisor
MGM Aurangabad

MGM MEDICAL COLLEGE & HOSPITAL

ELECTRICAL MAINTANCE REPORT 13/12/2021 to 19/12/2021 19.12.2021

Sr.No.	Received Date	Time	Attende Time	Response Time	Cpmplaint No.	Nature Of Complent	Name Of Department	Date Of Complation	Close Time	Remark
1	13.12.2021	03.47 pm	04.10 pm		1195	LED Bulb not working	Labour Room	18.12.2021	10.15 am	
2	13.12.2021	09.45 am	10.10 am		131	Switch Board not working	FSW	13.12.2021	12.30 pm	
3	13.12.2021	10.20 am	11.05 am		130	Cilling Fan not working	FSW	13.12.2021	12.45 pm	
4	13.12.2021	11.50 am	12.05 pm		669	Split AC not working	MICU	13.12.2021	02.55 pm	
5	14.12.2021	09.30 am	09.45 am		858	Split AC not working	Radiology Dept	14.12.2021	11.30 am	
6	14.12.2021	12.30 pm	12.55 pm		3009	LED Light not Working	Microbiology	14.12.2021	02.55 pm	
7	14.12.2021	02.30 pm	02.45 pm		3493	LED Bulb not working	OT Complex	14.12.2021	02.45 pm	
8	14.12.2021	10.20 am	10.55 am		1914	LED Tubelight not working	Pead.ward	15.12.2021	10.15 am	
9	14.12.2021	03.25 pm	04.00 pm		677	Lift No-01 not working	Time Office	15.12.2021	11.00 am	
10	14.12.2021	02.40 pm	02.55 pm		4319	Switch Board not working	OBGY Ward 1st	15.12.2021	03.25 pm	
11	14.12.2021	03.45 pm	04.10 pm		128	Switch Board not working	Psysiotherapy Buil.	14.12.2021	03.55 pm	
12	15.12.2021	12.15 pm	12.45 pm		2307	Wall Fan not Working	Psy.ward.	15.12.2021	02.20 pm	
13	15.12.2021	10.41 am	11.35 am		2307	LED Tubelight not working	PSM Dept.	15.12.2021	02.45 pm	
14	15.12.2021	11.05 am	11.35 am		545	AC Remote not working	MCRI ICU	17.12.2021	02.40 pm	
15	16.12.2021	02.35 pm	02.40 pm		377	Switch Board not working	Super Deluxe	16.12.2021	02.40 pm	
16	16.12.2021	12.45 pm	02.35 pm		4323	Exhouast Fan not working	OBGY Ward	17.12.2021	10.00 am	
17	17.12.2021	09.50 am	10.25 am		2766	LED Light not Working	New Deluxe	17.12.2021	12.45 pm	
18	17.12.2021	11.25 am	12.10 pm		3068	Switch Board not working	MMW	18.12.2021	02.25 p	
19	17.12.2021	11.55 am	12.25 pm		862	LED Tubelight not working	Radiology Dept	18.12.2021	12.25 pm	
20	17.12.2021	11.45 am	02.20 pm		2688	Switch Board not working	Old Deluxe	18.12.2021	04.35 pm	
21	17.12.2021	02.28 pm	04.10 pm		4269	Split AC not working	IT Department	18.12.2021	02.55 pm	
22	17.12.2021	11.35 am	12.25 pm		3558	LED Tubelight not working	Cardac OT	18.12.2021	02.15 pm	
23	17.12.2021	10.40 am	11.35 am		1014	LED Tubelight not working	Medicin Dept.	17.12.2021	03.05 pm	
24	18.12.2021	11.05 am	12.30 pm		890	LED Tubelight not working	Anatomy	18.12.2021	04.30 pm	
25	18.12.2021	09.25 am	11.35 am		741	Gizer not working	TL ward	18.12.2021	04.15 pm	
26	18.12.2021	11.40 am	12.00 pm		2690	Exhouast Fan not working	Old Deluxe	18.12.2021	05.00 pm	
27	18.12.2021	10.15 am	11.20 am		3559	LED Bulb not working	Cardac OT	18.12.2021	12.35 pm	
28	18.12.2021	12.37 pm	02.35 pm		3560	Mascicoit Light not working	Cardac OT	20.12.2021	11.55 am	
29	18.12.2021	03.25 pm	04.10 pm		2051	Switch Board not working	MCRI OPD	20.12.2021	11.15 am	
	Pending work									
1	03.11.2021	02.36 pm	03.10 pm		3442	Tharmameter not working	OT Complex			Work in progress
2	20.11.2021	10.59 am	11.45 am		1757	Air cartain not working	SICU			Work in progress
3	30.11.2021	12.17 pm	02.15 pm		738	Exhouast Fan not working	OBGY Ward	17.12.2021	10.00 am	

Total Complaint	32
Pending Complaint	2
Complete Complaint	30
Complaint Precentrage	94%

M.V.Gaikwad
MGM Aurangabad

Electrical Engineer
MGM Aurangabad

Electrical Supervisor
MGM Aurangabad

MGM MEDICAL COLLEGE & HOSPITAL

ELECTRICAL MAINTANCE REPORT 20/12/2021 to 26/12/2021

Sr.No.	Received Date	Time	Attende Time	Response Time	Cpmplaint No.	Nature Of Complent	Name Of Department	Date Of Complation	Close Time	Remark
1	20.12.2021	09.45 am	10.10 am		3645	LED Tubelight not working	Cardac OT	20.12.2021	10.25 am	
2	20.12.2021	01.15 pm	02.45 pm		385	LED Tubelight not working	Super Deluxe	20.12.2021	04.25 pm	
3	20.12.2021	03.55 pm	04.15 pm		283	Switch Board not working	Physiotherapy	20.12.2021	04.31 pm	
4	20.12.2021	12.35 pm	04.13 pm		336	Projector Point requirement	Shool of Biomedical	20.12.2021	04.22 pm	
5	20.12.2021	11.26 am	12.00 pm		71	Cilling Fan not working	Central library	20.12.2021	02.05 pm	
6	21.12.2021	02.00 pm	02.15 pm		548	Gizer not working	MCRI ICU	21.12.2021	02.32 pm	
7	21.12.2021	11.05 am	11.05 am		1671	Table fan not working	CCU+CVTS	21.12.2021	03.04 pm	
8	21.12.2021	09.45 am	10.10 am		130	Switch Board not working	Physiotherapy	21.12.2021	10.11 am	
9	21.12.2021	10.20 am	10.45 am		2293	Switch Board not working	Pead.ward	21.12.2021	03.00 pm	
10	21.12.2021	03.32 pm	03.55 pm		271	Cilling Fan not working	MJPJAY ward	22.12.2021	02.05 pm	
11	22.12.2021	01.00 pm	02.45 pm		744	LED Tubelight & Cillng Fan not work	TL ward	23.12.2021	12.45 pm	
12	22.12.2021	03.40 pm	04.10 pm		1674	LED 15watt not working	CCU+CVTS	24.12.2021	03.30 pm	
13	22.12.2021	11.15 am	12.10 pm		2309	Cat-06 Cable laying	Psysiotherapy Buil.	28.12.2021	12.35 pm	
14	22.12.2021	03.45 pm	04.05 pm		1958	LED Tubelight not working	Pharm.Lecture Hall	23.12.2021	04.05 pm	
15	23.12.2021	11.15 am	11.55 am		818	LED Tubelight & LED Bulb not work	Central Store	24.12.2021	12.55 pm	
16	23.12.2021	12.10 pm	12.55 pm		2697	LED Tubelight not working	Old Deluxe	28.12.2021	11.21 am	
17	23.12.2021	09.30 am	09.45 am		3009	LED Tubelight not working	Microbiology	24.12.2021	11.00 am	
18	24.12.2021	09.48 am	10.35 am		3030	LED Tubelight not working	FMW	24.12.2021	11.35 am	
19	24.12.2021	10.46 am	02.11 pm		4712	LED Tubelight not working	OT Complex	28.12.2021	03.10 pm	
20	24.12.2021	02.30 pm	02.45 pm		685	Lift No-01 not working	Time Office	24.12.2021	05.30 pm	
21	24.12.2021	11.00 am	11.35 am		2827	LED Bulb not working	EICU	29.12.2021	11.25 am	
22	25.12.2021	02.25 pm	03.00 pm		392	LED 15watt not working	Super Deluxe	28.12.2021	10.45 am	
	Pending work									
1	03.11.2021	02.36 pm	03.10 pm		3442	Tharmameter not working	OT Complex			Work in progress
2	20.11.2021	10.59 am	11.45 am		1757	Air cartain not working	SICU			Work in progress
3	30.11.2021	12.17 pm	02.15 pm		738	Exhouast Fan not working	OBGY Ward	17.12.2021	10.00 am	
4	18.12.2021	03.25 pm	04.10 pm		2051	Switch Board not working	MCRI OPD	20.12.2021	03.25 pm	

Total Complaint	26
Pending Complaint	2
Complete Complaint	24
Complaint Precentrage	92%

M.V.Gaikwad
MGM Aurangabad

Electrical Engineer
MGM Aurangabad

Electrical Supervisor
MGM Aurangabad

MGM MEDICAL COLLEGE & HOSPITAL

ELECTRICAL MAINTANCE REPORT 27/12/2021 to 01/2021 02.01.2022

Sr.No.	Received Date	Time	Attende Time	Response Time	Cpmplaint No.	Nature Of Complent	Name Of Department	Date Of Complation	Close Time	Remark
1	27.12.2021	02.30 pm	02.45 pm		688	Lift No-06 Not working	Time Office	27.12.2021	05.00 pm	
2	27.12.2021	11.20 am	12.15 pm		285	Water cooler not working	Physiotherapy	27.12.2021	12.55 pm	
3	27.12.2021	09.20 am	10.20 am		687	RO Puri fire not working	Time Office	27.12.2021	04.10 pm	
4	28.12.2021	10.00 am	10.30 am		21	LED Bulb not working	IVF Centare	28.12.2021	10.45 am	
5	28.12.2021	12.50 pm	02.20 pm		4715	LED Tubelight not working	OT Complex	28.12.2021	03.00 pm	
6	28.12.2021	11.30 pm	02.35 pm		906	Switch Board not working	Labour Room	28.12.2021	03.40 pm	
7	28.12.2021	03.25 pm	04.15 pm		2698	LED Tubelight not working	Old Deluxe	29.12.2021	05.00 pm	
8	28.12.2021	12.05 pm	12.30 pm		690	Switch Board not working	Time Office	28.12.2021	04.20 pm	
9	29.12.2021	01.50 pm	02.25 pm		1779	Switch Board not working	SICU	29.12.2021	03.40 pm	
10	29.12.2021	11.33 am	02.20 pm		2567	LED Tubelight & LED Bulb not work	CSSD	29.12.2021	04.30 pm	
11	29.12.2021	10.44 am	02.15 pm		4223	LED Light not Working	OBGY ICU	29.12.2021	03.15 pm	
12	29.12.2021	12.20 pm	02.10 pm		3012	Switch Board not working	Microbiology	29.12.2021	02.45 pm	
13	30.12.2021	10.25 am	11.10 am		1587	LED Tubelight not working	Med.OPD	31.12.2021	10.30 am	
14	31.12.2021	03.40 pm	04.00 pm		915	Table fan not working	CVTS	01.01.2022	11.30 am	
15	31.12.2021	11.30 am	12.05 pm		4723	LED Tubelight not working	OT Complex	31.12.2021	12.30 pm	
16	31.12.2021	11.30 am	11.45 am		1780	Switch Board not working	SICU	31.12.2021	12.05 pm	
	GOOD BY 2021 & WISH A HAPPI NEW YEAR 2022									
17	01.01.2022	12.10 pm	12.45 pm		3647	LED Light not Working	Cardac OT	01.01.2022	02.20 pm	
18	01.01.2022	11.18 am	11.35 am		1271	10Hp Motor Fighter change	Biomedical Dept.			Work in progress
19	01.01.2022	12.58 pm	02.20 pm		2314	Switch Board not working	Psyciology ward	03.01.2022	11.15 am	
20	02.01.2022	10.20 am	11.10 pm		1922	RO Puri fire not working	Time Office	03.01.2022	12.10 pm	
	Pending work									
1	03.11.2021	02.36 pm	03.10 pm		3442	Tharmameter not working	OT Complex			Work in progress
2	20.11.2021	10.59 am	11.45 am		1757	Air cartain not working	SICU			Work in progress

Total Complaint	22
Pending Complaint	2
Complete Complaint	20
Complaint Precentrage	91%

M.V.Gaikwad
MGM Aurangabad

Electrical Engineer
MGM Aurangabad

Electrical Supervisor
MGM Aurangabad

MGM MEDICAL COLLEGE & HOSPITAL

ELECTRICAL MAINTANCE REPORT 03/01/2021 to 09.01.2021 09.01.2022

Sr.No.	Received Date	Time	Attende Time	Response Time	Cpmplaint No.	Nature Of Complent	Name Of Department	Date Of Complation	Close Time	Remark
1	03.01.2022	03.15 pm	03.35 pm		682	Switch Board not working	MICU	03.01.2022	03.35 pm	
2	03.01.2022	12.30 pm	12.45 pm		2253	Motor not working	Near DG Well	06.01.2022	04.00 pm	
3	03.01.2022	02.30 pm	02.45 pm		2037	Switch Board not working	MJPJAY ward	10.01.2022	11.00 am	
4	03.01.2022	10.05 am	10.30 am		4226	Switch Board not working	OBGY ICU	07.01.2022	03.15 pm	
5	04.01.2022	12.50 pm	12.55 pm		557	Extention Board Requirement-08	MCRI ICU	04.01.2022	12.55 pm	
6	04.01.2022	12.25 pm	02.10 pm		1679	LED 15watt not working	CCU+CVTS	04.01.2022	02.45 pm	
7	04.01.2022	11.25 am	03.55 pm		4329	Gizer not working	OBGY 1st	04.01.2022	04.00 pm	
8	04.01.2022	10.00 am	10.35 am		4229	Split AC not working	OBGY ICU	05.01.2022	04.00 pm	
9	04.01.2022	10.50 am	12.00 pm		695	Motor not working	Time Office	04.01.2022	05.00 pm	
10	05.01.2022	03.22 pm	04.05 pm		506	LED Tubelight not working	Old Deluxe	07.01.2022	11.10 am	
11	06.01.2022	10.19 am	11.20 am		749	Switch Board not working	OBGY 2nd	07.01.2022	11.34 am	
12	06.01.2022	11.45 am	12.05 pm		128	Split AC not working	PICU	06.01.2022	02.45 pm	
13	07.01.2022	09.45 am	10.00 am		3203	LED Bulb not working	Urology Dept.	07.01.2022	10.15 am	
14	07.01.2022	12.30 pm	12.45 pm		3314	Cilling Fan not working	PSM Dept.	11.01.2022	09.20 am	
15	07.01.2022	11.00 am	11.55 am		1682	Switch Board not working	CCU+CVTS	07.01.2022	12.45 pm	
16	07.01.2022	04.28 pm	04.45 pm		4729	Switch Board not working	OT Complex	08.01.2022	02.30 pm	
17	08.01.2022	08.30 pm	08.35 pm		2913	LED Tubelight not working	OT Complex	08.01.2022	08.35 pm	
18	08.01.2022	04.15 pm	04.25 pm		1432	LED Tubelight not working	Covid OPD	08.01.2022	04.25 pm	
19	08.01.2022	03.30 pm	04.10 pm		1651	Switch Board not working	Ex.Deluxe	09.01.2022	10.20 am	
20	08.01.2022	04.55 pm	05.10 pm		4733	Switch Board not working	OT Complex	10.01.2022	02.30 pm	
						Pending work				
1	03.11.2021	02.36 pm	03.10 pm		3442	Tharmameter not working	OT Complex			Work in progress
2	20.11.2021	10.59 am	11.45 am		1757	Air cartain not working	SICU	04.01.2022	10.20 am	
3	01.01.2022	11.18 am	11.35 am		1271	10Hp Motor Fighter change	Biomedical Dept.	09.01.2022	12.30 pm	

Total Complaint	23
Pending Complaint	1
Complete Complaint	22
Complaint Precentrage	96%

M.V.Gaikwad
MGM Aurangabad

Electrical Engineer
MGM Aurangabad

Electrical Supervisor
MGM Aurangabad

MGM MEDICAL COLLEGE & HOSPITAL

ELECTI CAL MAINTANCE REPORT 17/01/2022 to 2(1/2022 23.01.2022

Sr.No.	Received Date	Time	Attende Time	Response Time	Cpmplaint No.	Nature Of Complent	Name Of Department	Date Of Complation	Close Time	Remark
1	17.01.2022	11.10 am	11.30 am		2701	LED Tubelight not working	Pead.ward	17.01.2022	11.55 am	
2	17.01.2022	09.50 am	11.10 am		3035	Switch Board not working	FMW	17.01.2022	11.55 am	
3	17.01.2022	09.50 am	11.35 am		3034	LED Tubelight not working	FMW	17.01.2022	12.15 pm	
4	17.01.2022	10.20 am	12.00 pm		2206	Water filter not working	6th Floor	17.01.2022	04.00 pm	
5	17.01.2022	11.15 am	11.30 am		2449	Tharmameter not working	Kt ICU	17.01.2022	12.10 pm	
6	18.01.2022	11.10 am	11.35 am		1570	LED Tubelight not working	Casulty	18.01.2022	12.15 pm	
7	18.01.202	04.35 pm	04.45 pm		1371	LED Tubelight not working	MSW	20.01.2022	06.00 pm	
8	18.01.2022	11.10 am	11.20 am		1571	LED Tubelight not working	Casulty	18.01.2022	11.45 am	
9	18.01.2022	09.45 am	10.20 am		1135	LED Tubelight not working	M.Ortho ward	19.01.2022	11.45 am	
10	18.01.2022	02.30 pm	03.10 pm		1370	Switch Board not working	MSW	18.01.2022	03.45 pm	
11	19.01.2022	05.00 pm	05.10 pm		520	LED Tubelight not working	Old Deluxe	21.01.2022	03.45 pm	
12	19.01.2022	11.05 am	11.15 am		4419	LED Tubelight & Cilling fan not work	F.Ortho ward	19.01.2022	11.25 am	
13	19.01.2022	11.00 am	11.10 am		4418	LED Light not Working	F.Ortho ward	19.01.2022	11.20 am	
14	19.01.2022	02.30 pm	02.45 pm		2908	Tharmameter not working	MICU	19.01.2022	02.45 pm	
15	19.01.2022	10.35 am	11.15 am		2781	LED Light not Working	New Deluxe	20.01.2022	11.45 am	
16	19.01.2022	04.55 pm	05.10 pm		521	LED Tubelight not working	Old Deluxe	19.01.2022	05.10 pm	
17	20.01.2022	11.55 am	12.35 pm		1661	Switch Board not working	Ex.Deluxe	20.01.2022	05.38 pm	
18	20.01.2022	03.20 pm	03.30 pm		864	Call Bell not working	Radiology Dept			Work in progress
19	20.01.2022	03.45 pm	03.55 pm		1707	VRV Not working	Lecture Hall	21.01.2022	11.45 am	
20	21.01.2022	09.24 am	09.45 am		1374	LED Tubelight not working	MSW	21.01.2022	04.55 pm	
21	21.01.2022	04.55 pm	05.05 pm		1376	LED Tubelight not working	MSW	21.01.2022	05.25 pm	
22	21.01.2022	12.25 pm	12.35 pm		2254	LED Tubelight not working	STP	21.01.2022	03.34 pm	
23	21.01.2022	12.00 pm	12.20 pm		4742	LED Tubelight not working	OT Complex	21.01.2022	03.00 pm	
24	22.01.2022	12.45 pm	02.35 pm		1436	Switch Board not working	Covid OPD	22.01.2022	03.05 pm	
25	22.01.2022	02.10 pm	02.45 pm		1437	LED Tubelight not working	Covid OPD	22.01.2022	02.45 pm	
26	22.01.2022	04.35 pm	04.55 pm		2540	LED Tubelight not working	Opthalomogy	22.01.2022	05.00 pm	
27	22.01.2022	11.30 am	11.30 am		2539	Switch Board not working	Opthalomogy	22.01.2022	04.00 pm	
28	22.01.2022	05.25 pm	05.35 pm		4270	Split AC not working	IT Department	24.01.2022	11.45 am	
	Pending work									
1	03.11.2021	02.36 pm	03.10 pm		3442	Tharmameter not working	OT Complex			Work in progress

Total Complaint	29
Pending Complaint	2
Complete Complaint	27
Complaint Precentrage	93%

M.V.Gaikwad
MGM Aurangabad

Electrical Engineer
MGM Aurangabad

Electrical Supervisor
MGM Aurangabad

MGM MEDICAL COLLEGE & HOSPITAL

ELECTRICAL MAINTANCE REPORT 24/01/2022 to 30/01/2022 30.01.2022

Sr.No.	Received Date	Time	Attende Time	Response Time	Cpmplaint No.	Nature Of Complent	Name Of Department	Date Of Complation	Close Time	Remark
1	24.01.2022	05.25 pm	05.45 pm		4270	Split AC not working	IT Department	25.01.2022	11.55 am	
2	24.01.2022	03.00 pm	03.30 pm		534	LED 15watt not working	Dental OPD	28.01.2022	11.30 am	
3	24.01.2022	12.00 pm	12.30 pm		4763	AHU Filter cleaning	OT Complex	24.01.2022	04.00 pm	
4	24.01.2022	10.53 am	11.10 am		1438	Switch Board not working	Covid OPD	24.01.2022	02.45 pm	
5	25.01.2022	10.00 am	10.10 am		2154	Extention Board Maintance	Hematology ICU	25.01.2022	10.16 am	
6	25.01.2022	12.30 pm	12.45 pm		2325	LED Tubelight not working	Psyciology ward	28.01.2022	01.20 pm	
7	25.01.2022	12.20 pm	12.25 pm		820	LED Tubelight not working	Central Store	25.01.2022	12.31 pm	
8	26.01.2022	07.20 pm	07.35 pm		4422	LED Light not Working	F.Ortho ward	26.01.2022	07.35 pm	
9	27.01.2022	12.05 pm	02.10 pm		4765	Switch Board not working	OT Complex	27.01.2022	03.00 pm	
10	27.01.2022	01.35 pm	02.15 pm		2210	Lift No-01 not working	Time Office	29.01.2022	02.50 pm	
11	27.01.2022	12.05 pm	02.20 pm		4766	LED Tubelight not working	OT Complex	27.01.2022	03.00 pm	
12	27.01.2022	12.45 pm	01.55 pm		3080	Switch Board not working	MMW	28.01.2022	02.20 pm	
13	27.01.2022	10.00 am	10.30 am		3194	LED Light not Working	Covid OPD	28.01.2022	03.00 pm	
14	28.01.2022	12.05 pm	02.10 pm		136	Switch Board not working	PICU	28.01.2022	03.30 pm	
15	28.01.2022	11.05 am	11.35 am		917	PL Tubelight 11watt not working	Labour Room	28.01.2022	03.40 pm	
16	28.01.2022	11.45 am	12.10 pm		1959	LED Tubelight & Wall fan not workin	Pharm.Lecture Hall	28.01.2022	03.20 pm	
17	28.01.2022	10.20 am	10.45 am		2213	Lift No-04 not working	Time Office	29.01.2022	02.35 pm	
18	28.01.2022	12.10 pm	0		Letter	Shutdown cable repairing work	Endoscophy	30.01.2022	02.10 pm	
19	28.01.2022	04.00 pm	04.20 pm		137	Switch Board not working	PICU	28.01.2022	04.20 pm	
20	29.01.2022	10.00 am	10.25 am		2074	Switch Board not working	MCRI OPD No-13	29.01.2022	10.30 am	
21	29.01.2022	01.20 pm	02.20 pm		2847	Switch Board not working	EICU	29.01.2022	02.45 pm	
22	29.01.2022	10.15 am	10.45 am		926	LED 15watt not working	CCU+CVTS	29.01.2022	11.35 am	
23	30.01.2022	08.20 am	09.10 am		2214	Lift No-06 Not working	Time Office	31.01.2022	10.20 am	
	Pending work									
1	03.11.2021	02.36 pm	03.10 pm		3442	Tharmameter not working	OT Complex			Work in progress
2	20.01.2022	03.20 pm	03.30 pm		864	Call Bell not working	Radiology Dept			Work in progress

Total Complaint	25
Pending Complaint	2
Complete Complaint	23
Complaint Precentrage	92%

M.V.Gaikwad
MGM Aurangabad

Electrical Engineer
MGM Aurangabad

Technical Executive
MGM Aurangabad

Electrical Supervisor
MGM Aurangabad

MGM MEDICAL COLLEGE & HOSPITAL

ELECTRICAL MAINTANCE REPORT 31/01/2022 to ~~02/2022~~ 07.02.2022

Sr.No.	Received Date	Time	Attende Time	Response Time	Cpmplaint No.	Nature Of Complent	Name Of Department	Date Of Complation	Close Time	Remark
1	31.01.2022	11.05 am	11.45 am		4426	Electrical problame	F.Ortho ward	31.01.2022	12.50 pm	
2	31.01.2022	11.56 am	12.15 pm		3577	Zero bulb not working	Cardac OT	01.02.2022	04.15 pm	
3	31.01.2022	09.55 am	10.45 am		466	LED Removing work.	Sport Building	03.01.2022	02.40 pm	
4	31.01.2022	09.10 am	09.45 am		2215	Lift No-06 Not working	Time Office	01.02.2022	11.15 am	
5	01.02.2022	01.52 pm	02.45 pm		530	LED Light not working	Old Deluxe	01.02.2022	04.03 pm	
6	02.02.2022	10.30 am	11.55 am		894	Refregator, Desert cooler, Tubelight, LED Bulb & Etc. work	Anatomy	02.02.2022	02.00 pm	
7	02.02.2022	10.40 am	11.45 am		2158	Switch Board not working	Hematology ICU	02.02.2022	02.30 pm	
8	04.02.2022	10.40 am	11.00 am		4429	LED Tubelight not working	F.Ortho ward	04.02.2022	11.00 am	
9	04.02.2022	08.20 am	09.05 am		2210	Lift No-01 not working	Time Office	04.02.2022	11.55 am	
10	05.02.2022	01.00 pm	01.05 pm		338	Switch Board not working	Biomedical Dept.	05.02.2022	01.05 pm	
11	05.02.2022	03.00 pm	03.10 pm		1810	Earthing Problame	Super Deluxe	05.02.2022	03.20 pm	
12	05.02.2022	03.00 pm	03.15 pm		77	LED Light not Working	Stair case	07.02.2022	04.15 pm	
						Pending work				
1	03.11.2021	02.36 pm	03.10 pm		3442	Tharmameter not working	OT Complex			Work in progress
2	20.01.2022	03.20 pm	03.30 pm		864	Call Bell not working	Radiology Dept	02.02.2022	11.10 am	

Total Complaint	14
Pending Complaint	1
Complete Complaint	13
Complaint Precentrage	93%

M.V.Gaikwad
MGM Aurangabad

Electrical Engineer
MGM Aurangabad

Technical Executive
MGM Aurangabad

Electrical Supervisor
MGM Aurangabad

MGM MEDICAL COLLEGE & HOSPITAL

ELECTRIC[illegible] MAINTANCE REPORT 08/02/2022 to 13/0[illegible]022 13.02.2022

Sr.No.	Received Date	Time	Attende Time	Response Time	Cpmplaint No.	Nature Of Complent	Name Of Department	Date Of Complation	Close Time	Remark
1	29.01.2022	11.10 am	11.30 am		466	Light Fitting removing work	C' Building	30.01.2022	12.35 pm	
2	04.02.2022	09.30 am	10.10 am		5109	Switch Board not working	NICU	05.02.2022	10.22 am	
3	07.02.2022	11.20 am	12.10 pm		534	LED 15watt not working	Old Deluxe	07.02.2022	02.10 pm	
4	07.02.2022	11.15 am	11.45 am		2849	LED 15watt not working	EICU	07.02.2022	03.40 pm	
5	07.02.2022	03.20 pm	03.25 pm		536	Exhouast Fan not working	Dental OPD	07.02.2022	03.55 pm	
6	08.02.2022	10.20 am	11.10 am		7406	Air Cooler & Refregator not working	Anatomy			Work in progress
7	09.02.2022	10.30 am	10.50 am		2226	Switch Board not working	Time Office	09.02.2022	10.50 am	
8	09.02.2022	10.25 am	10.50 am		2795	Switch Board not working	New Deluxe	09.02.2022	11.15 am	
9	09.02.2022	11.05 am	11.50 am		2797	Extention Board not working	New Deluxe	09.02.2022	02.45 pm	
10	09.02.2022	10.25 am	11.10 am		2090	Switch Board not working	MCRI OPD No-25	09.02.2022	12.30 pm	
11	09.02.2022	11.25 am	12.00 pm		4273	LED 15watt not working	IT Department	09.02.2022	04.10 pm	
12	09.02.2022	03.30 pm	04.10 pm		3200	LED Light not Working	ENT Ward	09.02.2022	12.00 pm	
13	09.02.2022	10.52 am	11.15 am		1806	Tharmameter not working	Super Deluxe	10.02.2022	10.30 am	
14	09.02.2022	05.05 pm	05.30 pm		2850	LED Bulb not working	EICU	10.02.2022	11.30 am	
15	10.02.2022	12.40 pm	12.55 pm		3832	Switch Board not working	Dialysis	10.02.2022	04.10 pm	
16	10.02.2022	04.02 pm	04.20 pm		2228	New Motor Requirement	Time Office	12.02.2022	10.40 am	
17	10.10.2022	11.35 am	11.55 am		5111	Switch Board not working	NICU	10.02.2022	03.22 pm	
18	11.02.2022	09.45 am	10.10 am		3332	LED Tubelight not working	Skin VD	12.02.2022	11.30 am	
19	12.02.2022	10.00 am	10.30 am		823	LED Tubelight not working	Central Store	12.02.2022	11.26 am	
20	12.02.2022	11.27 am	11.55 am		4340	LED Bulb not working	OBGY Ward	12.02.2022	03.10 pm	
21	13.02.2022	10.50 am	10.56 am		3087	Switch Board not working	MMW	13.02.2022	10.56 am	
	Pending work									
1	03.11.2021	02.36 pm	03.10 pm		3442	Tharmameter not working	OT Complex	06.02.2022	11.10 am	

Total Complaint	22
Pending Complaint	1
Complete Complaint	21
Complaint Precentrage	95%

M.V.Gaikwad
MGM Aurangabad

Electrical Engineer
MGM Aurangabad

Technical Executive
MGM Aurangabad

Electrical Supervisor
MGM Aurangabad

MGM MEDICAL COLLEGE & HOSPITAL

ELECTRICAL MAINTANCE REPORT 14/02/2022 t[illegible]/02/2022 20.02.2022

Sr.No.	Received Date	Time	Attende Time	Response Time	Cpmplaint No.	Nature Of Complent	Name Of Department	Date Of Complation	Close Time	Remark
1	07.01.2022	09.25 am	10.10 am		697	RO Puri fire not working	Radiology Dept	07.01.2022	12.55 pm	
2	07.01.2022	02.30 pm	02.45 pm		698	RO Puri fire not working	Hospital Canteen	07.01.2022	04.15 pm	
3	10.01.2022	10.20 am	11.15 am		72	RO Puri fire not working	Central library	10.01.2022	04.15 pm	
4	14.02.2022	09.25 am	09.45 am		1381	C.fan,LED tubelight & switch board n	M.Surjery ward	14.02.2022	11.05 am	
5	14.02.2022	12.40 pm	12.55 pm		Letter	Cat-06 Cable laying	Saket book	15.02.2022	04.30 pm	
6	14.02.2022	11.30 am	12.10 pm		3088	Switch Board not working	MMW	14.02.2022	02.45 pm	
7	14.02.2022	11.30 am	12.00 pm		3090	Cilling Fan not working	MMW	14.02.2022	02.30 pm	
8	14.02.2022	10.05 am	10.30 am		1301	Switch Board not working	Covid-19	16.02.2022	11.05 am	
9	14.02.2022	10.00 am	10.15 am		1302	Gizar not working	Covid-19	16.02.2022	11.30 am	
10	14.02.2022	10.37 am	12.55 pm		578	Gizar not working	MCRI ICU	14.02.2022	02.45 pm	
11	15.02.2022	11.15 am	12.31 pm		3585	LED Light not Working	Cardac OT	15.02.2022	12.45 pm	
12	15.02.2022	09.30 am	09.45 am		4337	Exhouast Fan not working	OBGY 1st	15.02.2022	01.10 pm	
13	15.02.2022	12.45 pm	01.00 pm		907	Peddastal fan not working	CATH-LAB	15.02.2022	03.20 pm	
14	15.02.2022	12.46 pm	02.35 pm		4593	LED Tubelight not working	Biochemistry Dept.	15.02.2022	04.20 pm	
15	15.02.2022	03.10 pm	03.35 pm		2045	Switch Board not working	MJPJAY ward	15.02.2022	03.35 pm	
16	16.02.2022	12.45 pm	12.55 pm		2948	X-Ray Box not working	MICU	16.02.2022	02.35 pm	
17	16.02.2022	01.00 pm	02.45 pm		3017	Split AC not working	Microbiology	21.02.2022	10.20 am	
18	17.02.2022	02.35 pm	03.05 pm		146	Switch Board not working	PICU	17.02.2022	03.05 pm	
19	17.02.2022	02.20 pm	02.40 pm		4800	Switch Board not working	OT Complex	18.02.2022	03.35 pm	
20	17.02.2022	03.40 pm	03.45 pm		318	LED Light not Working	Endoscophy	17.02.2022	04.15 pm	
21	18.02.2022	03.30 pm	03.45 pm		1451	Switch Board not working	Covid OPD	18.02.2022	03.45 pm	
22	18.02.2022	01.00 pm	02.35 pm		6002	Switch Board not working	OT Complex	18.02.2022	03.20 pm	
23	18.02.2022	02.10 pm	03.20 pm		2954	Telephone cable laying work.	MICU	19.02.2022	04.30 pm	
24	18.02.2022	02.11 pm	03.00 pm		2953	X-Ray Box not working	MICU	19.02.2022	04.15 pm	
25	18.02.2022	01.25 pm	02.40 pm		2048	Split AC not working	MJPJAY ward	21.02.2022	11.30 pm	
						Pending work				
1	08.02.2022	10.20 am	11.10 am		7406	Air Cooler & Refregator not working	Anatomy	16.02.2022	02.45 pm	

Total Complaint	26
Pending Complaint	0
Complete Complaint	26
Complaint Precentrage	100%

M.V.Gaikwad
MGM Aurangabad

Electrical Engineer
MGM Aurangabad

Technical Executive
MGM Aurangabad

Electrical Supervisor
MGM Aurangabad

MGM MEDICAL COLLEGE & HOSPITAL

ELECTRICAL MAINTANCE REPORT 21/02/2022 to 27/02/2022 27.02.2022

Sr.No.	Received Date	Time	Attende Time	Response Time	Cpmplaint No.	Nature Of Complent	Name Of Department	Date Of Complation	Close Time	Remark
1	15.02.2022	10.15 am	10.45 am		1308	Split AC not working	Isolation ICU	18.02.2022	12.30 pm	
2	21.02.2022	09.57 am	10.15 am		1142	LED Tubelight not working	M.Ortho ward	21.02.2022	12.30 pm	
3	21.02.2022	09.57 am	10.35 am		1143	Cilling Fan not working	M.Ortho ward	21.02.2022	12.45 pm	
4	21.02.2022	04.35 pm	04.55 pm		2235	Lift No-05 not working	Time Office	24.02.2022	10.25 am	
5	21.02.2022	10.00 am	02.31 pm		6006	LED Light not Working	OT Complex	22.02.2022	03.00 pm	
6	21.02.2022	04.03 pm	04.15 pm		906	Split AC not working	CATH-LAB			Work in progress
7	21.02.2022	03.20 pm	04.10 pm		1821	Switch Board not working	Super Deluxe	21.02.2022	05.10 pm	
8	22.02.2022	10.00 am	11.30 am		6007	LED Tubelight not working	OT Complex	22.02.2022	02.32 pm	
9	22.02.2022	09.20 am	02.00 pm		4342	Exhouast Fan not working	OBGY-I	22.02.2022	02.30 pm	
10	22.02.2022	05.15 pm	05.35 pm		2236	Lift No-07 Not working	Time Office	24.02.2022	03.45 pm	
11	22.02.2022	10.55 am	11.10 am		585	Air cartain not working	MCRI ICU	26.02.2022	11.35 am	
12	22.02.2022	11.20 am	03.20 pm		584	LED Light not Working	MCRI ICU	23.02.2022	04.20 pm	
13	22.02.2022	05.25 pm	05.55 pm		2237	Lift No-07 Not working	Time Office	23.02.2022	10.30 am	
14	22.02.2022	09.15 am	09.45 am		3094	Switch Board not working	MMW	23.02.2022	10.20 am	
15	23.02.2022	11.35 am	11.45 am		2543	Switch Board not working	Opthal OPD	23.02.2022	11.45 am	
16	23.02.2022	10.50 am	11.35 am		588	Gizar not working	MCRI ICU	23.02.2022	04.30 pm	
17	23.02.2022	10.15 am	02.40 pm		3095	LED Tubelight & Switch Board not w	MMW	23.02.2022	04.48 pm	
18	23.02.2022	03.05 pm	04.10 pm		5301	LED Bulb not working	Blood bank	24.02.2022	10.05 am	
19	25.02.2022	02.05 pm	03.35 pm		540	Switch Board not working	Old Deluxe	26.02.2022	10.45 am	
20	25.02.2022	10.45 am	11.40 am		915	Refregator not working	Labour Room	25.02.2022	11.45 am	
21	25.02.2022	09.45 am	10.30 am		2855	LED Light not Working	EICU	25.02.2022	11.15 am	
22	25.02.2022	09.25 am	09.45 am		2705	LED Light not Working	New Deluxe	25.02.2022	10.05 am	
23	25.02.2022	11.50 am	12.20 pm		2138	Cat-06 Cable laying	MCRI OPD-251	25.02.2022	04.35 pm	
24	25.02.2022	02.10 pm	03.20 pm		3098	LED Tubelight not working	MMW	26.02.2022	11.15 am	
25	25.02.2022	10.30 am	11.30 am		3251	LED Light not Working	Pead.ward	26.02.2022	10.00 am	
26	25.02.2022	12.25 pm	02.40 pm		27	LED Light not Working	IVF Centare	26.02.2022	05.00 pm	
27	25.02.2022	11.25 am	11.35 am		6015	Tharmameter not working	OT Complex	26.02.2022	11.55 am	
28	25.02.2022	08.45 pm	08.55 pm		2240	Lift No-07 Not working	Time Office	27.02.2022	12.05 pm	
29	25.02.2022	02.05 pm	03.45 pm		539	Exhouast Fan not working	Old Deluxe	28.02.2022	04.45 pm	
30	26.02.2022	11.05 am	11.35 am		28	LED 15watt not working	IVF Centare	26.02.2022	04.00 pm	
31	26.02.2022	03.50 pm	04.35 pm		2965	Extantion Board not working	MMW	28.02.2022	05.45 pm	
32	26.02.2022	02.00 pm	02.30 pm		2242	Lift No-07 Not working	Time Office			Work in progress
						Pending work				

Total Complaint	32
Pending Complaint	2
Complete Complaint	30
Complaint Precentrage	94%

M.V.Gaikwad
MGM Aurangabad

Electrical Engineer
MGM Aurangabad

Technical Executive
MGM Aurangabad

Electrical Supervisor
MGM Aurangabad

MGM MEDICAL COLLEGE & HOSPITAL

ELECTRICAL MAINTANCE REPORT 28/02/2022 to 06.03.2022

Sr.No.	Received Date	Time	Attende Time	Response Time	Cpmplaint No.	Nature Of Complent	Name Of Department	Date Of Complation	Close Time	Remark
1	06.02.2022	04.30 pm	04.45 pm		78	Water filter not working	Central Laibrary	08.02.2022	11.30 am	
2	07.02.2022	11.20 am	11.45 am		3317	Water filter not working	PSM Dept.	08.02.2022	04.30 pm	
3	08.02.2022	11.20 am	12.10 pm		2676	Water filter not working	Exam cell	08.02.2022	03.00 pm	
4	08.02.2022	10.15 am	10.40 am		4592	Water filter not working	Biochemistry Dept.	08.02.2022	02.20 pm	
5	09.02.2022	11.30 am	11.55 am		2227	RO not working	Time Office	09.02.2022	12.25 pm	
6	09.02.2022	04.10 pm	04.25 pm		287	RO not working	Physiotherapy	09.02.2022	04.45 pm	
7	03.02.2022	10.10 am	11.15 am		2084	Electrical problame	MCRI OPD-27	03.02.2022	11.20 am	
8	14.02.2022	02.30 pm	02.55 pm		1305	Split AC not working	Isolation ICU	09.02.2022	04.05 pm	
9	15.02.2022	10.15 am	10.20 am		1308	Split AC not working	Isolation ICU	24.02.2022	01.00 pm	
10	16.02.2022	10.20 am	10.30 am		8173	RO & UV servicing work	MGM-IOMR	16.02.2022	04.30 pm	
11	17.02.2022	09.15 am	09.45 am		882	Split AC not working	Radiology Dept	17.02.2022	11.55 pm	
12	23.02.2022	09.00 am	10.55 am		2237	Lift No-07 Not working	Time Office	23.02.2022	04.10 pm	
13	27.02.2022	03.48 pm	04.15 pm		910	LED 15watt not working	CATH-LAB	01.03.2022	01.20 pm	
14	27.02.2022	09.55 am	11.10 am		1385	Cilling Fan not working	MSW	28.02.2022	12.45 pm	
15	27.02.2022	11.10 am	11.55 am		1277	Vaccum Motor not working	Biomedical Dept.	28.02.2022	03.10 pm	
16	28.02.2022	10.20 am	11.15 am		138	Cilling Fan not working	Physiotherapy	28.02.2022	11.50 am	
17	28.02.2022	09.05 am	09.40 am		1594	LED Tubelight not working	Med.OPD	28.02.2022	09.45 am	
18	28.02.2022	03.10 pm	03.20 pm		290	LED Tubelight not working	Physiotherapy	01.03.2022	11.30 am	
19	28.02.2022	03.48 pm	04.10 pm		886	LED 15watt not working	Radiology Dept	01.03.2022	11.35 am	
20	28.02.2022	10.10 am	10.45 am		3842	VRV Not working	Dialysis	28.02.2022	04.20 pm	
21	28.02.2022	11.00 am	11.45 am		926	FCU Not working	Labour Room	28.02.2022	05.00 pm	
22	28.02.2022	11.45 am	12.20 pm		143	Cilling Fan not working	FSW	28.02.2022	12.45 pm	
23	28.02.2022	09.05 am	12.30 pm		1386	Fan Regulator not working	MSW	28.02.2022	01.00 pm	
24	28.02.2022	10.45 am	11.55 am		6018	LED Tubelight not working	OT Complex	28.02.2022	03.30 pm	
25	01.03.2022	11.42 am	11.45 am		1328	Tharmameter not working	ICU	01.03.2022	11.50 am	
26	01.03.2022	11.38 am	11.45 am		2709	Tharmameter not working	New Deluxe	01.03.2022	12.05 pm	
27	01.03.2022	10.40 am	11.05 am		6019	LED Light not Working	OT Complex	01.03.2022	12.10 pm	
28	01.03.2022	11.13 am	12.10 pm		7103	VRV Not working	Casulty	02.03.2022	09.45 am	
29	01.03.2022	02.37 pm	02.45 pm		292	Lift not working	C' Building	01.03.2022	04.50 pm	
30	01.03.2022	10.57 am	11.15 am		1960	Split AC Servicing work	Pharmacology Dept.			Work in progress
31	01.03.2022	02.40 pm	03.10 pm		6706	Electrical problame	MCRI OPD	02.03.2022	10.05 am	
32	02.03.2022	09.45 am	10.00 am		1687	Electrical problame	Ex.Deluxe	02.03.2022	10.00 am	
33	02.03.2022	10.12 am	10.12 am		1686	LED 15watt not working	Ex.Deluxe	02.03.2022	02.30 pm	
34	02.03.2022	11.50 am	12.00 pm		2972	X-Ray Box not working	MICU	02.03.2022	12.20 pm	
35	02.03.2022	11.00 am	11.10 am		140	LED Tubelight not working	Physiotherapy	03.03.2022	11.10 am	

36	02.03.2022	11.00 am	11.35 am		1828	VRV Remote Required	Super Deluxe			Requirment work
37	03.03.2022	11.35 am	11.45 am		6022	LED Bulb not working	OT Complex	03.03.2022	12.25 pm	
38	03.03.2022	10.15 am	11.20 am		888	Split AC not working	Radiology Dept	03.03.2022	12.10 pm	
39	03.03.2022	12.25 pm	02.55 pm		596	Hanging fan not working	MCRI ICU			Work in progress
40	03.03.2022	01.20 pm	02.40 pm		144	LED Tubelight not working	FSW	07.03.2022	12.45 pm	
41	04.03.2022	11.05 am	11.20 am		1296	Cilling Fan not working	Anasitsa DEPT	04.03.2022	11.45 am	
42	04.03.2022	02.51 am	03.10 am		2344	Wall fan not working	Psy.WaRD	05.03.2022	02.30 pm	
43	05.03.2022	10.59 am	11.20 am		5302	LED 15watt not working	Blood Bank	05.03.2022	02.20 pm	
44	05.03.2022	09.45 am	09.55 am		4345	Cilling Fan not working	OBGY	05.03.2022	12.00 pm	
45	05.03.2022	03.00 pm	03.10 pm		1830	Tharmameter not working	Super Deluxe	05.03.2022	03.10 pm	
46	05.03.2022	03.50 pm	04.00 pm		1162	X-Ray Box not working	Urology Dept.	05.03.2022	04.23 pm	
47	05.03.2022	11.15 am	11.45 am		298	Switch Board not working	MJPJAY ward	08.03.2022	02.35 pm	
48	05.03.2022	10.59 am	12.10 pm		5303	Deep Freez not working	Blood bank	08.03.2022	11.30 am	
	Pending work									
1	21.02.2022	04.03 pm	04.15 pm		906	Split AC not working	CATH-LAB	03.03.2022	02.40 pm	
2	26.02.2022	02.00 pm	02.30 pm		2242	Lift No-07 Not working	Time Office	26.02.2022	04.15 pm	

Total Complaint	50
Pending Complaint	2
Complete Complaint	48
Complaint Precentrage	96%

M.V.Gaikwad
MGM Aurangabad

Electrical Engineer
MGM Aurangabad

Technical Executive
MGM Aurangabad

Electrical Supervisor
MGM Aurangabad

MGM MEDICAL COLLEGE & HOSPITAL

ELECTRICAL MAINTANCE REPORT 07/03/2022 to ~~/03/2022~~ 13.03.2022

Sr.No.	Received Date	Time	Attende Time	Response Time	Cpmplaint No.	Nature Of Complent	Name Of Department	Date Of Complation	Close Time	Remark
1	07.03.2022	10.19 am	10.49 am		6710	Switch Board not working	MCRI OPD-14	07.03.2022	11.00 am	
2	07.03.2022	02.30 pm	02.30 pm		929	Focus lamp not working	Labour Room	07.03.2022	03.30 pm	
3	07.03.2022	03.03 pm	03.30 pm		5304	Deep Freez not working	Blood Bank			Work in progress
4	07.03.2022	12.45 pm	01.45 pm		927	Focus lamp not working	Labour Room	09.03.2022	10.45 am	
5	07.03.2022	09.20 am	10.10 am		780	Exhouast Fan not working	Central Lab.	09.03.2022	11.55 am	
6	07.03.2022	03.03 pm	03.15 pm		5305	LED 15watt not working	Blood bank	08.03.2022	03.00 pm	
7	07.03.2022	11.23 am	11.55 am		4816	LED light not Working	Nephrology ward	07.03.2022	03.45 pm	
8	08.03.2022	10.10 am	10.30 am		325	X-Ray Box not working	Endoscophy	08.03.2022	10.30 am	
9	08.03.2022	09.45 am	10.10 am		4347	LED 15watt not working	OBGY 1st	08.03.2022	10.10 am	
10	08.03.2022	10.15 am	03.00 pm		5306	Split AC not working	Blood bank	08.03.2022	03.05 pm	
11	08.03.2022	02.42 pm	02.55 pm		266	LED Tubelight & Cilling fan not work	OPD-238	08.03.2022	03.45 pm	
12	09.03.2022	11.30 am	11.45 am		6713	FCU Not working	MCRI OPD-19	12.03.2022	02.30 pm	
13	09.03.2022	04.00 pm	04.15 pm		326	LED 15watt not working	Endoscophy			Work in progress
14	10.03.2022	10.30 am	10.55 am		1928	LED Tubelight not working	Pead.ward	10.03.2022	02.40 pm	
15	10.03.2022	11.35 am	12.10 pm		597	Gizar not working	MCRI ICU	12.03.2022	02.30 pm	
16	10.03.2022	01.00 pm	02.00 pm		892	USG Light not working	Radiology Dept	12.03.2022	02.05 pm	
17	11.03.2022	12.23 pm	12.30 pm		4602	Electrical problame	MMW	11.03.2022	12.40 pm	
18	11.03.2022	09.30 am	10.00 am		6918	Switch Board not working	SICU	11.03.2022	10.15 am	
19	11.03.2022	01.45 pm	02.10 pm		1697	LED 15watt not working	CCU+CVTS	11.03.2022	04.00 pm	
20	11.03.2022	03.08 pm	03.15 pm		1839	Cilling Fan not working	Super Deluxe	11.03.2022	03.35 pm	
21	11.03.2022	03.05 pm	04.00 pm		1470	Gizar not working	Opthal OPD	12.03.2022	01.05 pm	
22	11.03.2022	12.00 pm	12.00 pm		1392	Cilling Fan not working	MSW	12.03.2022	12.00 pm	
23	11.03.2022	12.53 pm	12.55 pm		2254	Lift No-06 Not working	Time Office	12.03.2022	09.00 am	
24	11.03.2022	01.10 pm	01.30 pm		2979	Code Blue cable laying work	MICU	12.03.2022	10.00 am	
25	12.03.2022	11.20 am	11.55 am		6033	Switch Board not working	OT Complex	12.03.2022	03.15 pm	
26	12.03.2022	12.20 pm	12.45 pm		6035	X-Ray Box not working	OT Complex	12.03.2022	03.00 pm	
27	12.03.2022	11.20 am	12.30 pm		6034	LED Tubelight not working	OT Complex	12.03.2022	03.10 pm	
28	12.03.2022	03.20 pm	03.20 pm		6036	Switch Board not working	OT Complex	12.03.2022	03.20 pm	
29	12.03.2022	04.00 pm	04.15 pm		7111	Switch Board not working	Casulty	12.03.2022	04.30 pm	
30	12.03.2022	10.44 am	10.44 am		824	Standing Fan not Working	Central Store	12.03.2022	04.00 pm	
31	12.03.2022	03.00 pm	03.15 pm		7112	Wall fan not working	Casulty	12.03.2022	04.25 pm	
32	13.03.2022	11.00 am	01.00 pm		Letter	UPS Conection work (OT No-05)	OT Complex	13.03.2022	02.40 pm	
33	12.03.2022	12.45 pm	02.55 pm		2871	Switch Board not working	EICU	14.03.2022	10.15 am	

Pending work

									Work in progress
1	01.03.2022	10.57 am	11.15 am		1960	Split AC Servicing work	Pharmacology Dept.		Work in progress
2	02.03.2022	11.00 am	11.35 am		1828	VRV Remote Required	Super Deluxe		Work in progress
3	03.03.2022	12.25 pm	02.55 pm		596	Hanging fan not working	MCRI ICU		
4	27.02.2022	02.00 pm	02.30 pm		1385	Cilling Fan not working	MSW	06.03.2022 02.40 pm	

Total Complaint	37
Pending Complaint	5
Complete Complaint	32
Complaint Precentrage	86%

M.V.Gaikwad
MGM Aurangabad

Electrical Engineer
MGM Aurangabad

Technical Executive
MGM Aurangabad

Electrical Supervisor
MGM Aurangabad

MGM MEDICAL COLLEGE & HOSPITAL

ELECTI CAL MAINTANCE REPORT 14/03/2022 to 2(3/2022 20.03.2022

Sr.No.	Received Date	Time	Attende Time	Response Time	Cpmplaint No.	Nature Of Complent	Name Of Department	Date Of Complation	Close Time	Remark
1	14.03.2022	10.30 am	11.55 am		4245	Switch Board not working	OBGY ICU	14.03.2022	12.10 pm	
2	14.03.2022	04.05 pm	04.15 pm		7410	Electrical problame	Anatomy	14.03.2022	04.15 pm	
3	14.03.2022	10.26 am	10.45 am		6039	OT lamp not working	OT No-06th			Work in progress
4	14.03.2022	02.20 pm	04.10 pm		1809	Cat-06 Cable laying	Medical Store	14.03.2022	05.00 pm	
5	14.03.2022	11.00 am	12.30 pm		Letter	Mock drill	Casulty	14.03.2022	12.30 pm	
6	15.03.2022	02.00 pm	02.15 pm		148	Cilling Fan not working	FSW	15.03.2022	02.35 pm	
7	15.03.2022	09.45 am	12.20 pm		6037	Switch Board not working	OT Complex	15.03.2022	05.30 pm	
8	15.03.2022	09.10 am	11.10 am		Letter	LED Tubelight not working	Parking	16.03.2022	04.00 pm	
9	15.03.2022	11.03 am	11.55 am		6716	Switch Board not working	MCRI OPD	16.03.2022	11.00 am	
10	15.03.2022	11.20 am	12.30 pm		283	LED 15watt not working	Nephrology ward	16.03.2022	01.15 pm	
11	15.03.2022	12.09 pm	02.45 pm		2352	Switch Board not working	Psy.Ward	16.03.2022	10.30 am	
12	16.03.2022	10.13 am	10.15 am		6044	Switch Board not working	OT Complex	16.03.2022	10.34 am	
13	16.03.2022	09.20 am	09.45 am		7120	Electrical problame	Casulty	21.03.2022	01.05 pm	
14	16.03.2022	09.55 am	11.30 am		2989	Switch Board not working	MICU	16.03.2022	12.00 pm	
15	16.03.2022	12.35 pm	12.48 pm		2423	Tharmameter not working	Covid lab	16.03.2022	12.48 pm	
16	16.03.2022	12.45 pm	01.45 pm		2991	LED 15watt not working	MICU	16.03.2022	01.45 pm	
17	16.03.2022	11.48 am	11.55 am		2258	Lift No-06 Not working	Time Office	17.03.2022	10.55 am	
18	16.03.2022	11.53 am	03.15 pm		328	Switch Board not working	Endoscophy	16.03.2022	03.39 pm	
19	16.03.2022	04.00 pm	04.45 pm		2260	Wall fan not working	Time Office	16.03.2022	05.40 pm	
20	16.03.2022	05.45 pm	06.20 pm		559	Switch Board not working	Old Deluxe	16.03.2022	06.20 pm	
21	16.03.2022	03.00 pm	03.50 pm		1149	Switch Board not working	M.Ortho ward	17.03.2022	03.50 pm	
22	17.03.2022	03.45 pm	04.00 pm		1698	LED 15watt not working	CCU+CVTS	17.03.2022	04.00 pm	
23	17.03.2022	12.48 pm	02.30 pm		3023	Refregator not working	Microbiology			Work in progress
24	17.03.2022	07.40 am	07.55 am		2261	Lift No-06 Not working	Time Office	17.03.2022	10.55 am	
25	17.03.2022	11.25 am	11.55 am		Letter	Cat-06 Cable laying	Saket book	20.03.2022	11.55 am	
26	17.03.2022	02.15 pm	03.45 pm		2724	LED 15watt not working	Quality Dept.	17.03.2022	04.30 pm	
27	17.03.2022	08.15 am	09.00 am		2262	Lift No-06 Not working	Time Office	17.03.2022	10.55 am	
28	17.03.2022	01.35 pm	02.20 pm		6720	LED 15watt not working	Account Department	17.03.2022	04.00 pm	
29	18.03.2022	08.55 am	09.00 am		6923	Switch Board not working	SICU	18.03.2022	06.30 pm	
30	19.03.2022	10.20 am	10.45 am		5148	Switch Board not working	NICU	19.03.2022	12.20 pm	
31	19.03.2022	10.20 am	10.45 am		390	Switch Board not working	Labour Room	21.03.2022	12.40 pm	
32	19.03.2022	11.55 am	12.12 pm		1697	Refregator not working	Ex.Deluxe	19.03.2022	12.27 pm	
33	19.03.2022	11.55 am	12.00 pm		1696	Switch Board not working	Ex.Deluxe	19.03.2022	12.27 pm	
34	19.03.2022	12.20 pm	12.45 pm		Telephone	Extention Board requirement-01	Exam cell	19.03.2022	12.45 pm	
35	19.03.2022	10.05 am	10.30 am		4100	Cooler not Working	OBGY OPD	21.03.2022	10.24 am	

	Pending work								
1	01.03.2022	10.57 am	11.15 am		196	Split AC Servicing work	Pharmacolo Dept.	21.03.2022	11.45 am	
2	02.03.2022	11.00 am	11.35 am		1828	VRV Remote Required	Super Deluxe	21.03.2022	10.30 am	
3	03.03.2022	12.25 pm	02.55 pm		596	Hanging fan not working	MCRI ICU			Work in progress
4	07.03.2022	03.03 pm	03.30 pm		5304	Deep Freez not working	Blood Bank			Work in progress
5	09.03.2022	04.00 pm	04.15 pm		326	LED 15watt not working	Endoscophy	17.03.2022	10.20 am	

Total Complaint	40
Pending Complaint	4
Complete Complaint	36
Complaint Precentrage	90%

M.V.Gaikwad
MGM Aurangabad

Electrical Engineer
MGM Aurangabad

Technical Executive(Elect.)
MGM Aurangabad

Electrical Supervisor
MGM Aurangabad

MGM MEDICAL COLLEGE & HOSPITAL

ELECTI AL MAINTANCE REPORT 21/03/2022 to 2 3/2022 27.03.2022

Sr.No.	Received Date	Time	Attende Time	Response Time	Cpmplaint No.	Nature Of Complent	Name Of Department	Date Of Complation	Close Time	Remark
1	21.03.2022	11.15 am	11.35 am		4354	Focus lamp not working	OBGY Ward	21.03.2022	12.00 pm	
2	21.03.2022	04.35 pm	05.00 pm		1466	Switch Board not working	Opthal Ward	21.03.2022	05.10 pm	
3	21.03.2022	11.30 am	11.30 am		6925	Switch Board not working	SICU	21.03.2022	11.34 am	
4	21.03.2022	02.28 pm	03.10 pm		6049	LED Tubelight not working	OT Complex	22.03.2022	03.00 pm	
5	22.03.2022	09.50 am	10.45 am		2140	Cilling Fan not working	OPD Regist.	22.03.2022	11.00 am	
6	22.03.2022	09.32 am	10.26 am		91	LED Tubelight not working	ENT OPD	22.03.2022	10.35 am	
7	22.03.2022	04.30 pm	04.55 pm		6602	Exhouast Fan not working	MS Office			Work in progress
8	22.03.2022	11.05 am	12.15 pm		4355	Cilling Fan not working	OBGY-1st	22.03.2022	12.31 pm	
9	22.03.2022	03.39 pm	03.50 pm		6601	Air Cooler not working	MS Office	22.03.2022	03.40 pm	
10	23.03.2022	01.20 pm	04.15 pm		1480	Cilling Fan Checking	ENT Ward	23.03.2022	04.15 pm	
11	23.03.2022	11.22 am	11.45 am		4356	Cilling Fan not working	OBGY-1st	25.03.2022	10.45 am	
12	23.03.2022	09.05 am	09.25 am		2548	Cilling Fan not working	Opthal OPD	24.03.2022	10.00 am	
13	24.03.2022	12.00 pm	12.45 pm		6726	LED light not Working	MCRI Resi.cabin	24.03.2022	01.30 pm	
14	24.03.2022	11.10 am	12.35 pm		341	Switch Board not working	School of Bio-Med.	25.03.2022	12.15 pm	
15	24.03.2022	11.30 am	03.45 pm		3253	LED Tubelight not working	Pead.ward	25.03.2022	09.45 am	
16	24.03.2022	11.05 am	12.15 pm		6304	LED Bulb not working	Ex.Deluxe	25.03.2022	05.00 pm	
17	24.03.2022	11.45 am	02.55 pm		932	LED Bulb not working	Labour Room	28.03.2022	04.10 pm	
18	24.03.2022	02.34 pm	03.10 pm		2141	Switch Board not working	OPD No-251	26.03.2022	01.00 pm	
19	24.03.2022	12.00 pm	02.55 pm		951	Switch Board not working	CVTS	25.03.2022	12.15 pm	
20	24.03.2022	12.30 pm	02.55 pm		2728	Cilling fan Regulater not working	New Deluxe	25.03.2022	11.45 am	
21	25.03.2022	11.00 am	11.15 am		933	Switch Board not working	Labour Room	25.03.2022	11.15 am	
22	25.03.2022	10.10 am	02.20 pm		4358	Switch Board not working	OBGY-1st	25.03.2022	03.10 pm	
23	25.03.2022	01.15 pm	02.20 pm		934	LED light not Working	Labour Room	25.03.2022	03.20 pm	
24	25.03.2022	10.10 am	11.35 am		4357	Cilling Fan not working	OBGY-1st	25.03.2022	02.55 pm	
25	25.03.2022	04.00 pm	04.45 pm		2266	1.5TR Split AC not working	Resistarar Office			Work in progress
26	25.03.2022	12.10 pm	12.55 pm		90	Water cooler not working	School of Bio-Med.			Work in progress
27	25.03.2022	03.16 pm	04.30 pm		572	Cilling Fan not working	Old Deluxe	26.03.2022	04.30 pm	
28	25.03.2022	10.03 am	10.45 am		2587	Air Cooler not working	CSSD	29.03.2022	11.05 am	
29	25.03.2022	03.14 pm	03.30 pm		773	Cilling fan Regulater not working	Old Deluxe	26.03.2022	04.00 pm	
30	25.03.2022	01.35 pm	02.20 pm		6603	1.5TR Split AC not working	CMS Office			Work in progress
31	25.03.2022	02.56 pm	03.15 pm		2549	LED Tubelight not working	Optholmology Dept.	26.03.2022	10.15 am	
32	25.03.2022	02.30 pm	03.10 pm		314	Switch Board not working	CATH-LAB	26.03.2022	10.30 am	
33	26.03.2022	09.15 am	10.10 am		2301	Electrical problame	OPD OBGY	26.03.2022	12.45 pm	
34	26.03.2022	11.30 am	12.20 pm		1012	Water cooler not working	MJPJAY			Work in progress
35	26.03.2022	01.10 pm	02.40 pm		1346	1.5TR Split AC not working	Isolation ICU			Work in progress
36	26.03.2022	04.03 pm	04.55 pm		4359	Switch Board not working	OBGY 1st	26.03.2022	04.55 pm	
37	26.03.2022	03.13 pm	04.25 pm		1482	Cilling Fan not working	Opthal Ward	28.03.2022	10.25 am	
38	26.03.2022	04.00 pm	04.35 pm		2302	Exhouast Fan not working	OPD No-252	28.03.2022	12.30 pm	

Pending work									
1	03.03.2022	12.25 pm	02.55 pm		59(	Hanging fan not working	MCRI ICU			Work in progress
2	07.03.2022	03.03 pm	03.30 pm		5304	Deep Freez not working	Blood Bank			Work in progress
3	14.03.2022	10.26 am	10.45 am		6039	OT lamp not working	OT No-06th			Work in progress
4	17.03.2022	12.48 pm	02.30 pm		3023	Refregator not working	Microbiology			Work in progress
5	19.03.2022	11.20 am	11.55 am		930	Switch Board not working	Labour Room	21.03.2022	12.40 pm	

Total Complaint	43
Pending Complaint	10
Complete Complaint	33
Complaint Precentrage	77%

M.V.Gaikwad
MGM Aurangabad

Electrical Engineer
MGM Aurangabad

Technical Executive(Elect.)
MGM Aurangabad

Electrical Supervisor
MGM Aurangabad

MGM MEDICAL COLLEGE & HOSPITAL

ELECTRICAL MAINTANCE REPORT 28/03/2022 to ~~01/04/2022~~ 02.04.2022

Sr.No.	Received Date	Time	Attende Time	Response Time	Cpmplaint No.	Nature Of Complent	Name Of Department	Date Of Complation	Close Time	Remark
1	28.03.2022	11.15 am	02.20 pm		2268	Telephone cable laying work.	OT Complex	28.03.2022	04.10 pm	
2	28.03.2022	09.25 am	10.10 am		548	Cilling Fan not working	Psyciology OPD	28.03.2022	11.20 am	
3	28.03.2022	12.36 pm	01.00 pm		268	Air Cooler not working	OPD Complex	28.03.2022	01.00 pm	
4	28.03.2022	12.01 pm	02.15 pm		1848	Cilling Fan not working	Super Deluxe	28.03.2022	03.40 pm	
5	28.03.2022	03.23 pm	03.45 pm		2677	Switch Board not working	Exam cell	28.03.2022	04.10 pm	
6	28.03.2022	09.41 am	10.45 am		2267	Lift No-06 Not working	Time Office	29.03.2022	11.15 am	
7	29.03.2022	12.31 pm	12.45 pm		6061	AHU Filter cleaning	OT Complex	29.03.2022	04.10 pm	
8	29.03.2022	11.00 am	11.15 am		147	Switch Board not working	Psysiotherapy Buil.	29.03.2022	12.30 pm	
9	29.03.2022	12.30 pm	12.45 pm		6060	FCU Not working	OT Complex	29.03.2022	02.10 pm	
10	29.03.2022	12.20 pm	12.35 pm		5162	X-Ray Box not working	NICU	31.03.2022	02.00 pm	
11	29.03.2022	09.20 am	10.10 am		151	Cilling fan & Switch Bord not working	FSW	31.03.2022	02.45 pm	
12	29.03.2022	03.00 pm	04.10 pm		2363	LED light not Working	Psyciology ward	30.03.2022	11.10 am	
13	29.03.2022	11.07 am	02.00 pm		4360	Air Cooler not working	OBGY ward-Ist	29.03.2022	03.00 pm	
14	30.03.2022	10.20 am	11.10 am		764	Air Cooler not working	OBGY Ward	02.04.2022	02.35 pm	
15	30.03.2022	11.35 am	11.55 am		74	AHU Filter cleaning	MICU	30.03.2022	04.15 pm	
16	30.03.2022	02.10 pm	02.35 pm		1485	Cilling Fan not working	Opthal Ward	30.03.2022	04.00 pm	
17	30.03.2022	03.00 pm	03.55 pm		4596	Water cooler not working	Biochemistry Dept.			Work in progress
18	30.03.2022	05.40 pm	05.55 pm		2270	Lift No-06 Not working	Time Office	30.03.2022	05.55 pm	
19	30.03.2022	10.01 am	11.35 am		344	Switch Board not working	School of Bio-Med.	31.03.2022	12.05 pm	
20	30.03.2022	03.03 pm	04.15 pm		2366	Wall fan not working	Psyciology ward	31.03.2022	11.15 am	
21	31.03.2022	10.15 am	11.05 am		333	LED light not Working	Endoscophy	31.03.2022	11.30 am	
22	31.03.2022	10.20 am	11.10 am		152	Cilling Fan not working	FSW			Work in progress
23	31.03.2022	04.24 pm	04.50 pm		3610	Cilling Fan not working	MCRI ICU			Work in progress
24	31.03.2022	12.53 pm	01.00 pm		3335	Cilling Fan not working	Skin VD	01.04.2022	03.30 pm	
25	31.03.2022	12.50 pm	02.40 pm		6509	Switch Board not working	Pathalogy	31.03.2022	03.40 pm	
26	31.03.2022	11.30 am	12.10 pm		1853	Cilling Fan not working	Super Deluxe	31.03.2022	02.30 pm	
27	01.04.2022	11.00 am	11.15 am		544	Switch Board not working	Dental OPD	01.04.2022	11.30 am	
28	01.04.2022	10.20 am	10.45 am		1152	Cilling Fan not working	M.Ortho ward	02.04.2022	02.45 pm	
29	01.04.2022	12.30 pm	12.45 pm		2607	Cilling Fan not working	Lecture Hall	03.04.2022	05.15 pm	
30	01.04.2022	12.00 pm	12.20 pm		2700	Air Cooler not working	CSSD			Work in progress
31	01.04.2022	11.20 am	12.00 pm		2551	Refregator not working	Opthalmology			Work in progress
32	01.04.2022	10.00 am	10.10 am		3063	Switch Board not working	FMW	02.04.2022	03.50 pm	
33	01.04.2022	02.00 pm	04.00 pm		009/22	UPS Conection work (OT No-06 & 08	OT Complex	01.04.2022	04.00 pm	
34	02.04.2022	04.26 pm	05.00 pm		Letter	Cilling fan, LED Tubelight, Switch Bo	Inst.Physiotheraphy	03.03.2022	04.26 pm	
35	02.04.2022	09.50 am	10.00 am		480	LED Tubelight not working	New Pead.	02.04.2022	10.00 am	
36	02.04.2022	11.30 am	11.55 am		4362	Air Cooler not working	OBGY Ward	02.04.2022	02.00 pm	

	Pending work									
1	03.03.2022	12.25 pm	02.55 pm		596	Hanging fan not working	MCRI ICU			Work in progress
2	07.03.2022	03.03 pm	03.30 pm		5304	Deep Freez not working	Blood Bank			Work in progress
3	14.03.2022	10.26 am	10.45 am		6039	OT lamp not working	OT No-06th			Work in progress
4	17.03.2022	12.48 pm	02.30 pm		3023	Refregator not working	Microbiology			Work in progress
5	22.03.2022	04.30 pm	04.55 pm		6602	Exhouast Fan not working	MS Office			Work in progress
6	25.03.2022	04.00 pm	04.45 pm		2266	1.5TR Split AC not working	Resistarar Office			Work in progress
7	25.03.2022	12.10 pm	12.55 pm		90	Water cooler not working	School of Bio-Med.			Work in progress
8	25.03.2022	01.35 pm	02.20 pm		6603	1.5TR Split AC not working	CMS Office	29.03.2022	02.40 pm	
9	26.03.2022	11.30 am	12.20 pm		1012	Water cooler not working	MJPJAY			Work in progress
10	26.03.2022	01.10 pm	02.40 pm		1346	1.5TR Split AC not working	Isolation ICU	29.03.2022	10.10 am	

Total Complaint	46
Pending Complaint	13
Complete Complaint	33
Complaint Precentrage	72%

M.V.Gaikwad
MGM Aurangabad

Electrical Engineer
MGM Aurangabad

Technical Executive(Elect.)
MGM Aurangabad

Electrical Supervisor
MGM Aurangabad

MGM MEDICAL COLLEGE & HOSPITAL

ELECTRICAL MAINTANCE REPORT 03/04/2022 to 14/04/2022 10.04.2022

Sr.No.	Received Date	Time	Attende Time	Response Time	Cpmplaint No.	Nature Of Complent	Name Of Department	Date Of Complation	Close Time	Remark
1	03.04.2022	11.38 am	11.55 am		7705	Air Cooler not working	OBGY Dept.	03.04.2022	04.00 pm	
2	03.04.2022	11.50 am	02.10 pm		6073	LED Tubelight not working OT No-08	OT Complex	05.04.2022	02.10 pm	
3	03.04.2022	03.59 pm	04.15 pm		6935	Gizar not working	SICU	05.04.2022	03.30 pm	
4	03.04.2022	02.10 pm	02.55 pm		91	New Electrical Fitting work	School of Bio-Med.	05.04.2022	01.00 pm	
5	04.04.2022	12.15 pm	02.55 pm		95	New Switch Board Requirement	School of Bio-Med.	05.04.2022	05.10 pm	
6	04.04.2022	03.20 pm	04.15 pm		1018	New Switch Board Requirement	Medicin Dept.	05.04.2022	02.31 pm	
7	04.04.2022	11.35 am	12.10 pm		1689	Water filter not working	Ex.Deluxe	04.04.2022	02.10 pm	
8	04.04.2022	09.45 am	11.15 am		2246	Water filter not working	7th Floor Tarace	04.04.2022	04.15 pm	
9	04.04.2022	04.10 pm	04.35 pm		Letter	LED tubelight, Exhouast Fan & Switcl	Hospital Building	06.04.2022	11.20 am	
10	04.04.2022	09.56 am	10.30 am		2678	Split AC not working	Exam cell	04.04.2022	03.55 pm	
11	04.04.2022	03.35 pm	04.10 pm		7415	Refregator not working	Anatomy	06.04.2022	01.55 pm	
12	04.04.2022	11.15 am	02.10 pm		2247	Water filter not working	6th floor	04.04.2022	05.10 pm	
13	04.04.2022	02.31 pm	02.31 pm		2057	Standing Fan not Working	MJPJAY	04.04.2022	05.30 pm	
14	05.04.2022	11.47 am	12.10 pm		803	Split AC not working	07.04.2022	06.04.2022	03.22 pm	
15	05.04.2022	02.30 pm	03.00 pm		545	Exhouast Fan not working	Dental OPD	06.04.2022	02.45 pm	
16	05.04.2022	02.49 pm	03.55 pm		2591	LED Tubelight not Working	Autoclove Dept.	06.04.2022	04.10 pm	
17	05.04.2022	09.15 am	10.00 am		2278	LED Tubelight not working	Time Office	05.04.2022	10.00 am	
18	05.04.2022	03.08 pm	04.15 pm		587	Water cooler not working	Old Deluxe	06.04.2022	10.45 am	
19	05.04.2022	06.15 pm	06.20 pm		2280	Lift No-02 Not working	Time Office	06.04.2022	05.55 pm	
20	05.04.2022	01.48 pm	02.20 pm		917	Switch Board not working	CATH-LAB	07.04.2022	02.55 pm	
21	05.04.2022	01.30 pm	02.20 pm		1350	Split AC not working	Step down ICU	07.04.2022	02.55 pm	
22	06.04.2022	11.13 am	11.55 am		6077	LED Tubelight not working	OT Complex	06.04.2022	03.50 pm	
23	06.04.2022	03.03 pm	03.40 pm		2519	Air Cooler not working	Record Section	07.04.2022	11.55 am	
24	06.04.2022	12.07 pm	12.55 pm		161	AHU Filter cleaning	PICU	07.04.2022	10.55 am	
25	06.04.2022	04.24 pm	04.55 pm		3066	Switch Board not working	FMW	07.04.2022	11.45 am	
26	06.04.2022	05.45 pm	05.45 pm		2059	Split AC not working	MJPJAY	06.04.2022	05.51 pm	
27	06.04.2022	02.05 pm	02.25 pm		2307	LED Tubelight not Working	Central Store	06.04.2022	02.39 pm	
28	07.04.2022	09.21 am	09.40 am		1491	Gizar not working	ENT Ward	07.04.2022	10.45 am	
29	07.04.2022	09.20 am	10.10 am		768	Air Cooler not working	OBGY Iind	07.04.2022	02.20 pm	
30	07.04.2022	11.30 am	11.55 am		2282	Cilling Fan Replacement work	Time Office	09.04.2022	02.30 pm	
31	07.04.2022	02.00 pm	02.30 pm		1938	Cilling Fan not working	Pead.ward	07.04.2022	04.15 pm	
32	07.04.2022	03.30 pm	04.10 pm		2371	Split AC not working	Psychetric ward			Work in progress
33	07.04.2022	09.05 am	09.25 am		1492	LED light not Working	Hemotology ICU	07.04.2022	10.15 am	
34	08.04.2022	02.00 pm	02.20 pm		6081	Humidity Meter Replace (OT-10)	OT Complex	08.04.2022	03.30 pm	
35	08.04.2022	11.10 am	11.45 am		1155	Cilling Fan not working	M.Ortho ward	08.04.2022	04.25 pm	
36	08.04.2022	10.35 am	10.45 am		769	LED 18watt Panel	OBGY Ward	08.04.2022	10.45 am	
37	08.04.2022	01.00 pm	02.55 pm		2284	Water cooler not working	Time Office	08.04.2022	03.15 pm	
38	08.04.2022	02.29 pm	03.11 pm		2285	Lift No-02 Not working	Time Office	09.04.2022	10.00 am	

				1018	Air Cooler not working	MJPJAY	08.04.2022	03.38 pm	
40	09.04.2022	09.40 am	10.00 am	51	FCU Not working	NICU	09.04.2022	04.00 pm	
41	09.04.2022	09.10 am	09.25 am	4360	All Electrical Cheacking	OBGY Ist	09.04.2022	11.45 am	
42	09.04.2022	11.00 am	11.15 am	4367	Cilling Fan Fitting -02	OBGY Ist	09.04.2022	12.55 pm	
43	09.04.2022	10.41 am	10.55 am	1019	Switch Board not working	MJPJAY	09.04.2022	12.55 pm	
44	09.04.2022	02.45 pm	03.00 pm	6741	Switch Board not working	MCRI OPD	09.04.2022	04.45 pm	
45	09.04.2022	03.00 pm	03.25 pm	1496	LED Tubelight not working	ENT Ward	11.04.2022	12.25 pm	
46	09.04.2022	01.00 pm	02.40 pm	2286	VRV Not working	Dr. Hostel	10.04.2022	11.00 am	
47	09.04.2022	03.00 pm	03.40 pm	588	Exhouast Fan not working	Old Deluxe			Work in progress
48	09.04.2022	12.45 pm	03.10 pm	2679	Casset AC not working	Exam cell			Work in progress
	Pending work								
1	03.03.2022	12.25 pm	02.55 pm	596	Hanging fan not working	MCRI ICU	06.04.2022	04.10 pm	
2	07.03.2022	03.03 pm	03.30 pm	5304	Deep Freez not working	Blood Bank	04.04.2022	10.30 am	
3	14.03.2022	10.26 am	10.45 am	6039	OT lamp not working	OT No-06th			Work in progress
4	17.03.2022	12.48 pm	02.30 pm	3023	Refregator not working	Microbiology	06.04.2022	11.35 am	
5	22.03.2022	04.30 pm	04.55 pm	6602	Exhouast Fan not working	MS Office	05.04.2022	12.30 pm	
6	25.03.2022	04.00 pm	04.45 pm	2266	1.5TR Split AC not working	Resistarar Office			Work in progress
7	25.03.2022	12.10 pm	12.55 pm	90	Water cooler not working	School of Bio-Med.			Work in progress
8	26.03.2022	11.30 am	12.20 pm	1012	Air cooler not working	MJPJAY	07.04.2022	04.00 pm	
9	30.03.2022	03.00 pm	03.55 pm	4596	Water cooler not working	Biochemistry Dept.	07.04.2022	12.35 pm	
10	31.03.2022	10.20 am	11.10 am	152	Cilling Fan not working	FSW	05.04.2022	02.30 pm	
11	31.03.2022	04.24 pm	04.50 pm	3610	Cilling Fan not working	MCRI ICU	06.04.2022	03.30 pm	
12	01.04.2022	12.00 pm	12.20 pm	2700	Air Cooler not working	CSSD	07.04.2022	11.35 am	
13	01.04.2022	11.20 am	12.00 pm	2551	Refregator not working	Opthalmology	06.04.2022	10.20 am	
14	01.04.2022	10.05 am	10.15 am	935	Split AC not working	Labour Room	07.04.2022	01.20 pm	

Total Complaint	62
Pending Complaint	6
Complete Complaint	56
Complaint Precentrage	90%

M.V.Gaikwad
MGM-Aurangabad

Electrical Engineer
MGM Aurangabad

Technical Executive(Elect.)
MGM Aurangabad

Electrical Supervisor
MGM Aurangabad

MGM MEDICAL COLLEGE & HOSPITAL

ELECTRICAL MAINTANCE REPORT 11/04/2022 to ~~/04/2022~~ 17.04.2022

Sr.No.	Received Date	Time	Attende Time	Response Time	Cpmplaint No.	Nature Of Complent	Name Of Department	Date Of Complation	Close Time	Remark
1	11.04.2022	10.30 am	11.00 am		340	X-Ray Box not working	Endoscophy			Work in progress
2	11.04.2022	04.20 pm	04.55 pm		2289	Cilling fan Requirement	Time Office	12.04.2022	04.20 pm	
3	11.04.2022	10.55 am	11.10 am		2680	Switch Board not working	Exam cell	11.04.2022	02.45 pm	
4	11.04.2022	04.00 pm	04.55 pm		3594	Split AC not working	Cardac OT	15.04.2022	11.50 am	
5	11.04.2022	12.30 pm	12.45 pm		97	Split AC not working	School of Physiolopy	12.04.2022	3.20 pm	
6	11.04.2022	10.00 am	10.10 am		1278	Switch Board not working	Sequirity office	11.04.2022	11.45 am	
7	11.04.2022	01.38 am	02.10 pm		2463	Switch Board not working	Kt ICU	11.04.2022	02.45 pm	
8	11.04.2022	09.30 am	09.45 am		1020	LED light not Working	MJPJAY	11.04.2022	02.30 pm	
9	12.04.2022	12.05 pm	12.10 pm		940	Switch Board not working	Labour Room	12.04.2022	12.15 pm	
10	12.04.2022	02.49 pm	03.15 pm		450	LED Tubelight not working	Ortho OPD	13.04.2022	10.40 am	
11	12.04.2022	10.45 am	11.40 am		2061	Split AC not working	MJPJAY	12.04.2022	02.55 pm	
12	12.04.2022	11.48 am	12.10 pm		2291	Motor not working	STP Plant	13.04.2022	11.10 am	
13	12.04.2022	12.41 pm	03.50 pm		3070	LED Tubelight & Cilling fan not work	5th Floor waiting area	12.04.2022	03.50 pm	
14	12.04.2022	09.55 am	10.05 am		1022	Extension Board Not working	MJPJAY	12.04.2022	10.25 am	
15	12.04.2022	09.45 am	10.10 am		7133	LED Bulb not working	Casulty	12.04.2022	02.05 pm	
16	13.04.2022	10.20 am	10.45 am		2307	Focus lamp not working	OBGY OPD	13.04.2022	11.05 am	
17	13.04.2022	02.15 pm	02.40 pm		6750	Cilling Fan not working	MCRI OPD	13.04.2022	03.10 pm	
18	13.04.2022	04.30 pm	04.55 pm		591	Water filter not working	Old Deluxe	13.04.2022	04.55 pm	
19	13.04.2022	03.27 pm	04.15 pm		3114	Cilling Fan not working	Linen Department	15.04.2022	02.45 pm	
20	16.04.2022	11.30 am	11.55 am		1461	X-Ray Box not working	Opthal Ward	16.04.2022	10.20 am	
21	16.04.2022	11.30 am	11.45 am		6087	LED Tubelight not working	OT Complex	16.04.2022	02.35 pm	
22	16.04.2022	02.56 pm	03.05 pm		1860	Electrical problame	Super Deluxe	16.04.2022	04.00 pm	
23	16.04.2022	03.30 pm	04.15 pm		919	Pedastral fan not working	CATH-LAB	16.04.2022	05.30 pm	
24	16.04.2022	10.20 am	10.55 am		1365	Split AC not working	Step down ICU	18.04.2022	10.55 am	
						Pending work				
1	14.03.2022	10.26 am	10.45 am		6039	OT lamp not working	OT No-06th			Work in progress
2	25.03.2022	04.00 pm	04.45 pm		2266	1.5TR Split AC not working	Resistarar Office			Work in progress
3	25.03.2022	12.10 pm	12.55 pm		90	Water cooler not working	School of Bio-Med.			Work in progress
4	07.04.2022	03.30 pm	04.10 pm		2371	Split AC not working	Psychetric ward	14.04.2022	02.35 pm	
5	09.04.2022	03.00 pm	03.40 pm		588	Exhouast Fan not working	Old Deluxe	12.04.2022	02.25 pm	
6	09.04.2022	12.45 pm	03.10 pm		2679	Casset AC not working	Exam cell	11.04.2022	02.40 pm	

Total Complaint	3
Pending Complaint	4
Complete Complaint	26
Complaint Precentrage	87%

M.V.Gaikwad
MGM Aurangabad

Electrical Engineer
MGM Aurangabad

Technical Executive(Elect.)
MGM Aurangabad

Electrical Supervisor
MGM Aurangabad

MGM MEDICAL COLLEGE & HOSPITAL

ELECTRICAL MAINTANCE REPORT 17/04/2022 to 24.04.2022

Sr.No.	Received Date	Time	Attende Time	Response Time	Cpmplaint No.	Nature Of Complent	Name Of Department	Date Of Complation	Close Time	Remark
1	18.04.2022	10.05 am	10.30 am		1279	Switch Board not working	Biomedical Dept.	18.04.2022	01.00 pm	
2	18.04.2022	12.00 pm	12.35 pm		919	Exhouast Fan Requirement	Central Laibrary	20.04.2022	11.50 am	
3	18.04.2022	01.07 pm	01.25 pm		1939	Kazi Lift not working	"C' Building	18.04.2022	01.25 pm	
4	18.04.2022	01.08 pm	02.45 pm		1937	Electrical problame	"C' Building			Work in progress
5	18.04.2022	09.45 am	10.15 am		567	Wall fan not working	Old Deluxe	22.04.2022	01.00 pm	
6	18.04.2022	09.45 am	10.20 am		5406	LED Tubelight & Switch Board not w	M.Surjery ward	19.04.2022	10.45 am	
7	18.04.2022	12.29 pm	1245 pm		594	Switch Board not working	Old Deluxe	19.04.2022	02.45 pm	
8	18.04.2022	04.25 pm	04.55 pm		2294	Water filter not working	C Buuilding	20.04.2022	12.35 pm	
9	18.04.2022	01.30 pm	02.10 pm		7139	Switch Board not working	Casulty	18.04.2022	02.15 pm	
10	19.04.2022	10.30 am	10.35 am		942	Switch Board not working	Labour Room	19.04.2022	10.35 am	
11	19.04.2022	10.20 am	10.40 am		6754	Switch Board not working	MCRI OPD-08	19.04.2022	10.50 am	
12	19.04.2022	01.12 pm	02.05 pm		595	Cilling Fan Tubelight not working	Old Deluxe	19.04.2022	03.15 pm	
13	19.04.2022	02.40 pm	02.50 pm		4449	Cilling Fan Tubelight not working	F.Ortho ward	19.04.2022	03.55 pm	
14	19.04.2022	09.20 am	09.45 am		2296	Lift No-06 Not working	Time Office	19.04.2022	11.30 am	
15	19.04.2022	09.20 am	09.45 am		2297	Lift No-06 Not working	Time Office	19.04.2022	11.30 am	
16	19.04.2022	11.30 am	11.40 am		Letter	1.5TR Split AC Shifting to Gandheli I	HILL	19.04.2022	11.40 am	
17	20.04.2022	12.30 pm	12.40 pm		2290	Standing Fan not Working	Time Office	20.04.2022	01.00 pm	
18	20.04.2022	10.30 am	10.35 am		6321	Gizar not working	Ex.Deluxe	20.04.2022	10.30 am	
19	20.04.2022	11.35 am	12.05 pm		598	LED Light & Gizar not working	Old Deluxe	20.04.2022	12.55 pm	
20	20.04.2022	12.20 pm	12.55 pm		2682	Switch Board not working	Exam cell	20.04.2022	03.15 pm	
21	21.04.2022	10.10 am	10.45 am		6094	LED Tubelight not Working	OT Complex	21.04.2022	11.30 am	
22	21.04.2022	09.25 am	10.10 am		1678	LED Tubelight not working	Surgery OPD	21.04.2022	11.15 am	
23	21.04.2022	10.45 am	11.15 am		1209	Tharmameter not working	ENT Ward	21.04.2022	02.05 pm	
24	21.04.2022	09.15 am	10.00 am		2300	VRV Not working	Dr. Hostel			Work in progress
25	21.04.2022	11.00 am	11.30 am		3078	Refregator not working	FMW	23.04.2022	04.35 pm	
26	21.04.2022	12.15 pm	12.20 pm		1161	LED Tubelight not working	M.Ortho ward	21.04.2022	04.15 pm	
27	21.04.2022	03.15 pm	03.45 pm		1208	Cilling Fan not working	Opthamology	21.04.2022	04.20 pm	
28	21.04.2022	10.00 am	11.15 am		3079	LED Tubelight not Working	FMW	21.04.2022	12.51 pm	
29	21.04.2022	12.15 pm	12.25 pm		1160	Electrical problame	M.Ortho ward	21.04.2022	12.25 pm	
30	22.04.2022	03.25 pm	03.35 pm		4278	Switch Board not working	IT Department	23.04.2022	03.35 pm	
31	22.04.2022	03.30 pm	04.00 pm		4277	Split AC not working	IT Department	22.04.2022	04.15 pm	
32	22.04.2022	11.35 am	12.30 pm		1213	Air Cooler not working	ENT Ward	25.04.2022	10.45 am	
33	22.04.2022	12.30 pm	12.45 pm		2705	Extention Board not working	Old Deluxe	25.04.2022	02.50 pm	
34	22.04.2022	03.40 pm	04.10 pm		1925	Wall fan not working	MICU	25.04.2022	10.35 am	
35	22.04.2022	07.30 am	07.45 pm		702	Lift No-06 Not working	Time Office	23.04.2022	12.30 pm	

37	23.04.2022	11.50 am	12.10 pm		2706	Extentiob Boadr not Working	Old Deluxe	25.04.2022	02.50 pm	
38	23.04.2022	11.45 am	12.05 pm		124	Switch Board not working	MET Cell	23.04.2022	01.10 pm	
39	23.04.2022	12.47 pm	02.40 pm		3323	LED Tubelight not working	PSM Dept.	23.04.2022	02.40 pm	
40	23.04.2022	10.05 am	10.30 am		5312	Split AC not working	Blood Bank			Work in progress
41	23.04.2022	12.47 pm	12.55 pm		5314	Switch Board not working	Blood Bank	25.04.2022	11.10 am	
42	23.04.2022	11.30 am	11.45 am		5313	LED light not Working	Blood Bank	25.04.2022	11.05 pm	
43	23.04.2022	11.55 am	12.10 pm		6098	LED Tubelight not working	OT Complex	23.04.2022	11.45 am	
					7148	VRV Not working	Dr.Room Casualty	25.04.2022	11.20 am	
					Pending work					
1	14.03.2022	10.26 am	10.45 am		6039	OT lamp not working	OT No-06th	18.04.2022	12.35 pm	
2	25.03.2022	04.00 pm	04.45 pm		2266	1.5TR Split AC not working	Resistarar Office			Work in progress
3	25.03.2022	12.10 pm	12.55 pm		90	Water cooler not working	School of Bio-Med.			Work in progress
4	11.04.2022	10.30 am	11.00 am		340	X-Ray Box not working	Endoscophy			Work in progress

Total Complaint	47
Pending Complaint	6
Complete Complaint	41
Complaint Precentrage	87%

M.V.Gaikwad
MGM Aurangabad

Electrical Engineer
MGM Aurangabad

Technical Executive(Elect.)
MGM Aurangabad

Electrical Supervisor
MGM Aurangabad

MGM MEDICAL COLLEGE & HOSPITAL

ELECTRICAL MAINTANCE REPORT 25/04/2022 to 01.05.2022

01.05.2022

Sr.No.	Received Date	Time	Attende Time	Response Time	Cpmplaint No.	Nature Of Complent	Name Of Department	Date Of Complation	Close Time	Remark
1	25.04.2022	12.30 pm	12.55 pm		1026	LED Tubelight not working	MJPJAY	25.04.2022	02.45 pm	
2	25.04.2022	11.30 am	11.45 am		2466	Refregator not working	Kt ICU			Work in progress
3	26.04.2022	11.38 am	11.55 am		3115	Air Cooler not working	Linen Department			Work in progress
4	26.04.2022	09.35 am	09.55 am		7152	LED 15watt not working	Casulty	26.04.2022	12.20 pm	
5	26.04.2022	09.35 am	10.10 am		7153	LED Tubelight not working	Casulty	26.04.2022	11.35 am	
6	26.04.2022	09.45 am	10.55 am		2882	LED 15watt not working	EICU	26.04.2022	11.38 am	
7	26.04.2022	03.00 pm	03.35 pm		345	LED 15watt not working	Endoscophy	26.04.2022	03.41 pm	
8	26.04.2022	03.00 pm	03.10 pm		31	Cilling Fan not working	IVF Centare	26.04.2022	03.10 pm	
9	26.04.2022	01.40 pm	01.45 pm		4260	Split AC not working	OBGY ICU	26.04.2022	02.00 pm	
10	26.04.2022	02.33 pm	02.45 pm		1867	LED 15watt not working	Super Deluxe	27.04.2022	03.00 pm	
11	26.04.2022	12.20 pm	12.45 pm		4624	Refregator not working	MMW			Work in progress
12	26.04.2022	09.55 pm	10.55 pm		7155	Standing Fan not Working	Casulty	27.04.2022	03.30 pm	
13	27.04.2022	12.30 pm	12.45 pm		1219	Gizar not working	ENT Ward			Work in progress
14	27.04.2022	12.55 pm	02.35 pm		2065	Split AC not working	MJPJAY			Work in progress
15	28.04.2022	10.39 am	10.45 am		776	Cilling Fan not working	OBGY Ward-II	28.04.2022	11.00 am	
16	28.04.2022	01.55 pm	02.35 pm		104	FCU Not working	Radiology Dept	28.04.2022	04.00 pm	
17	28.04.2022	05.00 pm	05.10 pm		5410	LED Tubelight not working	FSW	30.04.2022	04.00 pm	
18	28.04.2022	10.05 am	10.45 am		2066	LED Tubelight not working	MJPJAY	28.04.2022	11.30 am	
19	28.04.2022	03.45 pm	04.10 pm		6320	VRV Not working	Ex.Deluxe	28.04.2022	06.55 pm	
20	28.04.2022	11.35 am	12.10 pm		287	VRV Not working	Nephrology ward	28.04.2022	03.25 pm	
21	28.04.2022	03.50 pm	04.00 pm		7419	Cilling Fan not working	Anatomy	28.04.2022	04.00 pm	
22	29.04.2022	10.35 am	10.45 am		346	LED 15watt not working	Endoscophy	29.04.2022	10.45 am	
23	29.04.2022	04.10 pm	04.55 pm		2381	Wall fan not working	Psychetric ward	30.04.2022	01.35 pm	
24	30.04.2022	03.10 pm	04.25 pm		33	VRV Not working	IVF Centare	30.04.2022	04.25 pm	
25	30.04.2022	11.35 am	11.55 am		4279	Split AC not working	IT Department			Work in progress
26	30.04.2022	10.20 am	10.45 am		5190	Cilling Fan not working	NICU			Work in progress
27	30.04.2022	09.20 am	09.45 am		1031	Air Cooler not working	MJPJAY			Work in progress
28	30.04.2022	04.10 pm	04.45 pm		3596	Split AC not working	Cardac OT			Work in progress
29	30.04.2022	01.15 pm	02.35 pm		1019	Electrical wiring work	Medicin Dept.			Work in progress
						Pending work				
1	25.03.2022	04.00 pm	04.45 pm		2266	1.5TR Split AC not working	Resistarar Office	26.04.2022	04.15 pm	
2	25.03.2022	12.10 pm	12.55 pm		90	Water cooler not working	School of Bio-Med.			Not Repaireble
3	11.04.2022	10.30 am	11.00 am		340	X-Ray Box not working	Endoscophy	25.04.2022	10.55 am	
4	18.04.2022	01.08 pm	02.45 pm		1937	Electrical problame	"C' Building			Work in progress
5	21.04.2022	09.15 am	10.00 am		2300	VRV Not working	Dr. Hostel	26.04.2022	12.55 pm	

7	23.04.2022	12.47 pm	02.40 pm		3078	Refregator not working	FMW	29.04.2022	10.30 am	Not Repaireble
					5312	Split AC not working	Blood Bank	27.04.2022	02.35 pm	

Total Complaint	36
Pending Complaint	11
Complete Complaint	25
Complaint Precentrage	69%

M.V.Gaikwad
MGM Aurangabad

Electrical Engineer
MGM Aurangabad

Technical Executive(Elect.)
MGM Aurangabad

Electrical Supervisor
MGM Aurangabad

MGM MEDICAL COLLEGE & HOSPITAL

ELECTRICAL MAINTANCE REPORT 16/05/2022 to 22/05/2022

Sr.No.	Received Date	Time	Attende Time	Response Time	Cpmplaint No.	Nature Of Complent	Name Of Department	Date Of Complation	Close Time	Remark
1	16.05.2022	10.20 am	12.10 pm		6129	Humidity Meter Replace (OT-03)	OT Complex	20.05.2022	11.45 am	
2	16.05.2022	10.00 am	10.20 am		2558	LED Tube;ight not working	Opthal OPD	16.05.2022	10.35 am	
3	16.05.2022	12.15 pm	02.35 pm		1947	Cilling Fan not working	Pead.ward	16.05.2022	03.45 pm	
4	16.05.2022	10.20 am	11.15 am		1881	AC Remote not working	Super Deluxe	17.05.2022	11.35 am	
5	16.05.2022	04.30 pm	04.53 pm		7168	LED 15watt not working	Casulty	16.05.2022	04.55 pm	
6	16.05.2022	09.45 am	10.20 am		1882	AHU Filter cleaning	Super Deluxe	17.05.2022	03.25 pm	
7	16.05.2022	02.35 pm	03.45 pm		6126	X-Ray Box not working	OT Complex	17.05.2022	05.30 pm	
8	18.05.2022	10.15 am	11.20 am		498	Cilling Fan not working	Pul.Med.ward	19.05.2022	11.00 am	
9	18.05.2022	05.30 pm	05.45 pm		6341	FCU Not working	Ex.Deluxe	19.05.2022	11.35 am	
10	18.05.2022	10.00 am	12.35 pm		2472	AHU Filter cleaning	Kt ICU	18.05.2022	03.25 pm	
11	18.05.2022	11.20 am	11.55 am		6341	Casset AC not working	Ex.Deluxe	19.05.2022	04.15 pm	
12	19.05.2022	11.08 am	11.25 am		403	Cilling Fan not working	Physiotherapy	19.05.2022	11.45 am	
13	19.05.2022	02.20 pm	02.45 pm		2741	Cilling Fan not working	Old Deluxe	19.05.2022	04.40 pm	
14	19.05.2022	03.19 pm	04.15 pm		749	Cilling fan Requirement	Sequirity office	24.05.2022	05.10 pm	
15	19.05.2022	02.44 pm	03.15 pm		1385	Refregator not working	Step down ICU	23.05.2022	04.00 pm	
16	19.05.2022	02.46 pm	03.15 pm		1390	Switch Board not working	Step down ICU	20.05.2022	11.35 am	
17	19.05.2022	12.10 pm	12.35 pm		2891	AHU Filter cleaning	EICU	19.05.2022	04.55 pm	
18	19.05.2022	03.07 pm	03.55 pm		862	Water cooler not working	MJPJAY	20.05.2022	02.00 pm	
19	19.05.2022	10.15 am	10.20 am		2598	AHU Filter cleaning	C.S.S.D	20.05.2022	04.15 pm	
20	19.05.2022	02.45 pm	03.20 pm		1389	Fan Regulator not working	Step down ICU	20.05.2022	12.00 pm	
21	19.05.2022	05.30 pm	05.45 pm		6340	Cilling Fan not working	Ex.Deluxe	20.05.2022	10.30 am	
22	20.05.2022	10.16 am	11.15 am		2746	Cilling Fan not working	Old Deluxe	20.05.2022	12.55 pm	
23	20.05.2022	10.27 am	11.55 am		6134	Switch Board not working	OT Complex	20.05.2022	03.00 pm	
24	20.05.2022	10.27 am	11.30 am		6135	LED Tubelight not working	OT Complex	20.05.2022	04.00 pm	
25	20.05.2022	10.26 am	12.15 pm		6133	Switch Board not working	OT Complex	20.05.2022	04.20 pm	
26	20.05.2022	11.58 am	12.20 pm		5423	Switch Board not working	MSW	21.05.2022	12.35 pm	
27	20.05.2022	09.30 am	10.10 am		556	Pedastral fan not working	Dental OPD	24.05.2022	10.20 am	
28	20.05.2022	10.53 am	03.30 pm		2608	Electrical problame	Physiotherapy	24.05.2022	03.55 pm	
29	21.05.2022	12.50 pm	02.20 pm		218	Cilling Fan not working	RMO Office	24.05.2022	03.00 pm	
30	21.05.2022	11.05 am	11.25 am		2073	Tempreture meter not working	MJPJAY	23.05.2022	10.32 am	
31	21.05.2022	11.01 am	11.20 am		219	Cat-6 cable laying work	MRD-II			Work in progress
	Pending work									
1	18.04.2022	01.08 pm	02.45 pm		1937	Electrical problame	"C' Building	18.05.2022	02.45 pm	
2	02.05.2022	12.35 pm	12.55 pm		1955 & 1950	Electrical wiring work	"C' Building			Work in progress
3	30.04.2022	01.15 pm	02.35 pm		1019	Electrical wiring work	Medicin Dept.	19.05.2022	02.55 pm	

					Ceiling fan Requirement	All waiting area			Work in progress
5	12.05.2022	11.30 am	12.10 pm		830	Split AC not working	2D Eco.			Work in progress
6	14.05.2022	12.00 pm	12.35 pm		2889	LED Panel cleaning work	EICU	20.05.2022	04.15 pm	
7	14.05.2022	03.28 pm	04.10 pm		1971	Electrical fitting work	HR Department	22.05.2022	04.45 pm	

Total Complaint	38
Pending Complaint	4
Complete Complaint	34
Complaint Precentrage	89%

M.V.Gaikwad
MGM Aurangabad

Electrical Engineer
MGM Aurangabad

Technical Executive(Elect.)
MGM Aurangabad

Electrical Supervisor
MGM Aurangabad

MGM MEDICAL COLLEGE & HOSPITAL

ELECTRICAL MAINTANCE REPORT 06/06/2022 to 19/~~2022~~ 14.06.2022

Sr.No.	Received Date	Time	Attende Time	Response Time	Cpmplaint No.	Nature Of Complent	Name Of Department	Date Of Complation	Close Time	Remark
1	06.06.2022	12.15 pm	02.30 pm		315	Air Cooler not working	MRD-II nd	06.06.2022	02.41 pm	
2	06.06.2022	02.44 pm	03.55 pm		3326	LED Tubelight not working	PSM Dept.	06.06.2022	04.00 pm	
3	06.06.2022	09.32 am	09.55 am		6164	Switch Board not working	OT Complex	06.06.2022	11.55 am	
4	06.06.2022	03.19 pm	04.15 pm		754	LED Tubelight not working	Time Office	08.06.2022	12.05 pm	
5	06.06.2022	04.52 pm	05.00 pm		1548	LED Tubelight not working	Metron Office	07.06.2022	12.00 pm	
6	06.06.2022	11.55 am	12.25 pm		486	Air Cooler not working	Nursing College	06.06.2022	03.15 pm	
7	06.06.2022	04.50 pm	05.05 pm		2763	Refregator not working	Old Deluxe	07.06.2022	11.20 am	
8	06.06.2022	02.51 pm	04.15 pm		1547	Switch Board not working	Metron Office	07.06.2022	11.06 am	
9	07.06.2022	02.40 pm	03.55 pm		1400	Cilling Fan not working	Step down ICU	08.06.2022	01.00 pm	
10	07.06.2022	01.50 pm	01.55 pm		755	Electrical problame	Time Office	07.06.2022	02.10 pm	
11	07.06.2022	02.10 pm	02.45 pm		7183	Cilling Fan not working	Casulty	14.06.2022	11.00 am	
12	07.06.2022	01.05 pm	02.40 pm		788	LED light not Working	OBGY TL ward	08.06.2022	02.30 pm	
13	07.06.2022	11.37 am	03.00 pm		2145	Air Cooler not working	MRD-I St	07.06.2022	03.30 pm	
14	08.06.2022	10.03 am	10.15 am		859	Cilling Fan not working	Registrar Cabin	08.06.2022	10.31 am	
15	09.06.2022	11.33 am	12.10 pm		1706	Switch Board not working	CCU+CVTS	09.06.2022	03.25 pm	
16	09.06.2022	05.00 pm	05.10 pm		172	Wall fan not working	FMW	09.06.2022	05.25 pm	
17	09.06.2022	03.35 pm	04.05 pm		171	Switch Board not working	FMW	09.06.2022	04.35 pm	
18	09.06.2022	04.18 pm	04.45 pm		6366	Gizar not working	Ex.Deluxe	10.06.2022	12.00 pm	
19	09.06.2022	07.28 am	09.20 am		3709	Lift No-05 not working	Time Office	17.06.2022	12.10 pm	
20	09.06.2022	04.23 pm	05.00 pm		6364	LED 15watt not working	Ex.Deluxe	10.06.2022	12.25 pm	
21	10.06.2022	10.45 am	11.30 am		6172	LED Tubelight not working	OT Complex	10.06.2022	11.45 am	
22	10.06.2022	11.20 am	11.55 am		553	LED Tubelight not working	Psychetric OPD	10.06.2022	12.50 pm	
23	10.06.2022	10.06 am	11.10 am		408	VRV Not working	Physiotherapy			Work in progress
24	10.06.2022	11.30 am	12.05 pm		2393	Wall fan not working	Psychetric ward	10.06.2022	12.20 pm	
25	10.06.2022	03.00 pm	03.25 pm		1703	LED 18watt Panel	Cardac OT	10.06.2022	04.10 pm	
26	11.06.2022	09.20 am	09.30 am		756	10Hp Motor Not working	Time Office	11.06.2022	10.10 am	
27	11.06.2022	01.20 pm	01.25 pm		757	LED Tubelight not working	Time Office	11.06.2022	11.35 am	
28	11.06.2022	12.26 pm	12.45 pm		1249	LED Tubelight not working	ENT Ward	11.06.2022	01.00 pm	
29	11.06.2022	02.50 pm	03.00 pm		4463	Cilling Fan not working	F.Ortho ward	11.06.2022	03.15 pm	
30	11.06.2022	04.15 pm	04.35 pm		1250	Gizar not working	Opthal Ward	11.06.2022	05.35 pm	
31	11.06.2022	12.04 pm	12.55 pm		4841	Switch Board not working	Nephrology ward	11.06.2022	05.05 pm	
32	12.06.2022	11.00 am	11.00 am		12	Shutdown cable repairing work	CSSD	12.06.2022	03.00 pm	
33	13.06.2022	10.00 am	10.00 am		13	Shutdown cable repairing work	Ct-Scan & MRI	13.06.2022	02.00 pm	
34	13.06.2022	11.00 am	11.20 am		7188	LED 15watt not working	Casulty	13.06.2022	12.15 pm	
35	13.06.2022	03.00 pm	03.10 pm		8	Table fan not working	Medicine OPD	13.06.2022	04.15 pm	
36	14.06.2022	10.50 am	11.20 am		7190	LED Bulb not working	Casulty	14.06.2022	03.45 pm	
37	14.06.2022	11.33 am	12.10 pm		936	LED 15watt not working	CATH-LAB	14.06.2022	04.30 pm	
38	14.06.2022	03.30 pm	04.10 pm		6178	LED Fitting not working-OT 06	OT Complex			Work in progress

40	14.06.2022	03.40 pm	04.45 pm		6402	Exhouast Fan not working	Step down ICU	16.06.2022	04.10 pm	
41	14.06.2022	09.20 am	10.00 am		3[illegible]	Cat-06 Cable laying	Pead. Dep[illegible]nent	17.06.2022	12.45 pm	
42	15.06.2022	11.29 am	11.55 am		1682	Cilling Fan not working	Surgery OPD	17.06.2022	10.30 am	
43	15.06.2022	11.54 am	12.15 pm		2396	Wall fan not working	Psychetric ward	15.06.2022	12.12 pm	
44	15.06.2022	11.54 am	12.20 pm		6181	Switch Board not working	OT Complex	15.06.2022	04.10 pm	
45	15.06.2022	02.37 pm	03.00 pm		6180	Switch Board not working	OT Complex	15.06.2022	03.40 pm	
46	15.06.2022	03.55 pm	04.20 pm		1707	Gizar not working	CCU+CVTS	17.06.2022	11.00 am	
47	15.06.2022	12.48 pm	02.55 pm		1173	Cilling Fan not working	Pead.ward	16.06.2022	03.30 pm	
48	15.06.2022	10.47 am	11.45 am		173	Switch Board not working	FSW	17.06.2022	03.35 pm	
49	15.06.2022	11.10 am	01.00 pm		2852	Extention Board not working	MICU	16.06.2022	10.27 am	
50	15.06.2022	11.23 am	02.55 pm		317	Air Cooler not working	MRD II nd			Work in progress
51	15.06.2022	11.23 am	12.05 pm		708	Wall fan not working	FMW	16.06.2022	02.15 pm	
52	16.06.2022	02.15 pm	03.20 pm		709	Cilling Fan not working	FMW	16.06.2022	02.30 pm	
53	17.06.2022	12.55 pm	02.45 pm		6207	Door Bell Requirement	CSSD			Requirment work
54	17.06.2022	11.50 am	12.05 pm		940	LED 15watt not working	CATH-LAB	17.06.2022	03.15 pm	
55	17.06.2022	09.45 am	10.00 pm		939	Switch Board not working	CATH-LAB	17.06.2022	01.15 pm	
56	17.06.2022	11.00 am	11.20 am		7507	Electrical problame	Super Deluxe	17.06.2022	12.00 pm	
57	17.06.2022	11.29 am	12.25 pm		10	Cilling Fan not working	Medicin OPD	18.06.2022	12.00 pm	
58	17.06.2022	04.14 pm	05.00 pm		7195	LED 18watt Panel	Cusualty	18.06.2022	03.25 pm	
59	17.06.2022	11.29 am	12.10 pm		4658	LED Tubelight not Working	MMW	18.06.2022	01.00 pm	
60	18.06.2022	11.25 am	12.05 pm		7194	LED 15watt not working	Cusualty	18.06.2022	03.00 pm	
61	18.06.2022	02.45 pm	03.10 pm		1053	LED Bulb not working	MJPJAY	20.06.2022	03.35 pm	
62	18.06.2022	04.00 pm	04.45 pm		275	Exhouast Fan not working	OPD Building	20.06.2022	02.20 pm	
63	18.06.2022	12.42 pm	02.35 pm		2768	LED Bulb not working	Old Deluxe	18.06.2022	04.45 pm	
					3044	Split AC not working	Microbiology			Work in progress

Pending work

1	04.06.2022	04.27 pm	05.10 pm		2762	Water cooler not working	Old Deluxe	07.06.2022	11.15 am	
2	04.06.2022	10.09 am	12.15 pm		7425	Cilling Fan not working	Anatomy	07.06.2022	12.30 pm	
3	04.06.2022	11.14 am	02.40 pm		3707	LED Bulb not working	Time Office	07.06.2022	03.00 pm	
4	03.06.2022	04.15 pm	04.20 pm		703	Wall fan not working	FMW	11.06.2022	01.55 pm	
5	02.06.2022	09.00 am	09.10 am		750	Lift No-01 not working	Time Office	02.06.2022	02.00 pm	
6	02.06.2022	02.49 pm	03.15 pm		5426	LED Tubelight & Cilling fan Requirer	MSW	08.06.2022	02.45 pm	
7	11.05.2022	03.30 pm	04.10 pm		736	LED light & cilling Fan not working	Time Office	07.06.2022	10.00 am	

Total Complaint	70
Pending Complaint	4
Complete Complaint	66
Complaint Precentrage	94%

M.V.Gaikwad
MGM Aurangabad

Electrical Engineer
MGM Aurangabad

Technical Executive(Elect.)
MGM Aurangabad

Electrical Supervisor
MGM Aurangabad

MGM MEDICAL COLLEGE & HOSPITAL

ELECTRIC[illegible] MAINTANCE REPORT 20/06/2022 to 26/0[illegible]022 26.06.2022

Sr.No.	Received Date	Time	Attende Time	Response Time	Cpmplaint No.	Nature Of Complent	Name Of Department	Date Of Complation	Close Time	Remark
1	01.06.2022	11.20 am	12.40 pm		2475	VRV Not working	Kt ICU	01.06.2022	04.50 pm	
2	02.06.2022	09.40 am	10.10 am		3868	VRV Not working	Dialysis	02.06.2022	01.50 pm	
3	06.06.2022	10.55 am	11.00 am		1898	FCU Not working	Super Deluxe	06.06.2022	11.45 am	
4	09.06.2022	12.30 pm	12.45 pm		3043	Split AC not working	Microbiology	14.06.2022	10.45 am	
5	14.06.2022	10.10 am	11.05 am		7191	VRV Not working	Casulty	14.06.2022	04.15 pm	
6	14.06.2022	09.20 am	10.10 am		Letter	Split AC not working	Yeshwant Graphics	14.06.2022	04.50 pm	
7	17.06.2022	10.37 am	10.45 am		938	Split AC not working	CATH-LAB	17.06.2022	03.55 pm	
8	20.06.2022	11.24 am	12.10 pm		358	LED light not Working	Endoscophy	20.06.2022	02.25 pm	
9	20.06.2022	04.50 pm	05.00 pm		Letter	Cable Tray fixing work	IT Department	22.06.2022	03.45 pm	
10	20.06.2022	10.10 am	11.20 am		2683	Split AC not working	Exam cell	25.06.2022	03.10 pm	
11	20.06.2022	11.03 am	12.20 pm		6189	OT lamp not working OT-06	OT Complex	24.06.2022	02.50 pm	
12	20.06.2022	09.20 am	10.10 am		947	Split AC not working	Labour Room	20.06.2022	12.05 pm	
13	20.06.2022	12.38 pm	03.30 pm		4464	Switch Board not working	F.Ortho ward	21.06.2022	10.55 am	
14	20.06.2022	11.20 am	12.35 pm		2526	Wall fan not working	Record Section	21.06.2022	02.25 pm	
15	21.06.2022	10.05 am	11.10 am		5433	Cilling Fan not working	MSW	21.06.2022	02.40 pm	
16	21.06.2022	10.30 am	10.45 am		114	VRV Not working	Radiology Dept	21.06.2022	10.20 am	
17	21.06.2022	09.20 am	10.10 am		3046	Split AC not working	Microbiology	21.06.2022	12.05 pm	
18	21.06.2022	04.04 pm	04.35 pm		154	Switch Board not working	Inst.Physiotheraphy	22.06.2022	12.45 pm	
19	23.06.2022	11.05 am	11.45 am		962	Focus lamp not working	Labour Room	23.06.2022	12.05 pm	
20	23.06.2022	12.15 pm	02.40 pm		6518	Split AC not working	Pathalogy			Work in progress
21	23.06.2022	10.10 am	11.35 am		1058	LED Tubelight not working	MJPJAY	23.06.2022	03.20 pm	
22	23.06.2022	11.30 am	11.45 am		217	Cilling Fan not working	MCRI OPD-011	25.06.2022	11.40 am	
23	23.06.2022	11.30 am	12.20 pm		2083	LED Bulb not working	MJPJAY	24.06.2022	03.00 pm	
24	23.06.2022	11.30 am	01.50 pm		213	LED Tubelight not working	MCRI OPD	23.06.2022	02.30 pm	
25	23.06.2022	10.40 am	11.45 am		1176	LED Tubelight not working	Pead. Department	23.06.2022	03.00 pm	
26	24.06.2022	11.58 am	12.20 pm		11	LED Tubelight not working	Med.OPD	24.06.2022	01.00 pm	
27	24.06.2022	02.31 pm	03.00 pm		359	LED 15watt not working	Endoscophy	24.06.2022	03.45 pm	
28	24.06.2022	10.10 am	10.20 am		35	AHU Filter cleaning	IVF Centare	24.06.2022	03.00 pm	
29	24.06.2022	03.30 pm	04.15 pm		3714	Lift No-02 Not working	Time Office	24.06.2022	05.00 pm	
30	24.06.2022	12.40 pm	12.45 pm		292	LED 18watt Panel	Nephrology ward	24.06.2022	01.15 pm	
31	24.06.2022	02.20 pm	02.40 pm		3956	VRV Not working	Dialysis	24.06.2022	03.20 pm	
32	24.06.2022	09.30 am	10.10 am		2146	Cilling Fan not working	Registation Dept.	25.06.2022	12.40 pm	
33	24.06.2022	12.30 pm	02.40 pm		5435	Cilling Fan not working	MSW	24.06.2022	03.30 pm	
34	24.06.2022	11.02 am	12.05 pm		3047	LED 15watt not working	Microbiology	24.06.2022	01.05 pm	
35	25.06.2022	11.45 am	11.45 am		6985	Switch Board not working	SICU	25.06.2022	12.05 pm	
36	25.06.2022	10.30 am	11.05 am		5035	LED Tubelight not working	NICU	25.06.2022	12.15 pm	
37	25.06.2022	11.20 am	11.50 am		115	VRV Not working	Radiology Dept	25.06.2022	04.10 pm	
38	25.06.2022	11.06 am	11.52 am		2560	Cilling Fan not working	Opthal OPD	28.06.2022	10.25 am	

40	25.06.2022	11.20 am	12.35 pm		3715	Lift No-06 Not working	Time Office	26.06.2022	02.00 pm	
41	25.06.2022	10.44 am	11.35 am		1	Electrical problame	Inst.Phy theraphy	25.06.2022	05.30 pm	
42	25.06.2022	01.00 pm	02.40 pm		7511	LED 15watt not working	Super Deluxe	25.06.2022	12.55 pm	
43	26.06.2022	06.50 pm	06.55 pm		1936	LED Tubelight not working	House kiping Dept.	25.06.2022	04.00 pm	
44	26.06.2022	08.19 am	08.45 am		764	Electrical problame	Time Office	26.06.2022	07.05 pm	
45	26.06.2022	03.10 pm	04.00 pm		3716	Lift No-06 Not working	Time Office	26.06.2022	02.00 pm	
46	26.06.2022	12.20 pm	12.35 pm		6210	Air Cooler not working	CSSD	27.06.2022	03.10 pm	
					351	LED light not Working	School of Bio-Med.			
					Pending work					
1	15.06.2022	11.10 am	01.00 pm		317	Air Cooler not working	MRD II nd			Work in progress
2	18.06.2022	12.42 pm	02.35 pm		3044	Split AC not working	Microbiology	21.06.2022	12.05 pm	
3	10.06.2022	10.06 am	11.10 am		408	VRV Not working	Physiotherapy	22.06.2022	09.20 am	
4	14.06.2022	03.30 pm	04.10 pm		6178	LED Fitting not working-OT 06	OT Complex	24.06.2022	02.50 pm	

Total Complaint	50
Pending Complaint	3
Complete Complaint	47
Complaint Precentrage	94%

M.V.Gaikwad
MGM Aurangabad

Electrical Engineer
MGM Aurangabad

Technical Executive(Elect.)
MGM Aurangabad

Electrical Supervisor
MGM Aurangabad

MGM MEDICAL COLLEGE & HOSPITAL

ELECTRICAL MAINTANCE REPORT 27/06/2022 to 07/2022 03.07.2022

Sr.No.	Received Date	Time	Attende Time	Response Time	Cpmplaint No.	Nature Of Complent	Name Of Department	Date Of Complation	Close Time	Remark
1	27.06.2022	11.05 am	11.25 am		3717	Telephone cable laying work.	Time Office	27.06.2022	12.05 pm	
2	27.06.2022	09.46 am	10.00 am		7428	LED Light not working	Anatomy	28.06.2022	10.27 am	
3	27.06.2022	11.15 am	12.20 pm		401	Switch Board not working	OT Complex	27.06.2022	05.00 pm	
4	27.06.2022	11.35 am	02.40 pm		299	Switch Board not working	Physiotherapy	29.06.2022	09.45 am	
5	28.06.2022	04.50 pm	05.10 pm		2779	LED light not Working	Old Deluxe	29.06.2022	02.25 pm	
6	28.06.2022	10.10 am	11.20 am		4850	Switch Board not working	Nephrology ward	29.06.2022	03.00 pm	
7	29.06.2022	12.28 pm	12.28 pm		306	Room Heater not working	Psychatric ward	29.06.2022	12.30 pm	Deposit
8	29.06.2022	12.27 pm	12.45 pm		307	LED 15watt not working	Psychatric ward	30.06.2022	02.25 pm	
9	30.06.2022	10.30 am	11.15 am		179	LED Tubelight & Switch Board not w	FSW	30.06.2022	04.00 pm	
10	30.06.2022	01.10 pm	02.55 pm		945	Humidity Meter Replace work	CATH-LAB			~~Work in progress~~ OK
11	30.06.2022	11.50 am	12.20 pm		1265	Gizar not working	Opthal Ward	02.07.2022	04.00 pm	
12	01.07.2022	12.34 pm	12.40 pm		182	Switch Board not working	FSW	01.07.2022	12.40 pm	
13	01.07.2022	10.41 am	11.00 am		2313	LED Tubelight & X-Ray box not work	PSM Dept.	02.07.2022	10.50 pm	
14	01.07.2022	12.20 pm	12.45 pm		1061	Cilling Fan not working	MJPJAY	02.07.2022	11.30 am	
15	01.07.2022	05.05 pm	05.10 pm		5330	LED Light not Working	Blood Bank	02.07.2022	11.05 am	
16	02.07.2022	12.50 pm	01.10 pm		2784	Water cooler not working	Old Deluxe	02.07.2022	01.10 pm	
17	02.07.2022	09.15 am	10.10 am		5442	Cilling fan & Switch Bord not working	MSW	04.07.2022	03.10 pm	
18	02.07.2022	02.30 pm	03.31 pm		407	LED Tubelight not working	OT Complex	04.07.2022	03.55 pm	
19	02.07.2022	02.30 pm	02.45 pm		413	LED Building Light not working	C' Building			Work in progress
20	02.07.2022	10.45 am	11.10 am		308	Split AC not working	Psy.Ward			Work in progress
	Pending work									
1	15.06.2022	11.10 am	01.00 pm		317	Air Cooler not working	MRD II nd	30.06.2022	10.45 am	
2	23.06.2022	12.15 pm	02.40 pm		6518	Split AC not working	Pathalogy			Work in progress
3	26.06.2022	12.20 pm	12.35 pm		351	LED light not Working	School of Bio-Med.	02.07.2022	01.30 pm	
4	26.06.2022	04.10 pm	04.30 pm		4459	X-Ray Box not working	Ortho Ward	28.06.2022	09.45 am	

Total Complaint	24
Pending Complaint	4
Complete Complaint	20
Complaint Precentrage	83%

M.V.Gaikwad
MGM Aurangabad

Electrical Engineer
MGM Aurangabad

Technical Executive(Elect.)
MGM Aurangabad

Electrical Supervisor
MGM Aurangabad

MGM MEDICAL COLLEGE & HOSPITAL

ELECTRICAL MAINTANCE REPORT 04/07/2022 to 10/07/2022

10.07.2022

Sr.No.	Received Date	Time	Attende Time	Response Time	Cpmplaint No.	Nature Of Complent	Name Of Department	Date Of Complation	Close Time	Remark
1	04.07.2022	04.05 pm	04.20 pm		227	VRV Not working	MCRI OPD-13 & 25	04.07.2022	05.05 pm	
2	04.07.2022	10.00 am	10.10 am		226	LED Tubelight not working	MCRI OPD-15	04.07.2022	10.30 am	
3	04.07.2022	05.00 pm	05.10 pm		2786	Wall fan not working	Old Deluxe	07.07.2022	12.00 pm	
4	04.07.2022	12.08 pm	02.05 pm		3262	LED Tubelight not working	Pead.Dept.	05.07.2022	02.40 pm	
5	04.07.2022	10.31 am	11.05 am		4389	Cilling Fan not working	OBGY-1st	04.07.2022	03.00 pm	
6	04.07.2022	06.19 pm	06.19 pm		5041	LED light not Working	NICU	04.07.2022	06.26 pm	
7	04.07.2022	11.00 am	02.20 pm		2089	Cilling Fan not working	MJPJAY	04.07.2022	02.50 pm	
8	04.07.2022	03.30 pm	03.35 pm		183	Cilling Fan not working	FSW	04.07.2022	03.35 pm	
9	04.07.2022	09.30 pm	09.35 am		566	Cilling Fan not working	Dental OPD	04.07.2022	09.35 am	
10	05.07.2022	09.20 am	10.10 am		2871	AHU Filter cleaning	MICU	05.07.2022	12.10 pm	
11	05.07.2022	08.00 pm	08.10 pm		3723	LED Tubelight not working	Time Office	05.07.2022	08.25 pm	
12	06.07.2022	10.10 am	11.20 am		3724	RO not working	Chairman Office			Work in progress
13	06.07.2022	02.30 pm	02.35 pm		5450	Cilling Fan not working	MSW	06.07.2022	02.50 pm	
14	06.07.2022	04.35 pm	04.50 pm		1192	Exhouast Fan not working	Urology Dept.	07.07.2022	11.45 am	
15	06.07.2022	04.35 pm	04.55 pm		1187	Switch Board not working	Urology Dept.	07.07.2022	11.15 am	
16	07.07.2022	11.30 am	11.45 am		798	Electrical problame	OBGY-2nd	07.07.2022	02.35 pm	
17	07.07.2022	10.45 am	11.10 am		1550	Table fan not working	Metron Office			Work in progress
18	07.07.2022	11.05 am	11.30 am		3725	Lift No-03 not working	Time Office	07.07.2022	03.10 pm	
19	07.07.2022	10.00 am	10.20 am		230	VRV Not working	Central Lab.	07.07.2022	02.00 pm	
20	08.07.2022	11.00 am	11.45 am		501	Tubelight not working	Opthal OPD	08.07.2022	03.25 pm	
21	08.07.2022	12.00 pm	12.30 pm		7523	LED light not Working	Super Deluxe			Work in progress
22	08.07.2022	04.00 pm	04.35 pm		800	LED Tubelight not working	OBGY-2nd	09.07.2022	10.20 am	
23	08.07.2022	02.40 pm			14	FCU Reconnect work	CATH-LAB	10.07.2022	02.00 pm	
24	08.07.2022	10.20 am	11.05 am		3958	Extention Board not working	Dialysis	09.07.2022	03.00 pm	
25	09.07.2022	11.10 am	11.45 am		947	FCU Not working	CATH-LAB	10.07.2022	12.10 pm	
26	09.07.2022	11.45 am	11.55 am		2317	Wall fan not working	PSM Dept.	09.07.2022	01.00 pm	
27	09.07.2022	12.08 pm	12.30 pm		770	10Hp Motor Not working	Time Office	10.07.2022	09.55 pm	
28	09.07.2022	12.40 pm	02.20 pm		422	Switch Board not working	OT Complex	09.07.2022	04.00 pm	
29	09.07.2022	02.30 pm	02.45 pm		946	Extention Board not working	CATH-LAB	09.07.2022	04.55 pm	
30	09.07.2022	12.45 pm	02.35 pm		424	Switch Board not working	OT No-01	09.07.2022	03.55 pm	
31	09.07.2022	12.00 pm	12.30 pm		6216	Cilling Fan not working	CSSD	10.07.2022	04.45 pm	
32	10.07.2022	03.10 pm	03.20 pm		6217	Call Bell Required	CSSD	10.07.2022	04.07 pm	
	Pending work									
1	23.06.2022	12.15 pm	02.40 pm		6518	Split AC not working	Pathalogy	05.07.2022	10.00 pm	Proses to New Split AC
2	30.06.2022	01.10 pm	02.55 pm		945	Humidity Meter Replace work	CATH-LAB	02.06.2022	12.30 pm	
3	02.07.2022	02.30 pm	02.45 pm		413	LED Building Light not working	C' Building			Work in progress
4	02.07.2022	10.45 am	11.10 am		308	Split AC not working	Psy.Ward	04.07.2022	02.20 pm	

Total Complaint	
Pending Complaint	4
Complete Complaint	32
Complaint Precentrage	89%

M.V.Gaikwad
MGM Aurangabad

Electrical Engineer
MGM Aurangabad

Technical Executive(Elect.)
MGM Aurangabad

Electrical Supervisor
MGM Aurangabad

MGM MEDICAL COLLEGE & HOSPITAL

ELECTRICAL MAINTANCE REPORT 11/07/2022 to 17/07/2022 17.07.2022

Sr.No.	Received Date	Time	Attende Time	Response Time	Cpmplaint No.	Nature Of Complent	Name Of Department	Date Of Complation	Close Time	Remark
1	11.07.2022	11.52 am	04.15 pm		5333	Wall fan not working	Blood Bank	11.07.2022	04.20 pm	
2	11.07.2022	11.52 am	04.15 pm		5334	LED 12Watt not working	Blood Bank	11.07.2022	04.30 pm	
3	11.07.2022	01.14 pm	04.00 pm		5393	Gizar not working	OBGY Ward 2nd	11.07.2022	04.45 pm	
4	11.07.2022	03.24 pm	04.15 pm		4669	LED Tubelight not working	MMW	12.07.2022	01.30 pm	
5	12.07.2022	12.15 pm	12.20 pm		7528	LED 15watt not working	Super Deluxe	12.07.2022	12.50 pm	
6	13.07.2022	11.20 am	02.30 pm		7026	Tharmameter not working	Casulty	13.07.2022	04.01 pm	
7	13.07.2022	04.38 pm	05.00 pm		950	LED Bulb not working	CATH-LAB			Work in progress
8	13.07.2022	11.37 am	12.00 pm		12	LED Tubelight not working	Med.OPD	16.07.2022	12.45 pm	
9	13.07.2022	10.53 am	02.00 pm		7022	LED 15watt not working	Casulty	14.07.2022	01.20 pm	
10	14.07.2022	09.30 am	10.10 am		109	LED 15watt not working	EICU	14.07.2022	12.30 pm	
11	14.07.2022	09.25 am	10.30 am		113	LED 15watt not working	EMS Passage	14.07.2022	12.00 pm	
12	14.07.2022	11.25 am	12.10 pm		167	Switch Board not working	C' Building	14.07.2022	01.15 pm	
13	14.07.2022	05.00 pm	05.25 pm		3732	LED Tubelight not working	Time Office	17.07.2022	02.30 pm	
14	14.07.2022	02.40 pm	03.10 pm		1283	Cilling Fan not working	ENT Ward	18.07.2022	04.25 pm	
15	14.07.2022	09.35 am	10.10 am		1710	LED 18watt Panel	Dyotan Hall			Work in progress
16	14.07.2022	11.30 am	12.00 pm		6220	Electrical problame	CSSD			Work in progress
17	14.07.2022	11.35 am	01.10 pm		187	Switch Board not working	FSW	14.07.2022	03.30 pm	
18	14.07.2022	02.40 pm	03.10 pm		1282	Gizar not working	ENT Ward	15.07.2022	12.00 pm	
19	14.07.2022	10.49 am	11.10 am		4672	LED Tubelight not working	MMW	14.07.2022	03.50 pm	
20	14.07.2022	01.30 pm	02.10 pm		6219	Cilling Fan not working	CSSD	14.07.2022	03.00 pm	
21	15.07.2022	09.52 am	10.10 am		1001	LED Tubelight not working	ENT OPD	15.07.2022	12.00 pm	
22	15.07.2022	12.50 pm	03.20 pm		320	LED 15watt not working	Psy.Ward	16.07.2022	12.00 pm	
23	15.07.2022	10.46 am	11.00 am		4674	Switch Board not working	MMW	16.07.2022	11.00 am	
24	15.07.2022	12.00 pm	12.20 pm		2316	Refregator not working	Medical Store			Work in progress
25	15.07.2022	03.07 pm	04.10 pm		1285	LED Tubelight not working	ENT Ward	16.07.2022	11.15 am	
26	15.07.2022	03.27 pm	05.00 pm		1066	LED Tubelight not Working	MJPJAY	18.07.2022	12.40 pm	
27	16.07.2022	12.00 pm	12.15 pm		189	LED Tubelight not working	FSW	18.07.2022	12.30 pm	
28	16.07.2022	11.20 am	12.20 pm		1200	LED Bulb not working	Urology Dept.	18.07.2022	10.20 am	
29	17.07.2022	11.10 am	11.10 am		772	LED Tubelight not working	Time Office	17.07.2022	02.30 pm	
	Pending work									
1	02.07.2022	02.30 pm	02.45 pm		413	LED Building Light not working	C' Building			Work in progress
2	06.07.2022	10.10 am	11.20 am		3724	RO not working	Chairman Office	13.07.2022	12.20 pm	
3	07.07.2022	10.45 am	11.10 am		1550	Table fan not working	Metron Office			Work in progress
4	08.07.2022	12.00 pm	12.30 pm		7523	LED light not Working	Super Deluxe	12.07.2022	12.50 pm	

Total Complaint	33
Pending Complaint	6
Complete Complaint	27
Complaint Precentrage	82%

M.V.Gaikwad
MGM Aurangabad

Electrical Engineer
MGM Aurangabad

Technical Executive(Elect.)
MGM Aurangabad

Electrical Supervisor
MGM Aurangabad

MGM MEDICAL COLLEGE & HOSPITAL

ELECTRICAL MAINTANCE REPORT 18/07/2022 to 24/07/2022

24.07.2022

Sr.No.	Received Date	Time	Attende Time	Response Time	Cpmplaint No.	Nature Of Complent	Name Of Department	Date Of Complation	Close Time	Remark
1	18.07.2022	10.31 am	10.35 am		436	Refregator Bulb not working	OT Complex	18.07.2022	11.00 am	
2	18.07.2022	12.10 pm	12.50 pm		1290	Cilling Fan not working	ENT Ward	18.07.2022	04.25 pm	
3	18.07.2022	03.05 pm	04.30 pm		2770	Fan Regulator not working	New Deluxe	20.07.2022	01.02 pm	
4	18.07.2022	04.35 pm	05.00 pm		778	LED Bulb not working	Time Office	20.07.2022	10.00 am	
5	18.07.2022	04.00 pm	04.30 pm		4298	LED Tubelight not working	OBGY ICU	20.07.2022	12.20 pm	
6	18.07.2022	11.39 am	12.00 pm		1068	Tempreture Meter not working	MJPJAY	18.07.2022	02.35 pm	
7	18.07.2022	11.36 am	11.40 am		415	LED 15watt not working	Physiotherapy	19.07.2022	12.00 pm	
8	18.07.2022	12.25 pm	12.45 pm		23202	LED Tubelight not working	Nursing College	20.07.2022	10.48 am	
9	18.07.2022	02.30 pm	02.40 pm		1718	OT lamp not working	CVTS OT	18.07.2022	02.55 pm	
10	19.07.2022	09.28 am	10.20 am		7034	LED Tubelight not working	Casulty	19.07.2022	10.53 am	
11	19.07.2022	10.53 am	11.05 am		3055	Split AC not working	Microbiology	20.07.2022	04.00 pm	
12	19.07.2022	02.35 pm	03.05 pm		169	Switch Board not working	Physiotherapy	20.07.2022	03.30 pm	
13	19.07.2022	10.54 am	11.25 am		3056	Extention Board not working	Microbiology	20.07.2022	04.50 pm	
14	19.07.2022	09.28 am	10.20 am		7036	Cilling Fan not working	Casulty	19.07.2022	10.32 am	
15	19.07.2022	09.28 am	10.20 am		7035	LED Tubelight not Working	Casulty	19.07.2022	10.35 am	
16	19.07.2022	10.42 am	11.10 am		729	LED Tubelight not working	FMW	20.07.2022	12.40 pm	
17	19.07.2022	09.42 am	11.00 am		237	LED Tubelight not working	MCRI OPD-13	19.07.2022	11.20 am	
18	19.07.2022	10.46 am	11.00 am		779	Lift No-05 not working	Time Office	19.07.2022	11.00 am	
19	19.07.2022	10.30 am	11.00 am		121	VRV Not working	Rediology Dept.	19.07.2022	01.00 pm	
20	19.07.2022	09.20 am	10.00 am		177	AHU Filter cleaning	PICU	19.07.2022	04.00 pm	
21	19.07.2022	02.30 pm	02.55 pm		3881	VRV Not working	Dialysis	19.07.2022	04.00 pm	
22	19.07.2022	03.50 pm	04.15 pm		441	Switch Board not working	OT Complex	19.07.2022	06.00 pm	
23	19.07.2022	02.47 pm	03.10 pm		2709	Electrical problame	New Pead.	19.07.2022	03.30 pm	
24	19.07.2022	12.10 pm	12.40 pm		787	VRV Not working	Central library	19.07.2022	12.40 pm	
25	19.07.2022	10.42 am	11.30 am		1183	LED Tubelight not working	M.Ortho ward	20.07.2022	11.48 am	
26	20.07.2022	10.55 am	11.55 am		4862	Cilling Fan & Tubelight not working	Nefrology Ward	20.07.2022	12.00 pm	
27	20.07.2022	01.00 pm	01.30 pm		1022	Fan Regulator not working	Medicine OPD	20.07.2022	01.30 pm	
28	20.07.2022	02.30 pm	03.14 pm		1291	Gizar not working	Opthal OPD	25.07.2022	03.10 pm	
29	20.07.2022	02.55 pm	03.40 pm		5058	Cilling Fan not working	NICU	23.07.2022	11.20 am	
30	20.07.2022	12.02 pm	12.35 pm		4863	Exhouast Fan not working	Nephrology ward			Work in progress
31	20.07.2022	01.10 pm	02.05 pm		1284	3HP Motor rewinding work	Autoclove Dept.	22.07.2022	11.15 am	
32	20.07.2022	10.55 am	12.05 pm		36	LED light not Working	IVF Centare	20.07.2022	04.30 pm	
33	20.07.2022	04.00 pm	04.30 pm		2711	LED Tubelight not working	New Pead.	20.07.2022	04.30 pm	
34	21.07.2022	10.37 am	12.00 pm		7431	Refregator not working	Anatomy	23.07.2022	03.20 pm	
35	21.07.2022	12.20 pm	12.45 pm		326	LED light not Working	Psy.Ward	21.07.2022	04.15 pm	
36	21.07.2022	03.00 pm	03.20 pm		1201	Cilling Fan not working	OBGY ward-Ist	22.07.2022	02.35 pm	
37	22.07.2022	11.10 am	11.35 am		1295	Gizar not working	ENT Ward			Work in progress
38	22.07.2022	08.45 am	09.00 am		782	Gizar not working	Time Office	22.07.2022	09.40 am	

39	22.07.2022	11.40 am	02.30 pm		6526	02TR Split AC Instalation work	Pathalogy	22.07.2022	02.30 pm	
40	22.07.2022	01.30 pm	02.10 pm		3689	Gizar not working	MCRI ICU	22.07.2022	03.25 pm	
41	22.07.2022	10.30 am	11.05 am		5465	Cilling Fan not working	MSW	22.07.2022	02.15 pm	
42	22.07.2022	02.40 pm	03.10 pm		3736	Cabin Light Required	Time Office			Work in progress
43	22.07.2022	10.00 am	10.30 am		555	Cilling Fan not working	Psy.OPD-250	22.07.2022	01.45 pm	
44	22.07.2022	10.50 am	11.25 am		4864	LED Tubelight not working	Nephrology ward	22.07.2022	04.00 pm	
45	22.07.2022	04.00 pm	04.20 pm		867	Extention Board not working	MJPJAY	22.07.2022	04.45 pm	
46	22.07.2022	01.25 pm	02.00 pm		3690	Cilling Fan not working	MCRI ICU	23.07.2022	02.25 pm	
47	22.07.2022	11.45 am	11.55 am		1101	X-Ray Box not working	OBGY ICU	25.07.2022	11.55 am	
48	23.07.2022	02.41 pm	03.10 pm		6221	LED tubelight not working	CSSD	25.07.2022	02.55 pm	
	Pending work									
1	02.07.2022	02.30 pm	02.45 pm		413	LED Building Light not working	C' Building			Work in progress
2	07.07.2022	10.45 am	11.10 am		1550	Table fan not working	Metron Office			Work in progress
3	13.07.2022	04.38 pm	05.00 pm		950	LED Bulb not working	CATH-LAB			Work in progress
4	14.07.2022	09.35 am	10.10 am		1710	LED 18watt Panel	Dyotan Hall	21.07.2022	02.50 pm	
5	14.07.2022	11.30 am	12.00 pm		6220	Electrical problame	CSSD			Work in progress
6	15.07.2022	12.00 pm	12.20 pm		2316	Refregator not working	Medical Store	20.07.2022	02.55 pm	

Total Complaint	54
Pending Complaint	7
Complete Complaint	47
Complaint Precentrage	87%

M.V.Gaikwad
MGM Aurangabad

Electrical Engineer
MGM Aurangabad

Technical Executive(Elect.)
MGM Aurangabad

Electrical Supervisor
MGM Aurangabad

MGM MEDICAL COLLEGE & HOSPITAL

ELECTRICAL MAINTANCE REPORT 25/07/2022 to 31/07/2022 31.07.2022

Sr.No.	Received Date	Time	Attende Time	Response Time	Cpmplaint No.	Nature Of Complent	Name Of Department	Date Of Complation	Close Time	Remark
1	25.07.2022	02.40 pm	03.22 pm	00.42 Hr	1218	LED light not Working	Urology Dept.	26.07.2022	11.50 am	
2	25.07.2022	02.53 pm	03.45 pm	00.52 Hr	1219	Exhouast Fan not working	Urology Dept.	26.07.2022	11.45 am	
3	25.07.2022	10.00 am	10.25 am	00.25 Hr	7042	LED light & cilling Fan not working	Casulty	25.07.2022	11.10 am	
4	25.07.2022	02.00 pm	02.10 pm	00.10 Hr	4675	LED Tubelight not working	MMW	25.07.2022	02.30 pm	
5	26.07.2022	10.20 am	10.45 am	00.25 Hr	247	Stabilizer not working	MCRI OPD	28.07.2022	04.40 pm	
6	26.07.2022	12.30 pm	12.55 pm	00.25 Hr	3057	Split AC not working	Microbiology	28.07.2022	01.05 pm	
7	26.07.2022	09.50 am	10.15 am	00.25 Hr	789	Lift No-01 not working	Time Office	27.07.2022	10.05 am	
8	26.07.2022	11.28 am	11.55 am	00.27 Hr	118	LED light not Working	EICU	26.07.2022	02.15 pm	
9	26.07.2022	02.30 pm	03.00 pm	00.30 Hr	1717	Switch Board not working	CCU+CVTS	26.07.2022	03.15 pm	
10	26.07.2022	11.38 am	12.10 pm	00.32 Hr	7045	LED light not Working	Step down ICU	26.07.2022	02.00 pm	
11	26.07.2022	09.15 am	09.30 am	00.15 Hr	7601	Gizar not working	Old Deluxe	26.07.2022	10.10 am	
12	27.07.2022	09.30 am	09.45 am	00.15 Hr	452	Refregator not working	OT Complex	28.07.2022	04.10 pm	
13	27.07.2022	04.23 pm	04.45 pm	00.22 Hr	790	Lift No-03 not working	Time Office	28.07.2022	10.00 am	
14	28.07.2022	09.40 am	09.55 am	00.15 Hr	251	AHU not working	MCRI OPD-11	28.07.2022	10.45 am	
15	28.07.2022	04.25 pm	04.45 pm	00.20 Hr	122	LED Light & Switch Board not worki	Rediology Dept.	30.07.2022	12.50 pm	
16	28.07.2022	12.05 pm	12.30 pm	00.25 Hr	903	LED light not Working	TL Ward	29.07.2022	01.15 pm	
17	28.07.2022	11.45 am	12.10 pm	00.25 Hr	455	LED Tubelight not working	OT Complex	28.07.2022	03.55 pm	
18	28.07.2022	11.00 am	11.10 am	00.10 Hr	7604	Gizar not working	Old Deluxe	28.07.2022	11.20 am	
19	29.07.2022	09.45 am	10.10 am	00.25 Hr	2774	Exhouast Fan not working	New Deluxe	29.07.2022	12.00 pm	
20	29.07.2022	01.40 pm	01.40 pm	00.00 Hr	1556	Standing Fan not Working	Metron Office	29.07.2022	02.15 pm	
21	29.07.2022	02.31 pm	03.15 pm	00.44 Hr	462	LED Tubelight not working	OT Complex	30.07.2022	11.55 pm	
22	29.07.2022	04.00 pm	04.10 pm	00.10 Hr	7051	Switch Board not working	EMS Ward	29.07.2022	04.10 pm	
23	30.07.2022	03.00 pm	03.30 pm	00.30 Hr	6998	AHU Filter cleaning	SICU	30.07.2022	04.45 pm	
24	30.07.2022	04.00 pm	04.10 pm	00.10 Hr	7052	X-Ray Box not working	Casulty	30.07.2022	04.20 pm	
25	30.07.2022	10.10 am	10.30 am	00.20 Hr	7053	LED 12Watt not working	EMS Ward			Work in progress
26	30.07.2022	12.20 pm	12.45 pm	00.25 Hr	2775	Electrical problame	New Deluxe	30.07.2022	12.45 pm	
27	30.07.2022	10.35 am	10.45 am	00.10 Hr	7548	Tempreture Meter not working	Super Deluxe	30.07.2022	10.45 am	
28	30.07.2022	02.58 pm	03.10 pm	00.12 Hr	793	Lift No-07 Not working	Time Office	31.07.2022	09.45 am	
29	31.07.2022	07.30 am	08.00 pm	00.30 Hr	794	Lift No-05 not working	Time Office	31.07.2022	10.00 am	
30	31.07.2022	09.20 am	09.45 am	00.25 Hr	795	Lift No-05 not working	Time Office	31.07.2022	02.15 pm	
	Pending work									
1	02.07.2022	02.30 pm	02.45 pm	00.15 Hr	413	LED Building Light not working	C' Building	28.07.2022	03.40 pm	
2	07.07.2022	10.45 am	11.10 am	00.25 Hr	1550	Table fan not working	Metron Office	29.07.2022	10.45 am	
3	13.07.2022	04.38 pm	05.00 pm	00.22 Hr	950	LED Bulb not working	CATH-LAB			Work in progress
4	14.07.2022	11.30 am	12.00 pm	00.30 Hr	6220	Electrical problame	CSSD	26.07.2022	10.45 am	
5	20.07.2022	12.02 pm	12.35 pm	00.33 Hr	4863	Exhouast Fan not working	Nephrology ward	27.07.2022	12.55 pm	

7	22.07.2022	02.40 pm	03.10 pm	00.30 Hr	1295	Gizar not working	ENT Ward	27.07.2022	10.30 am	
8	23.07.2022	02.45 pm	03.10 pm	00.25 Hr	416	LED Light & Switch Board not worki	Time Offic			Requirement work
							Physiotherapy	28.07.2022	04.00 pm	

Total Complaint	38
Pending Complaint	3
Complete Complaint	35
Complaint Precentrage	92%

M.V.Gaikwad
MGM Aurangabad

Electrical Engineer
MGM Aurangabad

Technical Executive(Elect.)
MGM Aurangabad

Electrical Supervisor
MGM Aurangabad

MGM MEDICAL COLLEGE & HOSPITAL

ELECTRICAL MAINTANCE REPORT 01/08/2022 to 07/08/2022

07.08.2022

Sr.No.	Received Date	Time	Attende Time	Response Time	Cpmplaint No.	Nature Of Complent	Name Of Department	Date Of Complation	Close Time	Remark
1	01.08.2022	12.30 pm	12.45 pm	00.15 Hr	2874	Extention Board not working	MICU	01.08.2022	01.25 pm	
2	01.08.2022	01.20 pm	02.10 pm	00.50 Hr	1944	LED Tubelight not working	House kiping Dept.	08.08.2022	03.45 pm	
3	01.08.2022	03.28 pm	03.35 pm	00.07 Hr	828	LED Tubelight not working	Central Store	01.08.2022	03.45 pm	
4	01.08.2022	12.56 pm	01.10 pm	00.14 Hr	5468	LED Tubelight not working	MSW	01.08.2022	03.35 pm	
5	01.08.2022	10.20 am	10.45 am	00.25 Hr	333	Wall fan not working	Psychatric ward	02.08.2022	04.10 pm	
6	01.08.2022	11.19 am	11.45 am	00.26 Hr	3331	LED Tubelight not working	PSM Dept.	04.08.2022	02.00 pm	
7	01.08.2022	12.30 pm	12.45 pm	00.15 Hr	2873	Switch Board not working	MICU	01.08.2022	01.25 pm	
8	02.08.2022	09.30 am	09.45 am	00.15 Hr	335	Wall fan not working	Psychatric ward	02.08.2022	10.45 am	
9	02.08.2022	10.00 am	10.45 pm	00.45 Hr	192	X-Ray Box not working	FSW	02.08.2022	11.05 am	
10	02.08.2022	02.10 pm	02.40 pm	00.30 Hr	569	Split AC not working	Dental OPD	03.08.2022	10.40 am	
11	02.08.2022	11.25 am	11.45 am	00.20 Hr	6227	LED Tubelight not working	CSSD	04.08.2022	11.00 am	
12	02.08.2022	02.25 pm	02.45 pm	00.20 Hr	1300	Colling fan removing work	Hemotology ICU	04.08.2022	11.00 am	
13	02.08.2022	02.10 pm	02.30 pm	00.20 Hr	6	Cilling Fan Deposit in Elect dept	Hemotology ICU	06.08.2022	10.40 am	
14	02.08.2022	04.24 pm	04.45 pm	00.21 Hr	953	Split AC not working	CATH-LAB	03.08.2022	10.40 am	
15	03.08.2022	11.40 am	12.20 pm	00.40 Hr	831	1.5TR Split AC not working	2D Eco	03.08.2022	04.10 pm	
16	03.08.2022	12:30 pm	12.45 pm	00.15 Hr	2069	Standing Fan not Working	MJPJAY ICU	06.08.2022	11.50 am	
17	03.08.2022	02.15 pm	02.45 pm	00.30 Hr	469	Switch Board not working	OT Complex	04.08.2022	02.15 pm	
18	03.08.2022	09.45 am	10.00 am	00.15 Hr	1073	Tharmameter not working	MJPJAY ward	03.08.2022	10.50 am	
19	03.08.2022	03.00 pm	03.10 pm	00.10 Hr	3884	Switch Board not working	Dialysis	03.08.2022	03.30 pm	
20	04.08.2022	02.55 pm	03.15 pm	00.20 Hr	1719	LED 15watt not working	CCU+CVTS	04.08.2022	04.15 pm	
21	04.08.2022	11.01 am	11.35 am	00.34 Hr	3506	Pendent switch Board not working	MCRI ICU	04.08.2022	04.00 pm	
22	04.08.2022	01.00 pm	02.40 pm	01.40 Hr	95	LED 12Watt not working	Central library			Work in progress
23	04.08.2022	09.45 am	10.00 am	00.15 Hr	4869	Tharmameter not working	Nephrology ward	04.08.2022	12.00 pm	
24	05.08.2022	02.41 pm	02.55 pm	00.14 Hr	6418	Switch Board not working	Isolation ICU	08.08.2022	04.21 pm	
25	05.08.2022	03.00 pm	03.20 pm	00.20 Hr	5475	Electrical problame	MSW	05.08.2022	04.15 pm	
26	05.08.2022	12.50 pm	02.00 pm	01.10 Hr	258	LED 15watt not working	MCRI OPD	05.08.2022	02.15 pm	
27	06.08.2022	11.50 am	12.10 pm	00.20 Hr	2095	1.5TR Split AC not working	MJPJAY ICU	08.08.2022	12.25 pm	
28	06.08.2022	12.00 pm	12.10 pm	00.10 Hr	2021	Switch Board not working	MJPJAY ICU	06.08.2022	12.45 pm	
29	06.08.2022	11.50 am	12.00 pm	00.10 Hr	2096	Switch Board not working	MJPJAY ward	06.08.2022	03.50 pm	
30	06.08.2022	08.29 am	09.00 am	00.31 Hr	3742	10Hp Motor Not working	Time Office	06.08.2022	09.00 am	
31	06.08.2022	01.00 pm	02.40 pm	01.40 Hr	4482	Exhouast Fan not working	F.Ortho ward	07.08.2022	02.00 pm	
32	06.08.2022	10.51 am	11.00 am	00.09 Hr	7609	LED Bulb not working	Old Deluxe	06.08.2022	11.15 am	
33	06.08.2022	12.00 pm	12.45 pm	00.45 Hr	474	Switch Board not working	OT Complex			Work in progress
34	06.08.2022	10.30 am	10.45 am	00.15 Hr	1246	Switch Board not working	MET Cell	06.08.2022	10.45 am	
35	06.08.2022	03.01 pm	03.30 pm	00.29 Hr	23222	LED 15watt not working	Nursing College	08.08.2022	11.00 am	
36	07.08.2022	12.20 pm	12.20 pm	00.00 Hr	4873	Switch Board not working	Nephrology ward	07.08.2022	02.00 pm	

Pending work

1	13.07.2022	04.38 pm	05.00 pm	00.22 Hr	95	LED Bulb not working	CATH-LA			Work in progress
2	22.07.2022	02.40 pm	03.10 pm	00.30 Hr	3736	Cabin Light Required	Time Office			Requirement work
3	30.07.2022	10.10 am	10.30 am	00.20 Hr	7053	LED 12Watt not working	EMS Ward			Work in progress
4	30.07.2022	10.15 am	11.10 am	00.25 Hr	250	Refregator not working	MCRI OPD	02.08.2022	11.40 am	

Total Complaint	40
Pending Complaint	4
Complete Complaint	36
Complaint Precentrage	90%

M.V.Gaikwad
MGM Aurangabad

Electrical Engineer
MGM Aurangabad

Technical Executive(Elect.)
MGM Aurangabad

Electrical Supervisor
MGM Aurangabad

MGM MEDICAL COLLEGE & HOSPITAL

ELECTRICAL MAINTANCE REPORT 08/08/2022 to 14/08/2022 14.08.2022

Sr.No.	Received Date	Time	Attende Time	Response Time	Cpmplaint No.	Nature Of Complent	Name Of Department	Date Of Complation	Close Time	Remark
1	08.08.2022	11.45 am	12.10 pm	00.25 Hr	4481	LED Tubelight not working	F.Ortho ward	08.08.2022	03.35 pm	
2	08.08.2022	02.46 pm	02.55 pm	00.09 Hr	1286	3HP Motor rewinding work	CSSD	12.08.2022	01.00 pm	
3	08.08.2022	04.34 pm	04.55 pm	00.21 Hr	3747	Water Filter not working	D' Hostel	13.08.2022	12.00 pm	
4	08.08.2022	01.00 pm	02.40 pm	01.40 Hr	337	Switch Board not working	Psy ward	08.08.2022	04.10 pm	
5	08.08.2022	03.30 pm	03.50 pm	00.20 Hr	475	LED Tubelight not working	OT Complex	09.08.2022	03.00 pm	
6	08.08.2022	04.00 pm	04.30 pm	00.30 Hr	375	Cat-06 Cable laying	Endoscophy			Work in progress
7	08.08.2022	07.00 am	09.10 am	02.10 Hr	3748	Lift No-05 not working	Time Office	09.08.2022	03.15 pm	
8	08.08.2022	03.25 pm	04.10 pm	00.45 Hr	6527	LED Panel 15 & 18watt not working	Pathalogy			Work in progress
9	08.08.2022	02.10 pm	02.40 pm	00.30 Hr	338	LED Tubelight & LED Bulb not work	Psy ward	08.08.2022	11.30 am	
10	09.08.2022	09.55 am	10.00 am	00.05 Hr	1687	LED Tubelight not working	Surgery OPD	09.08.2022	10.20 am	
11	09.08.2022	12.00 pm	12.45 pm	00.45 Hr	799	LED Tubelight not working	Time Office	09.08.2022	03.20 pm	
12	09.08.2022	12.05 pm	03.10 pm	03.05 Hr	7714	Exhouast Fan not working	OBGY Dept.			Work in progress
13	09.08.2022	11.10 am	11.45 am	00.35 Hr	2564	LED Tubelight not working	Opthalmology	09.08.2022	02.30 pm	
14	09.08.2022	03.03 pm	03.50 pm	00.47 Hr	6231	LED Tubelight not working	CSSD	10.08.2022	11.20 am	
15	10.08.2022	02.30 pm	02.55 pm	00.25 Hr	7558	LED Panel 15 & 18watt not working	5th Floor Covid	10.08.2022	02.55 pm	
16	10.08.2022	03.00 pm	03.15 pm	00.15 Hr	3121	LED Tubelight not working	Linen Department	10.08.2022	03.15 pm	
17	10.08.2022	03.15 pm	03.20 pm	00.05 Hr	4015	LED 15watt not working	MICU	10.08.2022	03.30 pm	
18	10.08.2022	10.40 am	10.55 am	00.15 Hr	7557	AC Pipe line water lickage problame	Super Deluxe			Work in progress
19	10.08.2022	03.26 pm	03.40 pm	00.14 Hr	800	Switch Board not working	Time Office	10.08.2022	03.40 pm	
20	10.08.2022	02.35 pm	03.00 pm	00.25 Hr	4874	Exhouast Fan not working	Nephrology ward	11.08.2022	03.00 pm	
21	10.08.2022	04.00 pm	06.00 pm	02.00 Hr	ED001	Electrical Busbar fitting work	IVF Centare	10.08.2022	05.05 pm	
22	11.08.2022	09.30 am	09.40 am	00.10 Hr	2565	LED Tubelight not working	Opthalmology	11.08.2022	09.40 am	
23	11.08.2022	03.16 pm	03.20 pm	00.04 Hr	4016	Tempreture Meter not working	MICU	11.08.2022	09.20 am	
24	11.08.2022	11.54 am	12.25 pm	00.31 Hr	127	LED 15watt not working	Radiology Dept	13.08.2022	10.20 am	
25	11.08.2022	08.35 am	09.02 am	00.27 Hr	3749	Lift No-05 not working	Time Office	11.08.2022	01.35 pm	
26	11.08.2022	03.40 pm	03.50 pm	00.10 Hr	477	Switch Board not working	OT Complex	12.08.2022	03.05 pm	
27	12.08.2022	12.50 pm	12.55 pm	00.05 Hr	5263	AHU not working	OT Complex	12.08.2022	01.30 pm	
28	13.08.2022	04.50 pm	05.05 pm	00.15 Hr	955	LED Pannel not working	CATH-LAB			Work in progress
29	13.08.2022	02.35 pm	02.55 pm	00.20 Hr	481	LED Tubelight not working	OT Complex	13.08.2022	02.55 pm	
30	13.08.2022	11.18 am	12.10 pm	00.52 Hr	1607	Switch Board not working	ENT Ward	14.08.2022	11.55 am	
31	13.08.2022	12.15 pm	12.40 pm	00.25 Hr	5480	Switch Board not working	M.Surjery ward			Work in progress
	Pending work									
1	13.07.2022	04.38 pm	05.00 pm	00.22 Hr	950	LED Bulb not working	CATH-LAB	13.08.2022	04.10 pm	
2	22.07.2022	02.40 pm	03.10 pm	00.30 Hr	3736	Cabin Light Required	Time Office			Work in progress
3	30.07.2022	10.10 am	10.30 am	00.20 Hr	7053	LED 12Watt not working	EMS Ward	13.08.2022	05.45 pm	

5	04.08.2022	12.40 pm	01.00 pm	00.20 Hr	2[illegible]	RO Filter cleaning work	MCRI OPD	09.08.2022	03.00 pm	Work in progress
6	06.08.2022	12.00 pm	12.45 pm	00.45 Hr	474	Switch Board not working	OT Complex	09.08.2022	03.10 pm	

Total Complaint	38
Pending Complaint	8
Complete Complaint	30
Complaint Precentrage	79%

M.V.Gaikwad
MGM Aurangabad

Electrical Engineer
MGM Aurangabad

Technical Executive(Elect.)
MGM Aurangabad

Electrical Supervisor
MGM Aurangabad

MGM MEDICAL COLLEGE & HOSPITAL

ELEC RICAL MAINTANCE REPORT 15/08/2022 to /08/2022 21.08.2022

Sr.No.	Received Date	Time	Attende Time	Response Time	Cpmplaint No.	Nature Of Complent	Name Of Department	Date Of Complation	Close Time	Remark
1	15.08.2022	04.00 pm	04.05 pm	00.05 Hr	7622	LED 14watt light not working	Old Deluxe	15.08.2022	04.05 pm	
2	16.08.2022	12.30 pm	12.55 pm	00.25 Hr	4484	Switch Board not working	F.Ortho ward	16.08.2022	12.55 pm	
3	16.08.2022	02.45 pm	03.10 pm	00.25 Hr	571	LED light not Working	Dental OPD	17.08.2022	10.20 am	
4	16.08.2022	02.55 pm	03.40 pm	00.45 Hr	7433	LED Tubelight, LED 15watt & Cilling Fan not working	Anatomy	16.08.2022	02.45 pm	
5	16.08.2022	11.22 am	12.10 pm	00.48 Hr	340	Cilling Fan not working	Psy.Ward	17.08.2022	04.05 pm	
6	16.08.2022	02.50 pm	03.15 pm	00.25 Hr	5082	Extention Board not working	NICU	16.08.2022	03.25 pm	
7	16.08.2022	09.48 am	10.15 am	00.27 Hr	1721	Water Lickege problame LED Removing	CCU+CVTS	16.08.2022	10.25 am	
8	17.08.2022	12.01 pm	12.45 pm	00.44 Hr	956	De-Humidifire not working	CATH-LAB	19.08.2022	05.00 pm	
9	17.08.2022	10.16 am	10.20 am	00.04 Hr	1968	Tempreture Meter not working	Pead.OPD	17.08.2022	10.25 am	
10	17.08.2022	12.00 pm	12.05 pm	00.05 Hr	1187	Tempreture Meter not working	M.Ortho ward	17.08.2022	12.05 pm	
11	17.08.2022	03.30 pm	03.45 pm	00.15 Hr	1608	LED Tubelight not working	ENT Ward	18.08.2022	10.30 am	
12	17.08.2022	07.30 am	08.20 am	00.50 Hr	3751	Lift No-05 not working	Time Office	18.08.2022	03.45 pm	
13	17.08.2022	02.15 pm	02.20 pm	00.05 Hr	485	Switch Board not working	OT Complex	17.08.2022	02.31 pm	
14	17.08.2022	04.00 pm	04.20 pm	00.20 Hr	23227	Cat-06 Cable laying	Nursing College			Work in progress
15	17.08.2022	10.30 am	11.10 am	00.40 Hr	1248	LED 15watt not working	MET Cell	17.08.2022	12.40 pm	
16	17.08.2022	10.47 am	11.10 am	00.23 Hr	2532	LED Tubelight not working	Record Section	17.08.2022	12.55 pm	
17	17.08.2022	11.30 am	11.45 am	00.15 Hr	1287	LED Tubelight not Working	Biomedical Dept.	17.08.2022	11.45 am	
18	18.08.2022	03.10 pm	04.15 pm	00.55 Hr	3753	Lift No-05 Light not working	Time Office	20.08.2022	02.40 pm	
19	18.08.2022	11.30 am	12.00 pm	00.30 Hr	1289	Oxygen Pump Electrical connection	Central Oxygen Plant	20.08.2022	09.55 pm	
20	18.08.2022	12.26 pm	02.40 pm	02.14 Hr	7625	Refregator not working	Old Deluxe	21.08.2022	02.10 pm	
21	18.08.2022	11.50 am	12.10 pm	00.20 Hr	1946	LED Tubelight & Cilling fan not working	House kiping Dept.	18.08.2022	03.00 pm	
22	18.08.2022	12.50 pm	12.55 pm	00.05 Hr	1415	Split AC not working	MJPJAY ward	18.08.2022	02.10 pm	
23	18.08.2022	12.00 pm	12.25 pm	00.25 Hr	7779	Refregator & Cilling fan not working	MCRI Canteen	22.08.2022	02.55 pm	
24	18.08.2022	12.23 pm	12.55 pm	00.32 Hr	1723	Gizar not working	CCU+CVTS	19.08.2022	03.10 pm	
25	19.08.2022	04.10 pm	04.50 pm	00.40 Hr	1615	Refregator not working	Opthal Ward	21.08.2022	12.10 pm	
26	19.08.2022	10.00 am	10.15 am	00.15 Hr	7074	Switch Board not working	EMS Ward	20.08.2022	02.30 pm	
27	20.08.2022	03.10 pm	03.15 pm	00.05 Hr	3887	Tempreture Meter not working	Dialysis	20.08.2022	03.25 pm	
28	20.08.2022	11.50 am	12.10 pm	00.20 Hr	3755	Lift No-12 not working	Time Office	20.08.2022	02.50 pm	
29	20.08.2022	04.10 pm	04.20 pm	00.10 Hr	7568	Extention Board not working	Super Deluxe	20.08.2022	04.20 pm	
30	20.08.2022	12.18 pm	12.35 pm	00.17 Hr	936	Electrical problame	Central Lab.	20.08.2022	03.50 pm	
31	20.08.2022	02.51 pm	03.05 pm	00.14 Hr	342	Switch Board not working	Psy.Ward	22.08.2022	03.35 pm	
32	20.08.2022	03.00 pm	03.20 pm	00.20 Hr	1727	Gizar not working	CCU+CVTS	22.08.2022	02.46 pm	

Pending work

1	22.07.2022	02.40 pm	03.10 pm	00.30 Hr	3736	Cabin Light Required	Time Office	21.08.2022	11.50 am	
2	04.08.2022	01.00 pm	02.40 pm	01.40 Hr	95	LED 2' x 2' fitting not working	Central library			Work in progress
3	08.08.2022	04.00 pm	04.30 pm	00.30 Hr	375	Cat-06 Cable laying	Endoscophy			Work in progress
4	08.08.2022	03.25 pm	04.10 pm	00.45 Hr	6527	LED Panel 15 & 18watt not working	Pathalogy	18.08.2022	02.40 pm	
5	09.08.2022	12.05 pm	03.10 pm	03.05 Hr	7714	Exhouast Fan not working	OBGY Dept.	17.08.2022	10.30 am	
6	10.08.2022	10.40 am	10.55 am	00.15 Hr	7557	AC Pipe line water lickage problame	Super Deluxe	17.08.2022	03.45 pm	
7	12.08.2022	01.20 pm	02.40 pm	01.20 Hr	954	De-Humidifire not working	CATH-LAB	19.08.2022	05.00 pm	
8	13.08.2022	04.50 pm	05.05 pm	00.15 Hr	955	LED Pannel not working	CATH-LAB	16.08.2022	02.30 pm	
9	13.08.2022	12.15 pm	12.40 pm	00.25 Hr	5480	Switch Board not working	M.Surjery ward	17.08.2022	03.40 pm	

Total Complaint	41
Pending Complaint	3
Complete Complaint	38
Complaint Precentrage	93%

M.V.Gaikwad
MGM Aurangabad

Electrical Engineer
MGM Aurangabad

Technical Executive(Elect.)
MGM Aurangabad

Electrical Supervisor
MGM Aurangabad

MGM MEDICAL COLLEGE & HOSPITAL

ELECTRICAL MAINTANCE REPORT 22/08/2022 to 28.08.2022

Sr.No.	Received Date	Time	Attende Time	Response Time	Cpmplaint No.	Nature Of Complent	Name Of Department	Date Of Complation	Close Time	Remark
1	22.08.2022	09.35 am	10.10 am		937	VRV Not working	Central Lab.	22.08.2022	05.20 pm	
2	22.08.2022	01.30 pm	02.00 pm		7627	Switch Board not working	Old Deluxe	22.08.2022	03.30 pm	
3	22.08.2022	11.41 am	12.10 pm		7080	LED 15watt not working	Casualty	22.08.2022	03.45 pm	
4	22.08.2022	11.41 am	12.55 pm		7079	Electrical problame	Casualty	22.08.2022	03.10 pm	
5	22.08.2022	12.40 pm	12.50 pm		491	Extention Board not working	OT Complex	22.08.2022	01.10 pm	
6	23.08.2022	09.40 am	10.31 am		3756	LED Tubelight not working	Time Office	23.08.2022	10.41 am	
7	23.08.2022	12.30 pm	02.10 pm		2103	LED Tubelight not working	Step down ICU	24.08.2022	10.45 am	
8	23.08.2022	11.45 am	12.30 pm		1950	LED Tubelight not working	House kiping Dept.	24.08.2022	05.45 pm	
9	23.08.2022	12.50 pm	12.50 pm		1290	1/2 HP Motor not working	Biomedical Dept.	25.08.2022	09.55 am	
10	23.08.2022	11.29 am	12.10 pm		4877	Gizar not working	Nephrology ward	23.08.2022	05.15 pm	
11	24.08.2022	12.00 pm	12.10 pm		3890	VRV Not working	Dialysis	24.08.2022	02.30 pm	
12	24.08.2022	01.00 pm	02.30 pm		1103	LED Tubelight & Cilling fan not work	Physiology Dept.	24.08.2022	03.30 pm	
13	24.08.2022	11.55 am	12.30 pm		7631	Gizar not working	Old Deluxe	24.08.2022	04.40 pm	
14	24.08.2022	11.00 am	11.55 am		5090	Switch Board not working	NICU	24.08.2022	04.00 pm	
15	24.08.2022	11.38 am	12.40 pm		7569	LED 15watt not working	Super Deluxe	25.08.2022	02.55 pm	
16	24.08.2022	12.30 pm	01.10 pm		4802	Fan Regulator not working	FSW	25.08.2022	03.15 pm	
17	24.08.2022	10.45 am	11.00 am		3757	10Hp Motor Not working	Time Office			Work in progress
18	24.08.2022	04.00 pm	04.45 pm		1728	Extention Board not working	CCU+CVTS	25.08.2022	04.15 pm	
19	24.08.2022	03.24 pm	04.10 pm		7633	LED Bulb not working	Old Deluxe	24.08.2022	04.10 pm	
20	24.08.2022	03.05 pm	04.15 pm		7635	Cilling Fan not working	Old Deluxe	24.08.2022	05.00 pm	
21	24.08.2022	12.00 pm	12.30 pm		745	Switch Board not working	FMW	24.08.2022	12.30 pm	
22	25.08.2022	10.45 am	11.00 am		2106	Switch Board not working	Step down ICU	25.08.2022	12.45 pm	
23	25.08.2022	10.42 am	11.10 am		7637	Electrical problame	Old Deluxe	25.08.2022	02.25 pm	
24	26.08.2022	02.00 pm	03.20 pm		6425	Split AC not working	Isolation ICU	27.08.2022	10.40 am	
25	26.08.2022	01.00 pm	02.40 pm		4486	LED light not Working	F.Ortho ward	27.08.2022	10.05 am	
26	26.08.2022	03.30 pm	04.20 pm		4879	Gizar not working	Nephrology ward	27.08.2022	11.05 am	
27	26.08.2022	11.25 am	11.45 am		2789	Extention Board not working	New Deluxe	27.08.2022	12.00 pm	
28	26.08.2022	10.30 am	11.10 am		7577	LED 15watt not working	Super Deluxe	27.08.2022	12.45 pm	
29	27.08.2022	10.20 am	10.40 am		7642	Refregator not working	Old Deluxe	27.08.2022	11.45 am	
30	27.08.2022	11.35 am	12.10 pm		4881	LED Tubelight & Cilling fan not work	Nephrology ward	28.08.2022	01.00 pm	
31	27.08.2022	09.45 am	11.55 am		4487	Switch Board not working	F.Ortho ward	27.08.2022	06.25 pm	
32	27.08.2022	09.20 am	11.20 am		7084	LED light not Working	Casualty	27.08.2022	01.18 pm	
33	27.08.2022	12.34 pm	12.55 pm		3337	Water filter not working	PSM Dept.	27.08.2022	03.45 pm	
34	27.08.2022	02.45 pm	03.00 pm		2108	Switch Board not working	Step down ICU	27.08.2022	03.15 pm	
35	27.08.2022	10.04 am	11.00 am		283	Exhouast Fan not working	OPD Complex	27.08.2022	02.30 pm	
36	28.08.2022	07.50 pm	07.59 pm		2723	Electrical problame	Pead.ward	28.08.2022	07.59 pm	

1	04.08.2022	01.00 pm	02.40 pm	01.40 Hr	9[illegible]	**Pending work**				
2	04.08.2022	02.20 pm	02.40 pm		3758	LED 2' x 2' fitting not working	Central lib[illegible]y			Work in progress
3	05.08.2022	10.20 am	11.10 am		3741	RO Filter cleaning work	Radiology Dept	04.08.2022	03.35 pm	
4	08.08.2022	04.00 pm	04.30 pm	00.30 Hr	375	Cat-06 Cable laying	Time Office	08.08.2020	12.45 pm	
5	08.08.2022	10.40 am	11.10 am		3332	RO Filter cleaning work	Endoscophy			Work in progress
6	15.08.2022	10.20 am	10.45 am		4019	AHU Water lickage	PSM Dept.	08.08.2022	02.20 pm	
7	16.08.2022	12.01 pm	12.35 pm		4020	AC Pipe line water lickage problame	MICU	15.08.2022	11.10 am	
8	17.08.2022	04.00 pm	04.20 pm	00.20 Hr	23227	Cat-06 Cable laying	MICU	16.08.2022	03.00 pm	
9	17.08.2022	02.20 pm	03.00 pm		5083	Humidity Meter Replace work	Nursing College	22.08.2022	02.40 pm	
10	18.08.2022	09.20 am	09.40 am		488	AHU Filter damaged	NICU	17.08.2022	04.00 pm	
11	18.08.2022	11.45 am	12.10 pm		935	VRV Not working	OT Complex	18.08.2022	11.00 pm	
12	20.08.2022	02.15 pm	03.50 pm		1951	LED Tubelight not working	Central Lab.	18.08.2022	02.00 pm	
13	21.08.2022	09.00 am	11.00 am		ED002	Electrical Shut down work Canseld	House kiping Dept.	21.08.2022	03.50 pm	
14	21.08.2022	04.10 pm	04.50 pm		276	Call Bell Required	Panel-01	21.08.2022	11.00 am	
							MCRI OPD-12	23.08.2022	11.56 am	

Total Complaint	50
Pending Complaint	3
Complete Complaint	47
Complaint Precentrage	94%

M.V.Gaikwad
MGM Aurangabad

Electrical Engineer
MGM Aurangabad

Technical Executive(Elect.)
MGM Aurangabad

Electrical Supervisor
MGM Aurangabad

MGM MEDICAL COLLEGE & HOSPITAL

ELECTRICAL MAINTANCE REPORT 29/08/2022 to 03.09.2022

Sr.No.	Received Date	Time	Attende Time	Response Time	Cpmplaint No.	Nature Of Complent	Name Of Department	Date Of Complation	Close Time	Remark
1	29.08.2022	11.30 am	12.10 pm	00.40 Hr	4804	Switch Board not working	FSW	29.08.2022	03.15 pm	
2	29.08.2022	04.15 pm	04.20 pm	00.05 Hr	830	Cardless Bell not working	Central Store	29.08.2022	04.27 pm	
3	29.08.2022	11.30 am	11.45 am	00.15 Hr	23238	Lift not working	C' Building	29.08.2022	11.45 am	
4	29.08.2022	09.42 am	10.35 am	00.53 Hr	7643	Gizar not working	Old Deluxe	30.08.2022	03.50 pm	
5	29.08.2022	10.31 am	11.20 am	00.49 Hr	344	Gizar not working	Psychatric ward	30.08.2022	03.40 pm	
6	30.08.2022	02.01 pm	02.55 pm	00.54 Hr	345	Wall fan not working	Psychatric ward	30.08.2022	03.30 pm	
7	30.08.2022	03.16 pm	04.15 pm	00.59 Hr	5270	LED Tubelight not working	OT Complex	01.09.2022	04.30 pm	
8	30.08.2022	10.38 am	11.01 am	00.23 Hr	1084	LED Tubelight not working	MJPJAY ward	30.08.2022	04.40 pm	
9	31.08.2022	12.45 pm	01.00 pm	00.15 Hr	5489	Cilling Fan not working	MSW	31.08.2022	01.00 pm	
10	01.09.2022	09.20 am	10.10 am	00.50 Hr	4883	Gizar not working	Nephrology ward	01.09.2022	11.00 am	
11	01.09.2022	10.15 am	10.35 am	00.20 Hr	7583	LED 15watt not working	Super Deluxe	01.09.2022	10.35 am	
12	01.09.2022	04.15 pm	04.30 pm	00.15 Hr	347	Wall fan not working	Psychatric ward	01.09.2022	05.00 pm	
13	01.09.2022	01.15 pm	02.30 pm	01.15 Hr	7649	Cilling Fan not working	Old Deluxe	01.09.2022	05.10 pm	
14	01.09.2022	12.23 pm	12.35 pm	00.12 Hr	346	Wall fan not working	Psychatric ward	04.09.2022	11.00 am	
15	01.09.2022	03.53 pm	04.10 pm	00.17 Hr	1024	LED Tubelight not working	MMW	02.09.2022	10.00 am	
16	01.09.2022	11.20 am	12.00 pm	00.40 Hr	1614	LED Tubelight not working	Opthal Ward	02.09.2022	04.00 pm	
17	02.09.2022	12.19 pm	02.10 pm	01.51 Hr	3067	LED Bulb not working	Microbiology	02.09.2022	03.00 pm	
18	02.09.2022	09.42 am	12.10 pm	02.28 Hr	7651	LED 15watt not working	Old Deluxe	02.09.2022	05.00 pm	
19	02.09.2022	03.00 pm	03.30 pm	00.30 Hr	287	LED 12Watt not working	MCRI OPD	02.09.2022	04.15 pm	
20	03.09.2022	10.20 am	10.35 am	00.15 Hr	132	AHU not working	Casualty	03.09.2022	11.05 am	
21	03.09.2022	03.15 pm	03.25 pm	00.10 Hr	7089	AHU not working	Casualty	03.09.2022	04.35 pm	
22	03.09.2022	11.15 am	11.45 am	00.20 Hr	6530	Extention Board not working	Pathalogy	03.09.2022	10.45 am	
23	03.09.2022	12.15 pm	12.40 pm	00.25 Hr	2728	63amp 4pole MCCB Replaced	New Pead.	03.09.2022	03.40 pm	
	Pending work									
1	04.08.2022	01.00 pm	02.40 pm	01.40 Hr	95	LED 2' x 2' fitting not working	Central library	01.09.2022	04.20 pm	
2	08.08.2022	04.00 pm	04.30 pm	00.30 Hr	375	Cat-06 Cable laying	Endoscophy			Work in progress
3	24.08.2022	10.45 am	11.00 am	00.15 Hr	3757	10Hp Motor Not working	Time Office	02.09.2022	10.30 am	
4	27.08.2022	02.27 pm	03.10 pm	00.43 Hr	2308	LED 15watt not working	Ex.Deluxe	01.09.2022	10.00 am	
5	27.08.2022	11.00 am	11.20 am	00.20 Hr	284	Call Bell Repeiring work	MCRI OPD	02.09.2022	03.40 pm	

Total Complaint	28
Pending Complaint	1
Complete Complaint	27
Complaint Precentrage	96%

M.V.Gaikwad
MGM Aurangabad

Electrical Engineer
MGM Aurangabad

Technical Executive(Elect.)
MGM Aurangabad

Electrical Supervisor
MGM Aurangabad

MGM MEDICAL COLLEGE & HOSPITAL

ELECTRICAL MAINTANCE REPORT 05/09/2022 to 10/09/2022 11.09.2022

Sr.No.	Received Date	Time	Attende Time	Response Time	Cpmplaint No.	Nature Of Complent	Name Of Department	Date Of Complation	Close Time	Remark
1	03.09.2022	10.20 am	11.10 am		3101	LED Tube light not working	OT Complex	07.09.2022	02.30 pm	
2	05.09.2022	10.25 am	10.35 am		1117	VRV Not working	OBGY ICU	05.09.2022	12.10 pm	
3	05.09.2022	10.00 am	10.15 am		941	LED 15watt panel Ceiling fan not wor	Central Lab.	05.09.2022	11.00 am	
4	05.09.2022	10.20 am	10.35 am		7586	LED 15watt not working	Super Deluxe	05.09.2022	01.10 pm	
5	05.09.2022	12.10 pm	12.45 pm		7587	Switch Board not working	Super Deluxe	05.09.2022	12.45 pm	
6	05.09.2022	11.15 am	11.35 am		561	Fan Regulator not working	Psychatric OPD	05.09.2022	12.00 pm	
7	05.09.2022	05.00 pm	05.21 pm		7653	LED 15watt not working	Old Deluxe	05.09.2022	05.30 pm	
8	05.09.2022	11.30 am	12.15 pm		910	LED Tube light & Ceiling fan not wor	OBGY Ward II	06.09.2022	10.00 am	
9	05.09.2022	03.28 pm	03.40 pm		609	Switch Board not working	SICU	06.09.2022	10.30 am	
10	05.09.2022	12.27 pm	12.40 pm		289	Switch Board not working	MCRI OPD	06.09.2022	12.40 pm	
11	06.09.2022	03.20 pm	03.40 pm		Letter	Ceiling Fan not working	Medical Store	06.09.2022	04.38 pm	
12	06.09.2022	09.55 am	10.45 am		3767	10Hp Motor Not working	Time Office	06.09.2022	03.00 pm	
13	06.09.2022	11.16 am	11.25 am		7588	Switch Board not working	Super Deluxe	07.09.2022	11.56 am	
14	06.09.2022	09.40 am	10.10 am		3768	LED 15watt not working	Time Office	07.09.2022	11.40 pm	
15	06.09.2022	10.00 am	11.10 am		3104	LED 15watt not working	OT Complex	07.09.2022	02.30 pm	
16	07.09.2022	10.44 am	11.05 am		7589	LED 15watt panel Ceiling fan not wor	Super Deluxe	07.09.2022	12.15 pm	
17	07.09.2022	10.40 am	10.55 am		1723	AHU not working	CVTS OT	07.09.2022	02.00 pm	
18	07.09.2022	12.30 pm	12.55 pm		962	LED 15watt not working	CATH-LAB			Water leakage
19	07.09.2022	02.30 pm	02.45 pm		3897	Switch Board not working	Dialysis	07.09.2022	03.15 pm	
20	07.09.2022	03.46 pm	04.00 pm		1505	Switch Board not working	CVTS	07.09.2022	04.20 pm	
21	07.09.2022	03.00 pm	03.30 pm		7095	Pedestal Fan not working	Casualty	10.09.2022	11.10 am	
22	08.09.2022	07.30 am	08.40 am		3772	Lift No-05 not working	Time Office	08.09.2022	09.20 am	
23	08.09.2022	03.40 pm	04.00 pm		3106	LED Tube light not working	OT Complex	10.09.2022	03.30 pm	
24	09.09.2022	11.30 am	11.30 am		Letter	63amp 4pole MCCB Replaced	OT Complex	09.09.2022	11.30 am	
25	09.09.2022	10.10 am	10.35 am		3773	Lift No-07 Not working	Time Office	09.09.2022	10.25 am	
26	10.09.2022	11.30 am	11.50 am		2342	LED Tube light not working	OBGY OPD	10.09.2022	12.35 pm	
27	10.09.2022	11.31 am	11.55 am		2341	Ceiling Fan not working	OBGY OPD	10.09.2022	05.30 pm	
28	10.09.2022	11.50 am	11.55 am		3108	LED Tube light not working	OT Complex	10.09.2022	02.40 pm	
29	10.09.2022	04.10 pm	04.20 pm		1092	Temperature Meter not working	MJPJAY ward	10.09.2022	04.20 pm	
30	10.09.2022	04.25 pm	04.45 pm		2325	Ceiling Fan not working	Ex.Deluxe	12.09.2022	11.35 am	
31	10.09.2022	04.25 pm	04.45 pm		2326	LED 15watt panel Ceiling fan not wor	Ex.Deluxe	12.09.2022	11.35 am	
32	11.09.2022	03.50 pm	04.15 pm		7660	LED Bulb not working	Old Deluxe	11.09.2022	04.55 pm	
	Pending work									
1	08.08.2022	04.00 pm	04.30 pm	00.30 Hr	375	Cat-06 Cable laying	Endoscophy			Work in progress

PTO

Total Complaint	
Pending Complaint	2
Complete Complaint	31
Complaint Precentrage	94%

M.V.Gaikwad
MGM Aurangabad

Electrical Engineer
MGM Aurangabad

Technical Executive(Elect.)
MGM Aurangabad

Electrical Supervisor
MGM Aurangabad

MGM MEDICAL COLLEGE & HOSPITAL

ELECT CAL MAINTANCE REPORT 12/09/2022 to 1 9/2022 18.09.2022

Sr.No.	Received Date	Time	Attende Time	Response Time	Cpmplaint No.	Nature Of Complent	Name Of Department	Date Of Complation	Close Time	Remark
1	12.09.2022	10.53 am	11.00 am		1733	Table fan not working	CCU+CVTS	12.09.2022	03.15 pm	
2	12.09.2022	12.11 pm	12.35 pm		1902	Pedestal Fan not working	Central library	13.09.2022	03.10 pm	
3	13.09.2022	10.23 am	11.05 am		1688	Cilling Fan not working	Surgery OPD	13.09.2022	11.05 am	
4	13.09.2022	04.30 pm	04.45 pm		193	LED Tube light not working	PICU	14.09.2022	12.20 pm	
5	13.09.2022	11.42 am	12.25 pm		1727	Extention Board not working	CVTS OT	14.09.2022	12.25 pm	
6	13.09.2022	10.40 am	11.05 am		1250	LED 15watt not working	MET Cell	13.09.2022	11.50 am	
7	13.09.2022	10.45 am	11.35 am		7662	Gizar not working	Old Deluxe	13.09.2022	03.55 pm	
8	13.09.2022	12.00 pm	12.30 pm		3114	X-Ray Box not working	OT Complex			Work in progress
9	14.09.2022	10.45 am	11.00 am		3778	LED 15watt not working	Time Office	14.09.2022	11.15 am	
10	14.09.2022	11.00 am	11.19 am		2876	LED 18watt Panel	MICU	20.09.2022	10.15 am	
11	14.09.2022	02.35 pm	03.00 pm		6246	LED Bulb not working	CSSD	14.09.2022	04.30 pm	
12	15.09.2022	08.40 am	08.55 am		3779	Lift No-06 Not working	Time Office	15.09.2022	11.00 am	
13	15.09.2022	02.00 pm	03.15 pm		1243	Exhouast fan & LED Tube light not w	Plastic surjery ward	15.09.2022	03.15 pm	
14	15.09.2022	10.30 am	10.35 am		1421	Switch Board not working	MJPJAY ward	16.09.2022	11.00 am	
15	15.09.2022	11.34 am	02.55 pm		4690	Cilling Fan not working	MMW	17.09.2022	11.30 am	
16	15.09.2022	12.04 pm	02.40 pm		3503	LED Tube light not working	MCRI OPD	16.09.2022	10.29 am	
17	15.09.2022	02.15 pm	03.25 pm		1632	LED Tube light not working	Opthal Ward	16.09.2022	10.50 pm	
18	16.09.2022	12.00 pm	12.45 pm		1633	LED Tube light not working	ENT Ward	16.09.2022	02.15 pm	
19	16.09.2022	12.04 pm	02.40 pm		1093	Exhouast Fan not working	MJPJAY ward			Work in progress
20	16.09.2022	04.07 pm	04.30 pm		2798	Call Bell not working	New Deluxe			Work in progress
21	16.09.2022	10.57 am	11.55 am		362	Switch Board not working	MGM-School Bio.	19.09.2022	04.10 pm	
22	16.09.2022	01.55 pm	02.10 pm		202	Tempreture Meter not working	Casualty	16.09.2022	02.10 pm	
23	16.09.2022	02.50 pm	03.00 pm		3120	LED Tube light not working	OT Complex	16.09.2022	03.50 pm	
24	16.09.2022	03.00 pm	04.20 pm		19	X-Ray Box not working	Medicine OPD	17.09.2022	11.24 am	
25	16.09.2022	03.22 pm	03.40 pm		1122	Switch Board not working	OBGY ICU	17.09.2022	04.15 pm	
26	16.09.2022	09.38 am	09.55 am		3780	Lift No-06 Not working	Time Office	16.09.2022	10.30 am	
27	16.09.2022	10.15 am	11.35 am		5494	Cilling Fan not working	M.Surjery ward	17.09.2022	10.20 am	
28	16.09.2022	10.16 am	11.20 am		5495	Exhouast Fan not working	M.Surjery ward	17.09.2022	10.45 am	
29	17.09.2022	02.45 pm	03.00 pm		1959	Cilling Fan not working	HR Department	17.09.2022	03.15 pm	
30	17.09.2022	11.58 am	02.20 pm		3507	VRV not working	MCRI OPD	17.09.2022	02.00 pm	
31	17.09.2022	11.45 am	12.30 pm		3782	Cilling Fan not working	Time Office	17.09.2022	02.35 pm	
32	17.09.2022	04.30 pm	04.45 pm		2334	LED light not Working	Ex.Deluxe	19.09.2022	02.58 pm	
33	17.09.2022	03.00 pm	03.40 pm		141	Refregator Light not working	MCRI Canteen			

Pending work

1	08.08.2022	04.00 pm	04.30 pm	00.30 Hr	375	Cat-06 Cable laying	Endoscophy			Work in progress
2	07.09.2022	12.30 pm	12.55 pm		962	LED 15watt not working	CATH-LAB	14.09.2022	10.36 am	Work in progress

Total Complaint	7
Pending Complaint	5
Complete Complaint	30
Complaint Precentrage	86%

M.V.Gaikwad
MGM Aurangabad

Electrical Engineer
MGM Aurangabad

Technical Executive(Elect.)
MGM Aurangabad

Electrical Supervisor
MGM Aurangabad

MGM MEDICAL COLLEGE & HOSPITAL

ELECTRICAL MAINTANCE REPORT 19/09/2022 to 25/09/2022 25.09.2022

Sr.No.	Received Date	Time	Attende Time	Response Time	Cpmplaint No.	Nature Of Complent	Name Of Department	Date Of Complation	Close Time	Remark
1	19.09.2022	12.00 pm	03.00 pm		2335	Ceiling Fan not working	OT Complex	20.09.2022	12.23 pm	
2	19.09.2022	11.20 am	11.45 am		4810	Switch Board not working	FSW	20.09.2022	01.10 pm	
3	19.09.2022	10.37 am	11.00 am		7673	Switch Board not working	Old Deluxe	19.09.2022	11.20 am	
4	19.09.2022	01.10 pm	02.05 pm		4493	Fan Regulator not working	F.Ortho ward	19.09.2022	02.40 pm	
5	20.09.2022	10.05 am	10.20 am		4280	LED TV Electrical Problame	IT Department	20.09.2022	10.20 am	
6	20.09.2022	12.30 pm	12.35 pm		3127	Tempreture Meter not working	OT Complex	20.09.2022	12.35 pm	
7	20.09.2022	04.15 pm	05.00 pm		1925	Wall fan not working	Waiting area	24.09.2022	02.20 pm	
8	21.09.2022	11.15 pm	01.10 pm		3786	Fouantain repairing work	Time Office	21.09.2022	02.45 pm	
9	21.09.2022	02.49 pm	03.00 pm		3135	Switch Board not working	OT Complex	22.09.2022	03.15 pm	
10	21.09.2022	10.41 am	11.10 am		963	Chilld water pipeline water lickage	CATH-LAB	21.09.2022	05.00 pm	
11	21.09.2022	04.17 pm	05.00 pm		5350	Split AC not working	Blood Bank	22.09.2022	01.00 pm	
12	21.09.2022	10.26 am	11.25 am		1975	LED Tube light & Ceiling fan not working	Pead.ward	22.09.2022	03.47 pm	
13	22.09.2022	11.30 am	11.55 am		1246	Exhouast, Cilling fan & Switch Board repairing work.	Plastic surjery ward	25.09.2022	04.15 pm	
14	22.09.2022	09.35 am	10.00 am		109	Ceiling Fan not working	School of Physiolopy	23.09.2022	01.30 pm	
15	22.09.2022	10.15 am	10.23 am		3349	LED Tubelight not working	Dermatology	22.09.2022	10.23 am	
16	22.09.2022	11.56 am	12.10 pm		2150	LED Tube light not working	OPD Complex	22.09.2022	03.00 pm	
17	23.09.2022	10.45 am	10.55 am		1952	Exhouast fan & LED Tube light not working	OPD Complex	23.09.2022	11.25 am	
18	23.09.2022	01.00 pm	02.45 pm		1976	Big Switch board replace work	Pead.ward			Work in progress
19	23.09.2022	11.10 am	11.20 am		1560	Switch Board not working	Metron Office	23.09.2022	03.15 pm	
20	23.09.2022	11.30 am	11.55 am		5514	Call Bell not working	Opthal OPD	26.09.2022	11.48 am	
21	23.09.2022	10.00 am	10.30 am		3789	RO repairing work	Time Office	23.09.2022	10.45 am	
22	23.09.2022	09.10 am	10.12 am		3787	Lift No-04 not working	Time Office	24.09.2022	10.20 am	
23	23.09.2022	12.50 pm	02.55 pm		23237	Cilling Fan not working	Nursing College			Work in progress
24	24.09.2022	02.27 pm	03.10 pm		210	LED 15watt not working	Casualty			Work in progress
25	24.09.2022	12.30 pm	12.45 pm		993	Focus lamp not working	Labour Room	26.09.2022	12.20 pm	
26	24.09.2022	01.00 pm	02.10 pm		1977	Refregator not working	Pead.ward			Work in progress
27	24.09.2022	02.20 pm	02.40 pm		208	Tempreture Meter not working	Casualty	24.09.2022	02.40 pm	
28	24.09.2022	10.45 am	11.00 am		7712	Exhouast Fan not working	OBGY ward	24.09.2022	12.25 pm	
29	24.09.2022	12.30 pm	12.45 pm		5499	Exhouast Fan not working	MSW	24.09.2022	12.30 pm	
30	24.09.2022	12.25 pm	12.45 pm		621	Switch Board not working	SICU	24.09.2022	03.30 pm	
31	24.09.2022	12.30 pm	12.45 pm		992	Fan Regulator not working	Labour Room	24.09.2022	03.45 pm	
32	24.09.2022	12.00 pm	12.20 pm		4811	Exhouast fan-08, 12mod. Switch Board-02, fan regulator-02, Cilling fan not working	FSW	25.09.2022	04.30 pm	

33	24.09.2022	09.30 am	09.45 am		3790	Water level Sensor Instalation	06th Floor	24.09.2022	01.20 pm	
34	24.09.2022	10.10 am	10.35 am		141	FCU water leackage	Radiology D	24.09.2022	04.30 pm	

Pending work

1	08.08.2022	04.00 pm	04.30 pm	00.30 Hr	375	Cat-06 Cable laying	Endoscophy			Work in progress
2	13.09.2022	12.00 pm	12.30 pm		3114	X-Ray Box not working	OT Complex			Work in progress
3	16.09.2022	12.04 pm	02.40 pm		1093	Exhouast Fan not working	MJPJAY ward	24.09.2022	04.35 pm	
4	16.09.2022	04.07 pm	04.30 pm		2798	Call Bell not working	New Deluxe			Work in progress
5	17.09.2022	03.00 pm	03.40 pm		141	Refregator Light not working	MCRI Canteen			Work in progress
6	17.09.2022	04.20 pm	04.45 pm		961	Pipe line water leakage	CATH-LAB	21.09.2022	05.00 pm	
7	17.09.2022	03.00 pm	04.15 pm		1422	LED Bulb not working	MJPJAY ward	24.09.2022	05.10 pm	

Total Complaint	41
Pending Complaint	9
Complete Complaint	32
Complaint Precentrage	78%

M.V.Gaikwad
MGM Aurangabad

Electrical Engineer
MGM Aurangabad

Technical Executive(Elect.)
MGM Aurangabad

Electrical Supervisor
MGM Aurangabad

MGM MEDICAL COLLEGE & HOSPITAL

ELECTRICAL MAINTANCE REPORT 10/10/2022 to 1[illegible]0/2022

Sr.No.	Received Date	Time	Attende Time	Response Time	Cpmplaint No.	Nature Of Complent	Name Of Department	Date Of Complation	Close Time	Remark
1	10.10.2022	10.31 am			3081	One light not working	Microbiology	10/10/2022	4.35 pm	
2	10.10.2022	03.39 pm			3800	One light not working	Time office	10/10/2022	5.00 pm	
3	11.10.2022	11.19 am			2128	3 light not working	EMS ward	11/10/2022	12.14 pm	
4	11.10.2022	04.00 pm			2705	Supply not working	Pead opd	11/10/2022	4.10 pm	
5	11.10.2022	03.25 pm			921	Bathroom light not working	OBGY WD II(TLWD)	11/10/2022	04.50 pm	
6	12.10.2022	03.40 pm			2349	Room no 606 ceiling fan not working properly	Delux ward	12/10/2022	3.50 pm	
7	12.10.2022	11.35 am			1743	15 W LED 2 Nos replace	CCU	12/10/2022	5.00 pm	
8	12.10.2022	10.06 am			222	Tubelight not working	Casualty	13/10/2022	2.20 pm	
9	12.10.2022	10.06 am			224	4 nos of tubelight not working at open space	Casualty	13/10/2022	02.25 pm	
10	12.10.2022	11.55 am			223	Fixing of lamp wire properly	Casualty	13/10/2022	02.30 pm	
11	13.10.2022	09.30 am			364	Tubelight one female unit and one wall fan not working	PSY ward	13/10/2022	3.30 pm	
12	12.10.2022	06.00 pm			3764	Lift no 4 not working	Time office	13/10/2022	10.05 am	
13	13.10.2022	09.45 am			291	Tubelight not working	S.S opd	14/10/2022	10.10 am	
14	13.10.2022	09.25 am			423	Check short circuit in cardio opd	Physiotherpy opd	13/10/2022	11.00 am	
15	14.10.2022	11.20 am			1223	Tubelight not working	OBGY ward -I	14/10/2022	12.45 pm	
16	11.10.2022	02.55 pm			288	View box not working properly	S.S OPD	14/10/2022	12.25 pm	
17	14.10.2022	02.30 pm			3548	Extension board 3 pin not working	MCRI	14/10/2022	3.00 pm	
18	12.10.2022	04.15 pm			912	One light not working	Dyotan hall	14/10/2022	03.31 pm	
19	14.10.2022	03.10 pm			23	Two light not working	MED OPD	14/10/2022	04.00 pm	
20	14.10.2022	10.30 am			145	Paitent toilet light not working	Radiology	15/10/2022	04.00 pm	
21	14.10.2022	12.30 pm			2742	2 tubelight not working	New peadiatric ward	15/10/2022	12.45 pm	
22	14.10.2022	10.25 am			2350	Room no 614 bathroom light not work	Execative delux	15/10/2022	10.15 am	
23	13.10.2022	11.20 am			7	Tube light broken	MMW	13/10/2022	12.10 pm	
24	14.10.2022	03.00 pm			3153	Tubelight in ot no 8 not working	OT complex	17/10/2022	03.50 pm	
25	14.10.2022	03.40 pm			336	Bathroom light not working	PSY ward	18/10/2022	02.00 pm	
26	16-10-2022	11.59 am			904	Fishpot light not working	Time office			**work in Progress**
27	16-.10.2022	11.59 am			905	Lift no 1 not working	Time office	16-10-2022	2.30 pm	
28	16.10.2022	04.07 pm			2798	Bell point not working	New delux			**work in Progress**
29	16.10.2022	02.20 pm			906	Akash kandil fixing work	Time office			**work in Progress**

Total Complaint	7
Pending Complaint	3
Complete Complaint	26
Complaint Precentrage	90%

M.V.Gaikwad
MGM Aurangabad

Electrical Engineer
MGM Aurangabad

Technical Executive(Elect.)
MGM Aurangabad

Electrical Supervisor
MGM Aurangabad