



**MGM INSTITUTE OF HEALTH SCIENCES
CENTRAL PURCHASE DEPARTMENT (CPD)**

Plot 1 & 2, Sector -1 Kamothe, Navi Mumbai - 410209

e Tender of HEPA Filter of HVAC PLANT

Tenders invited from reputed Manufactures of HEPA Filter at MGM Hospital, Kamothe, Navi Mumbai in the format given bellow:

Name & Address of Vendor: _____

Sr. No	Description	CFM	Unit	Qty	Rate per Unit Supply (Excluding GST)	Rate per Unit Labour (Excluding GST)	Total Supply (Excluding GST)	Total Labour (Excluding GST)	Total Supply + Labour (Excluding GST)
A	HEPA Filter								
1.1	915 X 610 X 75	1050	Nos.	12					
1.2	610 X 762 X 75	870	Nos.	48					
	<u>Technical Specification of HEPA Filters Filter.</u> Make : Airtech MOC: Aluminium extersion Efficiency: EU 14, 99.999 % down to 0.3 micron Media depth: 45 mm Pleats / Feet or pocket / feet: 65 Gasket type: Gel seal type.								
B	Supply of Fine Filter - 3 Micron Flange Type								
1.1	610 X 610 X 380	2000	nos	10					
1.2	610 X 310 X 380	1000	nos	6					
1.3	610 X 610 X 150	2000	nos	2					
1.4	610 X 310 X 150	1000	nos	2					
	<u>Technical Specification Fine Filter. 3 micron</u> Make: Airtech Efficiency: 99 % down to 3 Micron IPD : 8 MM WG FPD: 22 MM WG Frame: Aluminium Media: HDPE + Non-Woven Synthetic + HDPE Grade: EU 07 Temperature: Ambient Gasket: Food Grade								
C	Supply of Combination - Flange Type & Box type.								
2.1	610 X 610 X 200	1000	nos	12					
2.2	510 X 510 X 50	500	nos	12					
2.3	510 X 510 X 150	1400	nos	11					
2.4	405 X 405 X 50	500	nos	11					
2.5	610 X 310 X 200	1000	nos	8					

2.6	510 X 510 X 50	1000	nos	8					
2.7	610 X 610 X 380	2000	nos	6					
2.8	510 X 510 X 50	500	nos	6					
2.9	610 X 310 X 380	1000	nos	6					
2.10	510 X 205 X 50	500	nos	6					
2.11	610 X 610 X 150	1000	nos	4					
2.12	510 X 510 X 50	500	nos	4					
2.13	610 X 310 X 150	1000	nos	2					
2.14	510 X 205 X 50	500	nos	2					

Technical Specification of Combination Filter.

Make: Airtech
Efficiency: 90 % down to 10 micron + 99 % down to 3 micron
IPD: 6-7 MM WG
FPD: 22 MM WG
Frame: Aluminium
Media: HDPE + non woven synthetic + HDPE
Grade: EU - 4 + EU - 07
Temperature: Ambient
Gasket: Food Grade

D	Old HEPA filter removing		nos	60					
E	New HEPA Filter installation.		nos	60					
F	Transportation		lot	1					
G	Buy Back of Old Filters		lot						

Total Cost

Terms & Conditions:

Warranty On Site:

Delivery Period of Material:

Installation Time:

Payment Terms: 20% Advance PO, 50% after Delivery & 30% after Installation.

Kindly email your lowest quotations for above item with detailed specifications, terms and conditions as well as applicable Brochure / Catlog, Client list with installation Year and their Contact numbers to etenders@mgmuhs.com only.

Date:	Signature of Tenderer:
Seal	Name:
	Designation:
	Email ID:
	Mobile No.:
	Full Address: